PREDICTED INFECTION RISK FOR AEROSOL TRANSMISSION OF SARS-COV-2

Martin Kriegel[1], Udo Buchholz[2], Petra Gastmeier[3], Peter Bischoff[3], Inas Abdelgawad[4], Anne Hartmann[1]

[1] Technical University of Berlin, Hermann-Rietschel-Institut

[2] Robert-Koch-Institute, Department for Infectious Disease Epidemiology

[3] Charité-University Medicine Berlin, Institute for Hygiene and Environmental Medicine

[4] Public Health Department Berlin Spandau

Address for correspondence:

Prof. Dr.-Ing. Martin Kriegel

Hermann-Rietschel-Institut

TU Berlin

m.kriegel@tu-berlin.de

Author contributions:

MK extended the existing models and performed the calculation. UB and IA supplied the data for retrospective analysis to validate the model. PG, PB, UB and IA evaluated the results from a medical point of view. AH performed the literature research and the review of the models and calculations. MK and AH drafted the manuscript. All authors contributed to the interpretation of the results, critically revised the paper and agreed on the final version for submission.

1 Abstract

Currently, the respiratory route is seen as the most important transmission path for SARS-

CoV-2. In this investigation, models of other researchers which had the aim of predicting an

infection risk for exposed persons in a room through aerosols emitted by an infectious case-

patient were extended. As a novelty – usually neglected – parameters or boundary conditions,

namely the non-stationarity of aerosols and the half-life of the aerosolized virus, were

included and a new method for determining the quanta emission rate based on measurements

of the particle emission rate and respiratory rate at different types of activities was

implemented.

As a second step, the model was applied to twelve outbreaks to compare the predicted

infection risk with the observed attack rate. To estimate a "credible interval" of the predicted

infection risk, the quanta emission rate, the respiratory rate as well as the air volume flow

were varied.

In nine out of twelve outbreaks, the calculated predicted infection risk via aerosols was found

to be in the range of the attack rate (with the variation of the boundary conditions) and

reasons for the observed larger divergence were discussed.

The validation was considered successful and therefore the use of the model could be

recommended to predict the risk of an infection via aerosols in given situations. Furthermore,

appropriate preventive measures can be designed.

21 Introduction

The respiratory route is the main mode of transmission for the virus causing COVID-19

(SARS-CoV-2) [1, 2, 3]. The virus is transported on particles that can enter the respiratory

tract. Whereas larger particles (droplets) are only able to stay in the air for a short time and

just in the near field (approx. 1.5 m), due to rapid settling, smaller particles (called aerosols)

are also concentrated in the near field and in addition can follow the air flow and cause

infections in the far field. Epidemiologically, short-range transmission (through aerosols or

droplets) is distinguished from long-range transmission (aerosol).

In order to perform an infection risk assessment for the airborne transmission in the far field

and to introduce appropriate preventive measures, it would be necessary to know the amount

of aerosols produced by an infected person during various activities, how many viruses stick

to the aerosols and how many viruses are necessary to cause an infection. However, this

information is usually available only very late in the course of a pandemic, if it can be

determined at all. Another well-known approach is to use retrospective analysis of infection

outbreaks that are very probably due to far field transmission to determine a virus-laden

aerosol concentration. Exposed people have inhaled the virus-laden aerosols according to

their respiratory volume flow. The approach presented here corresponds to a combination of

known measured source rates of respiratory aerosols at different activities and the

retrospective analysis of previous infection incidents with the aim to calculate a predicted

infection risk via aerosols and to calculate the necessary air volume flow to reduce the risk of

COVID-19 infections.

Current state

The so-called aerosols (liquid or solid particles in a dispersed phase with a fluid) as well as

droplets differ by size. The particles, which are transported in a fluid over a longer distance,

are called aerosols. Droplets are more strongly influenced by gravitation and are deposited

more rapidly. The size of particles which can be transported in air for a longer distance varies

with the velocity of the fluid. In internal spaces with typical air velocities of up to 0.2 m/s

particles smaller than 10 μm will be distributed by air very well; with a higher air velocity,

larger particles may also be transported in air.

SARS-CoV-2 was found to be transmitted via close contact as well as over distance in

internal spaces, whereas in distant transmission so-called super-spreading events are more

probable [1, 2, 4].

In 1978, Riley et al. [5] evaluated a measles outbreak in a suburban elementary school. Based

on the number of susceptible persons (S), which have been infected (D) during each stage of

infection, the risk (P) for an infection in this stage has been calculated with equation (1).

Therefore, the risk for an infection has been defined as the percentage of infected persons

from the number of pupils not already infected or vaccinated.

$$P = \frac{D}{S} \tag{1}$$

59   A Poisson-distribution of the risk of infection has been assumed as well as a stationary and

60   evenly distributed concentration of the pathogens in the room air. Equation (2) shows the

61   Poisson-distribution.

$$P = 1 - e^{-\lambda} \tag{2}$$

62   Therefore, Wells defined in 1955 [6] a size called quantum as the number of emitted

63   infectious units, where the probability to get infected is $1 - e^{-1} = 63.2\%$. Hence, a quantum

64   can be seen as a combination of the number of emitted aerosols with the virus transported on

65   them and a critical dose which may result in an infection in 63.2 % of the exposed persons.

66   Riley [5] combined the quantum concept with equation (2) to produce equation (3).

$$P = 1 - e^{-I \cdot q \cdot Q_b \cdot t / Q} \tag{3}$$

In equation (3), the number of infectious persons (I), the quanta emission rate depending on

the activity (q), the pulmonary ventilation rate of exposed susceptible persons (Q_b), the

duration of stay (t) and the volume flow of pathogen free air (Q) was used. The quotient q/Q

represents the quanta concentration.

In poorly ventilated rooms, the assumption of a stationary concentration of quanta is not

justified, because of the amount of time necessary before a stationary concentration is

reached. The normalized time-dependent concentration process can be calculated according to

equation (4) and is shown in Figure 1. How rapidly the concentration of a human emitted

contamination in a room raises depends on the air exchange rate (ACH) and the time (t). This

relative concentration (c_{rel}) can be seen as an increase in the concentration compared to the

volume flow.

$$c_{rel} = 1 - e^{-ACH \cdot t} \tag{4}$$

Figure 1: Relative concentration curve as a function of air exchange rate and time.

In all published studies identified, ideal mixing ventilation was assumed, which means that

aerosols are evenly distributed in the room air. To avoid this assumption Noakes and Sleigh

[7] divided the room air into different zones, which are themselves considered to be well

mixed and have a uniform concentration. This should make it possible to calculate local

differences in concentration and thus locally differing infection risks. Furthermore, other

studies, which focus on the unsteady conditions mostly use the boundary condition of a

starting concentration of $c(t = 0) = 0 \frac{quanta}{m^3}$. Gammaitoni and Nucci [8] implemented the

starting condition of $c(t = 0) = c_0$ as well as the number of exposed susceptible people,

which may also change over time depending on their immune status.

To estimate the risk of infection in a given setting by a given infectious person with the

Wells-Riley-equation either the quanta emission rate or the P have to be known. In the

beginning of an epidemic, both values are unknown. Dai and Zhao [9] correlated and

calculated q for SARS-CoV-2 based on the basic reproduction number (R_0) known from

former outbreaks of MERS, tuberculosis, influenza and SARS-CoV-1 and published the

equation (5). If R_0 is known, q can be estimated as proposed by Dai and Zhao [9]. For SARS-

CoV-2 the average basic reproduction number has been estimated to be 3.28 [10], 3.32 [11]

and 3.77 [12].

$$q = -30.27958 - 44.81536 \cdot R_0 + 19.67934 \cdot R_0^2 \qquad\qquad (5)$$

In various studies of infection occurrences associated with SARS-CoV-2, q was determined

using the Wells-Riley equation. Different authors [9, 13] found a range of 22 to 61 quanta/h

with an assumed low activity (breathing, speaking) and values of 341 to 1190 quanta/h when

singing.

The virus can be transported on particles in air and the emission of aerosols can be used as an

indicator for the emission of the virus, but a correlation between q and the aerosol emission

rate (E) has not been investigated so far. In measurements at the Hermann-Rietschel-Institute

(HRI) of Technical University of Berlin [14, 15] the particle emission rates during breathing,

speaking, coughing as well as singing was measured. During breathing through the nose about

25 particles/s was emitted and during coughing about 13,700 particles/cough. It is therefore

evident that depending on the activity a wide range of particle emission rates can be found.

The transmission of a pathogen via aerosols is also influenced by the stability of the virus in

the environment. In an experimental study van Doremalen et al [16] measured the decrease of

infectious virus in the air and on different surfaces and compared SARS-CoV-1 and SARS-

CoV-2. Under the given conditions, the half-life of SARS-CoV-2 as well as SARS-CoV-1

was about 1.1 h.

The longer aerosols stay in the room air, the more the proportion of inactivated virus

increases. The age of air is dependent on the airflow as well as the position of the source of

the pollutants. At each point in the room, a local age of air can be calculated. The age of air

(τ_n) can be used as a measure to evaluate the air quality. For an ideal mixing ventilation, the

mean age of air is equal to the nominal time constant, which can be calculated using equation

(6) as the quotient of the room volume (V) and the air volume flow (Q).

$$\tau_n = \frac{V}{Q} \tag{6}$$

Besides the number of emitted pathogen-laden aerosols, the number of inhaled pathogens also

plays an important role, with regard to the assessment of the risk of infection. The pulmonary

ventilation rate may differ with different activities. Gupta et al. [17] performed a study with

25 healthy adults and found that the volume flow fluctuated in the form of a sine wave during

simple breathing, but gave a more constant volume flow during talking.

In measurements with athletes as well as sedentary persons a maximum volume flow for the

athletes of 200 l/min (12 m³/h) was found by Córdova and Latasa [18].

To measure the airflow without movement restrictions, a helmet was used by Jiang et al. [19]

in 32 subjects (16 males, 16 females) during speaking with different volumes as well as

during singing.

A comparison between a machine-learning based model and measurements of respiratory rate

was performed by Dumond et al. [20].

As a conclusion, the following average values can be used for adults:

• low activity (breathing while lying): 0.45 m^3/h [19]

• low activity (breathing while sitting, standing or talking): 0.54 m^3/h [19, 20]

• singing: 0.65 m^3/h [21]

• mid activity (physical work): 0.9 m^3/h [20]

• sports: 1.2 m^3/h [18, 20]

For children, the lung volume is smaller. Therefore, the respiratory rate for children aged 14

can be assumed to be 0.45 m^3/h for low activity (breathing while sitting, standing, talking)

[22].

Methods

Extension of the Wells-Riley equation for calculating the Predicted Infection Risk via

Aerosols (PIRA)

The Wells-Riley equation can be summarized as equation (7). To calculate the predicted

infection risk via aerosols (PIRA) in the far field of a room the concentration of quanta (c(t))

and the respiratory rate (Q_b) must be known. The integration of c(t) can be understood as the

number of particles inhaled per m^3/h. Together with Q_b, the number of inhaled quanta can

therefore be calculated.

$$PIRA = 1 - e^{(-\int [c(t)] \cdot Q_b)} \tag{7}$$

Equation (5) can be used for the definition of the quantum emission. This leads to a quanta

emission rate of q = 40 1/h at an assumed mean $R_0 = 3.35$. The mathematical approximation

presented by Dai und Zhao [9] can be optimized by equation (8), see Figure 2. For Figure 2

the quanta emission rate has been correlated with R_0 of tuberculosis [23, 24], Influenza [23,

25], MERS [26, 27] and SARS-CoV [23, 28].

Equation (8) results in q = 139 1/h for an assumed mean R_0 = 3.35. Because of the high

variance of the q as well as R_0 given in the currently available literature the difference

between the q calculated regarding equation (5) and equation (8) seems reasonable.

Figure 2: Relationship between quanta emission rate and R_0 according Dai and Zhao [9]

$$q_0 = 2.7618 \cdot (e^{1.1761 \cdot R_0} - 1) \tag{8}$$

q is influenced by the activity of the person as was shown by Buonanno et al. [29]. Therefore,

the measured aerosol emission rates E [14, 15] were correlated with the calculated quanta

emission rates influenced by the activity q_a by equation (9). For low-activity (breathing,

talking, sitting, standing) a basic volume flow $Q_{b,o}$ and normal activity = low activity

(breathing, talking, sitting, standing) with a basic emission rate of E_0 was used. Furthermore,

the basic q (q_0) was calculated with usage of R_0 regarding equation (8). With these

specifications q_a can be calculated.

$$q_a = q_0 \cdot \frac{E}{E_0} \cdot \frac{Q_b}{Q_{b,0}} \qquad\qquad (9)$$

$$Q_{b,0} = 0.54 \frac{m^3}{h}; \qquad E_0 = 100 \frac{P}{s} \,[15]$$

173   The effect of e.g. mouth-nose protection can be considered by using their filtration efficiency

174   (F_{MNS}) like in equation (10) which however will not be further considered in the following.

$$q_{a,MNS} = F_{MNS} \cdot q_a \qquad\qquad (10)$$

It is known that the infectivity of an infected person depends on the disease progression over

time [30]. This is shown qualitatively in Figure 3. With a simplified mathematical approach,

this can be integrated into the quanta source rate. An equation could be implemented to take

this into account.

Figure 3: Infectivity depending on the disease progression

Under experimental conditions, the half-life of virus was measured as 1.1 h [16]. Thus, the

number of emitted infectious quanta at time t ($q_a(t)$) is calculated according to equation (11).

$$q_a(t) = q_a \cdot e^{(-0.5776 \cdot t)} = q_a \cdot e^{\left(-\frac{361}{625} \cdot t\right)} \tag{11}$$

185   The concentration of quanta during the increase $c_I(t)$ can be calculated according to equation

186   (12) with the number of infectious persons (n).

$$c_I(t) = \frac{q_a(t)}{Q} \cdot n \cdot \left(1 - e^{(-ACH \cdot t)}\right) \tag{12}$$

187   An additional case is considered that if the time t is longer than the age of the air τ_n, most of

188   the virus-laden aerosols have left the room with the exhaust before the inactivation can take

189   place. Therefore, this concentration during the steady state situation is called $c_\tau(t)$.

$$q_{a,\tau} = q_a \cdot e^{(-0.5776 \cdot \tau_n)} \tag{13}$$

$$c_\tau(t) = \frac{q_{a,\tau}}{Q} \cdot n \cdot \left(1 - e^{(-ACH \cdot t)}\right) \tag{14}$$

190   with τ_n regarding equation (6)

192   For calculating the risk of infection the unsteady concentrations c_I and c_τ has to be used, to

193   include the time-dependent increase in concentration and to include the time-dependent

194   viability of the virus, otherwise the result could be overestimated or underestimated.

195   For equation (7) the integration of $c_I(t)$ and $c_\tau(t)$ is necessary.

$$C_I = \int_0^t c_I(t)$$

$$= \frac{q_a \cdot \left(390625 \cdot ACH - \left((390625 \cdot ACH + 225625) \cdot e^{ACH \cdot t} - 225625\right) \cdot e^{-ACH \cdot t - \frac{361}{625} \cdot t}\right)}{Q \cdot (225625 \cdot ACH + 130321)} \tag{15}$$

$$C_\tau = \int_\tau^{t \geq \tau_n} c_\tau(t) = \frac{q_{a,\tau} \cdot e^{-ACH \cdot (t + \tau_n)} \cdot \left(ACH \cdot (t - \tau_n) \cdot e^{ACH \cdot (t + \tau_n)} - e^{ACH \cdot t} + e^{ACH \cdot \tau_n}\right)}{Q \cdot ACH} \tag{16}$$

197   The Predicted Infection Risk via Aerosols can be calculated by equation (17) and (18).

$$PIRA = 1 - e^{(-(C_I(t=\tau) + C_\tau) \cdot Q_b)} \qquad t > \tau_n \tag{17}$$

$$PIRA = 1 - e^{(-(C_I) \cdot Q_b)} \qquad\qquad t \leq \tau_n \qquad\qquad\qquad (18)$$

For the calculation of PIRA the following assumptions must be considered:

• the aerosols are ideally mixed in the room

• the near field (up to approx. 1.5 m distance from the emitting person) can contain a

much higher virus-laden aerosol concentration

• the air, which is introduced into the room, is free of virus-laden aerosols (e.g. outside

air)

• no deposition of small particles is considered, because the settling time is longer than

the stability of the virus and the deposition rate would therefore be substantially

smaller than the inactivation

• the concentration of aerosols at the beginning is 0

Results

The PIRA calculation model was validated by using parameters of several known outbreaks

during the SARS-CoV-2 pandemic. Twelve different scenarios either scientifically published

or registered by the local health authorities were selected (A-L). The boundary conditions for

the calculations of these situations can be found in Table 1.

Table 1: Boundary conditions of SARS-CoV-2 outbreaks for the retrospective calculation of PIRA

	A	B	C	D	E	F	G	H	I	J	K	L
V in m^3	3000	1200	60*	630	254	830	180	150	150	47	170	60***
n	1	1	1	1	1	1	1	1	1	1	1	1
q_a in 1/h	232	4213	139	139	139	4213	116	116	139	139	139	139
Q_b in m^3/h	0.9	0.65	0.54	0.54	0.54	0.65	0.45	0.45	0.54	0.54	0.54	0,54
Q in m^3/h	1600	200*	200*	4000**	50*	200*	1500*	1500*	400*	75	200*	1260***
exposure time t in h	8	2.5	1.66	8	1.5	2.5	4.5*****	1.5*****	4.5*****	1.2	2	11
Attack Rate**** in %	26%	91%	34%	5%	58%	87%	10%	6%	43%	45%	17%	63%

*due to partly missing information, assumptions were made, especially for window ventilation. The assumptions are based on information from the persons involved on how the windows were opened and closed in combination with weather data at the time.

** It was assumed that the local regulations for fresh air supply were fulfilled.

***Geometry and Ventilation Rate due to [31]

****Attack Rate was simplified as percentage of persons infected. No separation regarding infection attack rate (measured serologically) and illness attack rate (persons with symptoms or laboratory-confirmed) was performed.

***** It was assumed that a school lesson lasts 45 minutes.

	Setting	Country	Remarks
A	Slaughterhouse [32]	Germany	
B	Choir rehearsal Berlin	Germany	not yet scientifically published, investigated by Robert-Koch-Institute
C	Bus Tour [33]	China	
D	Call Center [34]	Korea	The attack rate is mentioned as 43 % in the publication. However, the infection occurred almost exclusively on one half of the 11th floor. The local attack rate is therefore actually significantly higher. In Table 1 an attack rate of 5% was given, because only persons who had shown symptoms were quarantined. If one includes the persons who showed symptoms up to and including 04.02., the attack rate is 5 %.
E	Club Meeting	Germany	not yet scientifically published, investigated by Robert-Koch-Institute
F	Choir rehearsal Skagiq [13]	USA	
G	School Berlin 1	Germany	not yet scientifically published, investigated by Public Health Department Berlin Spandau
H	School Berlin 2	Germany	not yet scientifically published, investigated by Public Health Department Berlin Spandau
I	School Israel [35]	Israel	
J	Restaurant [1, 36]	China	
K	Meeting	Germany	not yet scientifically published, investigated by Robert-Koch-Institute
L	Aircraft [37]	-	

The infection events used for the validation of the model are shown in Table 1 with the

necessary parameters for the calculation. In the following, the comparison between the

documented Attack Rate (AR) and the PIRA is drawn.

The q used here was calculated according to equation (9) with the assumption that the cases

emitted particles as measured in [14, 15]. Due to the high spread of the particle emission E

and the unknown proportions of breathing, speaking, singing and shouting as well as the

respiratory volume flows, simplified a-priori assumptions were made. To take into account

the effects of the uncertainties regarding q, Q_b and especially with window ventilation on Q,

these values were further varied - q by +/- 20%, Q_b by +/- 20% and Q by +/- 50%,

individually and in combination, which then lead to a minimum PIRA and maximum PIRA.

Figure 4 presents PIRA and the minima and maxima calculated with the different variants.

The red dots show the documented AR.

Figure 4: Comparison between PIRA with the variants Min and Max to the documented AR

assuming that all cases were caused by long-range transmission

In nine out of twelve outbreaks, the attack rate lies in the Min Max values of the calculated

PIRA (see Table 2).

Table 2: Results of the Calculation of PIRA and comparsion with the documented AR

	A	B	C	D	E	F	G	H	I	J	K	L
PIRA	25%	92%	35%	13%	16%	97%	13%	4%	48%	40%	21%	44%
Min	17%	79%	19%	6%	10%	88%	6%	2%	26%	35%	11%	22%
Max	35%	99%	58%	30%	24%	99%	31%	11%	75%	56%	36%	80%
AR (documented)	26%	91%	34%	5%	58%	87%	10%	6%	43%	45%	17%	63%

From the PIRA model, it can be calculated how much volume flow per hour of exposure time

is required to not exceed a certain PIRA. The results are shown in Figure 5. It can be seen that

for a PIRA of 10% a volume flow of clean air of 750 m³/h and hour of exposure has to be

supplied to the room (see Table 3), whereas for two hours 1500 m³/h will be necessary for the

same PIRA.

As a regression of the calculated results presented in Figure 5, equation (19) was derived.

Using equation (19) the required volume flow per hour of exposure time can be calculated.

This information refers to the steady state if the product of ACH and t is higher than 5.0, see

Figure 1. If the product is smaller, correspondingly lower volume flows lead to the respective

PIRA.

$$Q_{sp} = 75 \cdot \frac{1}{PIRA} \qquad (19)$$

247 *Figure 5: Required specific volume flow per hour exposure time with regard to meeting a*

248 *specific PIRA*

250 Table 3 lists practical examples of the required volume flows depending on the exposure time

251 and PIRA.

252 *Table 3: Required volume flow at a certain exposure time for a defined PIRA*

					PIRA
			1%	5%	10%
exposure time in h		1	7500 m³/h	1500 m³/h	750 m³/h
		2	15000 m³/h	3000 m³/h	1500 m³/h
		3	22500 m³/h	4500 m³/h	2250 m³/h

Another type of evaluation shows the possible number of infected persons in relation to the

person-related volume flow and the number of persons in a room (see Figure 6), if several

exposed persons are in a room and each person would have 6 m³ of room volume available. If

more volume flow is available to each person, the result changes marginally and tends

towards a lower PIRA. For an exposure time of two hours a volume flow of 20 m³/(h·Per)

resulted in five probably infected persons in a room with 20, 40 or 100 persons, but of course

only one probably infected person in a room with two persons. For a volume flow of

60 m³/(h·Per) the number decreases to two probably infected persons in a room with 20, 40 or

100 persons, but of course stayed at one probable person for just two persons in a room.

Figure 6: Number of persons probably infected according to a specific volume flow

Discussion

For the first time with a q based on R_0 the PIRA was calculated for different known SARS-

CoV-2 outbreaks. In addition, the necessary air volume flows to reduce the risk of infection

were calculated.

In Table 4 the q-values are compared according to the stationary equation (3) and the PIRA

model under the boundary conditions of Table 1. Large differences between the same

activities were observed in the calculation of the steady-state.

First of all, in comparison, with fixed q according to equation (9) very good agreement can be

achieved with the documented AR in the retrospectively considered cases A, B, C, H, I, J, K.

Table 4: comparison steady state and unsteady calculated quanta

	q in 1/h											
	A	B	C	D	E	F	G	H	I	J	K	L
q steady state	255	344	275	965	67	449	808	2545	223	144	411	330
q unsteady	232	4213	139	139	139	4213	116	116	139	139	139	139

In outbreak D, the documentation does not clearly show how large the actual AR was for the

area under consideration. Due to the fact, that only the person who showed symptoms was

isolated, it is possible that in the meantime, additional persons, who were already infected by

the index case may have infected others (e.g. pre-symptomatically) leading to the high AR.

In outbreak E, there is little documentation of the infection process, and further contact

between some of the persons had occurred in a restaurant afterwards. Furthermore, it has not

been determined whether the infection can be attributed to only one person. The high AR after

a short time of exposure allows the conclusion that either two index persons were present or

that the exposure time was prolonged by the meeting in a restaurant.

In outbreak F, the group was not together for the entire time and some of the subjects

continued rehearsing in another room. For this reason, the exposure time for the whole group

was lower and this may account for the lower AR than calculated by PIRA.

In outbreak L an air exchange rate of 21 1/h was assumed. A relatively small change in the

assumed volume flow has a significant influence on the result of PIRA (where the total

exposure time was used). Furthermore, it cannot be excluded that droplet transmission may

also have happened.

Secondly, many assumptions were made, therefore it is not clear if the formula is already

optimal, perhaps further optimization during the course of the pandemic is possible if further

knowledge becomes available.

Third, the calculation model does not consider the sedimentation behavior of particles. It is

known that at higher air velocities, and especially at high turbulence, the sedimentation

behavior increases. In typical indoor air flows this decrease is about 10 % per hour. Compared

to the uncertainty of the overall emission rate, this effect is not significant.

Fourth, the calculation model assumes a homogeneous distribution of the particles in the room

air. Practically however, the ventilation effectiveness is locally very different. The differences

can be slightly greater than 100%.

Finally, it must be noted that the aerosol concentration is significantly higher in the near field

of the emitting person and the results of PIRA are not valid within the generally accepted

1.5 m distance rules.

Conclusion

It was shown in this investigation that it was possible to calculate the risk of an infection via

aerosols for situations where the long-distance transmission is more important. By using the

model presented here, a good agreement to previous infection outbreaks in different settings

and different attack rates was achieved. Previous retrospectively determined quanta emission

rates usually assumed a stationary state. However, if the concentration process is important

for the total amount of inhaled virus-laden aerosols (usually at ACH x t < 5), then a stationary

observation leads to an incorrect boundary condition. The time-dependent viability of the

virus also plays a significant role. Here, the influence of the viability is higher at low air

change rates compared with high ones, because the virus stays in the room air for a longer

time period and the proportion of inactivated pathogens increase. However, the effect of time-

dependent viability is not that important that a low air change rate has an overall positive

effect.

To reduce the risk of infection via aerosols the necessary volume flow of virus-free air

depending on the exposure time can be seen in Figure 5. This figure may be helpful to

implement measures, such as increasing the virus-free air supply rate. Furthermore, the number

of exposed persons must be kept in mind. An infection risk of 60% may result in one infected

person in a two-person office, but in 60 infected persons in a room with 100 persons.

Predicting the infection risk via aerosols and knowing the important parameters can help in the

selection of appropriate preventive actions.

328   **Declarations**

329   The authors received no specific funding for this work.

330   The authors declare no competing interests.

331   The authors declare that they followed the appropriate research guidelines.

Literature

[1] Y. Li, H. Qian, J. Hang, X. Chen, L. Hong, P. Liang, J. Li, S. Xiao, J. Wie, L. Liu and M. Kang, "Evidence for probable aerosol transmission of SARS-CoV-2 in a poorly ventilated restaurant," *Preprint medXRiv,* 2020.

[2] G. Correia, L. Rodrigues, M. Gameiro da Silva and T. Gonçalves, "Airborne route and bad use of ventilation systems as non-neglible factors in SARS-CoV-2 transmission," *Medical Hypotheses,* vol. 141, 2020.

[3] L. Ferretti, C. Wymant, M. Kendall, L. Zhao, A. Nurtay, L. Abeler-Dörner, M. Parker, D. Bonsall and C. Fraser, "Quantifying SARS-CoV-2 transmission suggests epidemic control with digital contact tracing," *Science,* vol. eabb6936, p. 368, 2020.

[4] L. Morawska and J. Cao, "Airborne transmission of SARS-CoV-2: The world should face the reality," *Environment International,* vol. 139, 2020.

[5] E. Riley, G. Murphy and R. Riley, "Airborne Spread of Measles in a Suburban Elementary School," *American Journal of Epidemiology,* vol. 107, no. 5, pp. 421-432, 1978.

[6] W. Wells, Airborne contagion and air hygiene: an ecological study of droplet infections, 1955.

[7] C. Noakes and A. Sleigh, "Applying the Wells-Riley equation to the risk of airborne infection in hospital environments: The importance of stochastic and proximity effects," in *Indoor Air*, Copenhagen, Denmark, 2008.

[8] L. Gammaitoni and M. Nucci, "Using a Mathematical Model to Evaluate the Efficacy of TB Control Measures," *Emerging Infectious Diseases,* vol. 3, no. 3, pp. 335-342, 1997.

[9] H. Dai and B. Zhao, "Association of the infection probability of COVID-19 with ventilation rates in confined spaces," *Building Simulations,* 2020.

[10] y. Liu, G. AA., A. Wilder-Smith and J. Rocklöv, "The reproductive number of COVID-19 is hisher compared to SARS coronavirus," *Journal of Travel Medicine,* pp. 1-4, 2020.

[11] Y. Alimohamadi, M. Taghdir and M. Sepandi, "The Estimate of the Basic Reproduction Number of Novel Coronavirus disease (COVID-19): A Systematic Review and Meta-Analysis," *Journal of Preventive Medicine and Public Health,* vol. March, 2020.

[12] Y.-F. Lin, Q. Duan, Y. Zhou, T. Yuan, P. Li, T. Fitzpatrick, F. Leiwen, A. Feng, G. Luo, Y. Zhan, B. Liang, S. Fan, Y. Lu, B. Wang, Z. Wang, H. Zhao, Y. Gao, M. Li, D. Chen, X. Chen, Y. Ao, L. Li, W. D. X. Cai, Y. Shu and H. Zhou, "Spread and Impact of COVID-19 in China: A Systematic Review and Synthesis of Predictions From Transmission-Dynamic Models," *frontiers in Medicine,* 2020.

[13] S. Miller, W. Nazaroff, J. Jimenez, A. Boerstra, G. Buonanno, S. Dancer, J. Kurnitski, L. Marr, L. Morawska and C. Noakes, "Transmission of SARS-CoV-2 by inhalation of respiratory aerosol in the Skagit Valley Chorale superspreading event," *Preprint medXRiv,* 2020.

[14] D. Mürbe, M. Kriegel, J. Lange, H. Rotheudt and M. Fleischer, "Aerosol emission is inscreased in professional singing," *Preprint,* 2020.

[15] A. Hartmann, J. Lange, H. Rotheudt and M. Kriegel, "Emission rate and particle size of bioaerosols during breathing, speaking and coughing," *Preprint,* 2020.

[16] N. van Doremalen, T. Bushmaker, D. Morris, M. Holbrook, A. Gamble, B. Williamson, A. Tamin, J. T. N. Harcourt, S. Gerber, J. Lloyd-Smith, E. de Wit and V. Munster, "Aerosol and Surface Stability of SARS-CoV-2 as Compared with SARS-CoV-1," *New England Journal of Medicine,* Vols. April, 16, p. 382, 2020.

[17] J. Gupta, C.-H. Lin and Q. Chen, "Characterizing exhaled airflow from breathing and talking," *Indoor Air,* vol. 20, pp. 31-39, 2010.

[18] A. Córdova and I. Latasa, "Respiratory flows as a method for safely preventing the coronvirus transmission (COVID-19)," *Apunts Sports Medicine,* vol. 55, pp. 81-85, 2020.

[19] J. Jiang, R. Hanna, M. Willey and A. Rieves, "The measurement of airflow using Singing helmet that allows free movement of the jaw," *Journal of Voice,* vol. 30, no. 6, pp. 641-648, 2016.

[20] R. Dumond, S. Gastinger, H. Rahman, A. Le Faucheur, P. Quinton, H. Kang and J. Prioux, "Estimation of respiratory colume from thoracoabdominal breathing distances: comparison of two models of machine learning," *European Journal of Applied Physiology,* vol. 117, pp. 1533-1555, 2017.

[21] B. Binazzi, B. Lanini, R. Bianchi, I. Romagnoli, M. Nerini, F. Gigliotti, R. M.-E. J. Duranti and G. Scano, "Breathing Pattern and kinematics in normal subjects during speech, singing and loud whispering," *Acta Physiologica,* vol. 186, pp. 233-246, 2006.

[22] Spektrum Akademischer Verlag, Heidelberg, "Lexikon der Biologie," spektrum.de, 1999. [Online]. Available: https://www.spektrum.de/lexika/showpopup.php?lexikon_id=9&art_id=5744&nummer=1988. [Accessed 05 Oktober 2020].

[23] B. Stephens, "HVAC Filtration and the Wells-Riley approach to assessing risks of infectious airborne diseases," 2013.

[24] S.-C. Chen, C.-M. Liao, S.-S. Li and S.-H. You, "A Probabilistic Transmission Model to Assess Infection Risk from Mycobacterium Tuberculosis in Commercial Passenger Trains," *Risk Analysis,* vol. 31, no. 6, pp. 930-939, 2011.

[25] G. Chowell, H. Nishiura and L. M. A. Bettencourt, "Comparative estimation of the reproduction number of pandemic influenza from daily case notification data," *Journal of the Royal Society Interface,* vol. 4, pp. 155-166, 2006.

[26] B. J. Coburn and S. Blower, "Predicting the potential for within-flight transmission and global dissemination of MERS," *The Lancet,* no. 14, 2014.

[27] WHO, "WHO MERS Global Summary and Assessment of Risk," WHO, 2019.

[28] WHO, "Consensus document on the epidemiology of severe acute respiratory syndrome (SARS)," WHO, 2003.

[29] G. Buonanno, L. Stabile and L. Morawska, "Estimation of airborne viral transmission: Quanta emission rate of SARS-CoV-2 for infection risk assessment," *Environment International,* vol. 141, 2020.

[30] X. He, E. H. Y. Lau, P. Wu, X. Deng, J. Wang, X. Hao, Y. C. Lau, J. Y. Wong, Y. Guan, X. Tan, X. C. Y. Mo, B. Lio, W. Chen, F. Hu, Q. Zhang, M. Zhong, Y. Wu, L. Zhao, F. Zhang, C. B. J., F. Li and G. M. Leung, "Author Correction: Temporal Dynamics in viral shedding and transmissibilitiy of COVID-19," *Nature Medicine,* 2020.

[31] N. A. o. Sciences, The Airliner Cabin Environment and the Health of Passengers and Crew, United States of America: National Academy Press, 2002.

[32] T. Günther, M. Czech-Sioli, D. Indenbirken, A. Robitailles, P. Tenhaken, M. Exner, M. Ottinger, N. Fischer, A. Grundhoff and M. M. Brinkmann, "Investigation of a superspreading event preceding the largest meat processing plant-related SARS-Coronavirus 2 outbreak in Germany," *Preprint,* 2020.

[33] Y. Shen, C. Li, H. Dong, Z. Wang, L. Martinez, Z. Sun, A. Handel, Z. Chen, E. Chen, M. Ebel, F. Wang, B. Yi, H. Wang, X. Wang, A. Wang, B. Chen, Y. Qi, L. Liang, Y. Li, F. Ling, J. Chen and G. Xu, "Community Outbreak Investigation of SARS-CoV-2 Transmission Among Bus Riders in Eastern China," *JAMA International Medicine,* 2020.

[34] S. Park, Y.-M. Kim, S. Lee, B.-J. Na, C. Kim, J.-i. Kim, H. Kim, Y. Kim, Y. Park, I. Huh, H. Kim, H. Yoon, H. Jang, K. Kim, Y. Chang, I. Kim, H. Lee, J. Gwack, S. Kim, M. Lim, S. Kweon, Y. Choe, O. Park and E. Jeong, "Coronavirus Disease Outbreak in Call Center, South Korea," *Emerging Infectious Diseases,* vol. 26, no. 8, pp. 1666-1670, 2020.

[35] C. Stein-Zamir, N. Abramson, H. Shoob, E. Libal, M. Bitan, T. Cardash, R. Cayam and I. Miskin, "A large COVID-19 outbreak in a high school 10 days after schools' reopening, Israel, May 2020," *Eurosurveillance,* 2020.

[36] J. Lu, J. Gu, K. Li, C. Xu, W. Su, Z. Lai, D. Zhou, C. Yu, B. Xu and Z. Yang, "COVID-19 Outbreak Associated with Air Conditioning in Restaurant, Guangzhou, China," *Emerging Infectious Diseases,* vol. 26, no. 7, pp. 1628-1631, 2020.

[37] N. C. Khanh, P. Q. Thai, H.-L. Quach, N.-A. H. Thi, P. C. Dinh, T. N. Duong, L. T. Q. Mai, N. D. Nghia, T. T. A., L. N. Quang, T. D. Quang, T.-T. Nguyen, F. Vogt and D. D. Anh, "Transmission of Severe Acute Respiratory Syndrome Coronavirus 2 During Ling Flight," *Emerging Infectious Diseases,* vol. 26, no. 11, 2020.

[38] G. Buonanno, L. Morawska and L. Stabile, "Quantitative Assessment of the Risk of Airborne Transmission of SARS-COV-2-Infection: Prospective and Retrospective Applications," *Preprint MedXRiv,* 2020.