Practical Indicators for Risk of Airborne Transmission in Shared Indoor Environments

and their Application to COVID-19 Outbreaks

Z. Peng,[1] A.L. Pineda Rojas,[2] E. Kropff,[3] W. Bahnfleth,[4] G. Buonanno,[5] S.J. Dancer,[6,7] J.

Kurnitski,[8] Y. Li,[9] M.G.L.C. Loomans,[10] L.C. Marr,[11] L. Morawska,[12] W. Nazaroff,[13] C.

Noakes,[14] X. Querol,[15] C. Sekhar,[16] R. Tellier,[17] T. Greenhalgh,[18] L. Bourouiba,[19] A.

Boerstra,[20] J.W. Tang,[21] S.L. Miller,[22] and J.L. Jimenez[1*]

Affiliations

1. Dept. of Chemistry and CIRES; University of Colorado, Boulder, CO, USA

2. CIMA, UMI-IFAECI/CNRS, FCEyN, Universidad de Buenos Aires—UBA/CONICET, Buenos Aires, Argentina

3. Leloir Institute—IIBBA/CONICET, CBA, Buenos Aires, Argentina

4. Dept. of Architectural Engineering, The Pennsylvania State University, University Park, PA, USA

5. Dept. of Civil and Mechanical Engineering, University of Cassino and Southern Lazio, Italy

6. Dept. of Microbiology, NHS Lanarkshire, Scotland, UK

7. School of Applied Sciences, Edinburgh Napier University, Scotland, UK

8. REHVA Technology and Research Committee, Tallinn University of Technology, Tallinn, Estonia

9. Dept. of Mechanical Engineering, the University of Hong Kong, Hong Kong, China

10. Dept. of the Built Environment, Eindhoven University of Technology, Eindhoven, the Netherlands

11. Dept. of Civil and Environmental Engineering, Virginia Tech, Blacksburg, VA, USA

12. International Laboratory for Air Quality and Health, Queensland University of Technology, Brisbane, Australia

13. Dept. of Civil and Environmental Engineering, University of California, Berkeley, CA, USA

14. School of Civil Engineering, University of Leeds, Leeds, UK

15. Institute of Environmental Assessment and Water Research, IDAEA, Spanish Research Council, CSIC, Barcelona, Spain

16. Dept. of the Built Environment, National University of Singapore, Singapore

17. McGill University, Montreal, QC, Canada

18. Dept. of Primary Care Health Sciences, University of Oxford, Oxford, UK.

19. The Fluid Dynamics of Disease Transmission Laboratory, Massachusetts Institute of Technology, Cambridge, MA, USA

20. REHVA (Federation of European Heating, Ventilation and Air Conditioning Associations), BBA Binnenmilieu, the Netherlands

21. Respiratory Sciences, University of Leicester, Leicester, UK

22. Dept. Mechanical Engineering, University of Colorado, Boulder, CO, USA

*: corresponding author: <jose.jimenez@colorado.edu>

Abstract. Some infectious diseases, including COVID-19, can be transmitted via aerosols that are emitted by an infectious person and inhaled by susceptible individuals. Most airborne transmission occurs at close proximity and is effectively reduced by physical distancing, but as time indoors increases, infections occur in those sharing room air despite maintaining distancing. There have been calls for quantified models to estimate the absolute and relative contribution of these different factors to infection risk. We propose two indicators of infection risk for this situation, i.e., relative risk parameter (H_r) and risk parameter (H). They combine the key factors that control airborne disease transmission indoors: virus-containing aerosol generation rate, breathing flow rate, masking and its quality, ventilation and particulate air cleaning rates, number of occupants, and duration of exposure. COVID-19 outbreaks show a clear trend in relation to these factors that is consistent with airborne infection The observed trends of outbreak size (attack rate) vs. H (H_r) allow us to recommend values of these parameters to minimize COVID-19 indoor infection risk. Transmission in typical pre-pandemic indoor spaces is highly sensitive to mitigation efforts. Previous outbreaks of measles, flu, and tuberculosis were assessed along with recently reported COVID-19 outbreaks. Measles outbreaks occur at much lower risk parameter values than COVID-19, while tuberculosis outbreaks are observed at much higher risk parameter values. Since both diseases are accepted as airborne, the fact that COVID-19 is less contagious than measles does not rule out airborne transmission. It is important that future outbreak reports include information on the nature and type of masking, ventilation and particulate-air cleaning rates, number of occupants, and duration of exposure, to allow us to understand the circumstances conducive to airborne transmission of different diseases.

Key words

COVID-19; airborne transmission; indoor air; risk assessment; mitigation

60 **Synopsis**

61 We propose two infection risk indicators for indoor spaces and apply them to COVID-19

62 outbreaks analysis and mitigation.

Introduction

Some respiratory infections can be transmitted through the airborne pathway, in which aerosol

particles (< 100 μm) are shed by infected individuals and inhaled by others, causing disease in

susceptible individuals.[1–4] It is widely accepted that measles, tuberculosis, and chickenpox are

transmitted in this way,[5,6] and acceptance is growing that this is a major and potentially the

dominant transmission mode of COVID-19.[7–13] There is substantial evidence that smallpox,[14]

influenza,[3] SARS,[15] MERS,[6] and rhinovirus[16] are also transmitted via aerosols.

There are three airborne transmission scenarios of interest in which infectious and susceptible

people: (a) are in close proximity to each other (< 1-2 m), so-called "short-range airborne

transmission,"[17] which is effectively mitigated by physical distancing; (b) share air in the same

room, "shared space airborne"; and (c) "longer-distance airborne transmission" in buildings

when individuals are not sharing a room (or are in very large rooms), or even between buildings

as in the Amoy Gardens SARS outbreak.[15] Often (b) and (c) are lumped together under "long-

range transmission," but in Scenario (c) transport of pathogen-containing air is more complex,

so that the approximation of well mixed air is less valid. It is thus useful to separate these

scenarios given the substantial differences in the risk of these situations and actions needed to

abate the risk of transmission.

Airborne diseases vary widely in transmissibility, but all of them are most easily transmitted at

short range due to the higher concentration of pathogen-containing aerosols close to the

infected person. For SARS-CoV-2, a pathogen of initially moderate infectivity (more recently

increased by some variants such as Delta), many instances have been reported implicating

transmission in shared indoor spaces. Indeed, multiple outbreaks of COVID-19 have been

reported in crowded spaces that were relatively poorly ventilated and that were shared by many

people for periods of half an hour or longer. Examples include choir rehearsals,[11] religious

services,[18] buses,[19] workshop rooms,[19] restaurants,[4,20] and gyms,[21] among others. There are

only a few documented cases of longer-distance transmission of SARS-CoV-2, in buildings.[22–24]

However, cases of longer-distance transmission are harder to detect as they require contact

tracing teams to have sufficient data to connect cases together and rule out infection acquired

elsewhere. Historically, it was only possible to prove longer-distance transmission in the

complete absence of community transmission (e.g. ref [14]).

Being able to quickly assess the risk of infection for a wide variety of indoor environments is of

the utmost importance given the impact of the continuing pandemic (and the risk of future

pandemics) on so many aspects of life in almost every country of the world. We urgently need to

improve the safety of the air that we breathe across a range of environments including child-

care facilities, kindergartens, schools, colleges, shops, offices, homes, eldercare facilities,

factories, public and private transportation, restaurants, gyms, libraries, cinemas, concert halls,

places of worship and mass outdoor events across different climates and socio-economic

conditions. There is very little evidence on the actual ventilation rates and the effectiveness of

ventilation systems at reducing risks from viral exposure and other indoor pollutants within the

majority of buildings. However, data from COVID-19 outbreaks consistently show that a large

fraction of buildings worldwide have very low ventilation rates despite the requirements set in

national building standards. A host of policy questions – from how to safely re-open schools to

how to prevent transmission in high-risk occupational settings – require accurate quantification

of the multiple interacting variables that influence airborne infection risk.

Qualitative guidance to reduce the risk of airborne transmission has been published.[25–27]

Different mathematical models have been proposed to help manage risk of airborne

transmission,[28,29] and several models have been adapted to COVID-19.[30–33] It is important to

define quantitative infection risk criteria for different spaces and types of events to more

effectively manage the pandemic.[34] Such criteria could then be used by authorities and policy

makers to assist in deciding which activities are permitted under what conditions, so as to limit

infection risk across a society. To our knowledge, no such quantitative criteria have been

proposed. Besides, often recommendations are complex and vague, e.g., "reduce duration and

density of occupancy, and increase ventilation." However, it is not clear how to combine the

different measures together (e.g., is half the duration equivalent to doubling the ventilation?) and

it is also not clear what level of mitigation is sufficient to reduce outbreak probability to a low

level.

Here, we use a box model to estimate the viral aerosol concentration indoors, and combine it

with the Wells-Riley infection model.[28] The combined model is used to derive two quantitative

risk parameters that allow comparing the relative risk of transmission in different situations when

sharing room air. We explore the trends in infections observed in outbreaks of COVID-19 and

other diseases as a function of these parameters. Finally, we use the parameters to quantify a

graphical display of the relative risk of different situations and mitigation options.

Materials and Methods

135
Box model of infection

The box model considers a single enclosed space, in which virus-containing aerosols are

assumed to be rapidly uniformly mixed compared with the time spent by the occupants in the

space. This is approximately applicable in many situations, but there are some exceptions such

as outbreaks where clear directional flow occurred in a room.[18,20] The mathematical notation

used in the paper is summarized in Table S1. The mass balance equation is first written in

terms of c, the concentration of infectious quanta in the air in the enclosed space (units of

quanta m^{-3}). Compared with a model written in terms of aerosol or viral particle concentrations, c

has the advantage of implicitly including effects such as the deposition efficiency of the aerosol

particles in the lungs of a susceptible person, as well as the efficiency with which such

deposited particles may cause infection, the multiplicity of infection, etc. The balance of quanta

in the space can be written as:

$$dc/dt = E_p \, f_e / V - (\lambda_0 + \lambda_{dec} + \lambda_{dep} + \lambda_{cle}) \, c \qquad\qquad (1)$$

where E_p is the emission rate of quanta into the indoor air from an infected person present in the

space (quanta / h); f_e is the penetration efficiency of virus-carrying particles through masks or

face coverings for exhalation (which takes into account the impact of whether the infector wears

a face covering); V is the volume of the space; λ_0 is the first-order rate of removal of quanta by

ventilation with outdoor air (h^{-1}); λ_{cle} is the removal of quanta by air cleaning devices (e.g.

recirculated air with filtering, germicidal UV, portable air cleaners, etc.); λ_{dec} is the infectivity

decay rate of the virus; λ_{dep} is the deposition rate of airborne virus-containing particles onto

surfaces. E_p is a critical parameter that depends strongly on the disease, and it can be

estimated with a forward model based on aerosol emission rates and pathogen concentration in

saliva and respiratory fluid[31,35] or by fitting a model such as the one used here to real

transmission events.[11,31]

This equation can be solved analytically or numerically for specific situations. Given the

enormous number of possible situations, and given the prevalence of outbreaks resulting from

longer events where air is shared for a substantial period of time, we consider a sufficiently long

event so that a steady state condition (dc/dt ~ 0) is a reasonable approximation. Writing $\lambda = \lambda_0 +$

$\lambda_{cle} + \lambda_{dec} + \lambda_{dep}$ for simplicity leads to a steady-state infectious quanta concentration of:

$\qquad c = E_p\, f_e\, /\, (V\, \lambda)$ (2)

Under the assumption of no infectious quanta at the beginning of the event, a multiplicative

factor, r_{ss}, can be applied for events too short to approximately reach steady state (see Section

S1 for detail) to correct the deviation of the quanta concentration averaged over the event (c_{avg})

from that at steady state:

$\qquad c_{avg} = r_{ss}\, E_p\, f_e\, /\, (V\, \lambda)$ (3)

Since the goal is to analyze outbreaks, we assume that only a single infectious person is

present in the space, which is thought to be applicable to the outbreaks analyzed below. This

allows calculation of the probability of infection, *conditional* to one infectious person being

present. The model can also be formulated to calculate the *absolute* probability of infection, if

we assume that the probability of an infectious person being present reflects the prevalence of a

disease at a given location and time (e.g. refs [30,36]).

The dose expressed in infectious quanta (n) inhaled by each of the susceptible persons present

in the space (N_{sus}) is then:

$\qquad n = f_i\, B\, c_{avg}\, D$ (4)

where f_i is the penetration efficiency of virus-carrying particles through masks or face coverings

for inhalation (which takes into account the effect of the fraction of occupants wearing face

coverings); B is the breathing volumetric flow rate of susceptible persons; D is the duration of

exposure, assumed to be the same for all the susceptible persons. Substituting:

$n = r_{ss} E_p f_e f_i B D / (V \lambda)$ (5)

The number of expected secondary infections increases monotonically with increasing n. For an

individual susceptible person, by definition of an infectious quantum, the probability of infection

is [28]:

$P = 1 - e^{-n}$ (6)

For low values of n, the use of the Taylor expansion for an exponential allows approximating P

as:

$P \sim n$ (7)

The total number of secondary infections expected, which may also be regarded as the effective

reproduction number (R_e) in a given situation, is then:

$N_{si} = P N_{sus} \sim n N_{sus}$ (8)

where N_{sus} is the number of susceptible individuals present, which may be lower than the

number of occupants due to vaccination or immunity due to past infection. All the outbreaks

studied here occurred before COVID-19 vaccines became available. Thus, the number of

secondary infections increases linearly with n at lower values, and non-linearly at higher values.

We retain the simplified form to define and calculate the risk parameters, but use equation (6)

for fitting the outbreak results in Figure 1b below.

Risk parameters for airborne infection

We define the relative risk parameter, H_r, and the risk parameter, H, for airborne infection in a

shared space. The purpose of H_r and H is to capture the dependency of P and N_{si}, respectively,

on the parameters that define an event in a given space, in particular those parameters that can

be controlled to reduce risk of shared-room airborne transmission. To better capture the

controllable actions, E_p and B were split into factors that can and cannot be controlled. E_p can

be expressed as the product E_{p0} x r_E where E_{p0} and r_E are, respectively, the quanta shedding

rate of an infectious person resting and only orally breathing (no vocalization); and the shedding

rate enhancement factor relative to E_{p0} for an activity with a certain degree of vocalization and

physical intensity (see Table S2a for detail). B can be expressed as B_0 x r_B, where B_0 and r_B are

the volumetric breathing rate of a sedentary susceptible person in the age group of 41-<51

years (numerically also the average for all age groups) and the relative breathing rate

enhancement factor (vs. B_0) for an activity with a certain physical intensity and for a certain age

group (see Table S2b for detail). E_{p0} is uncertain, likely highly variable across the population,

and variable over time during the period of infectiousness.[31,35,37] It may also increase due to new

virus variants such as the SARS-CoV-2 Delta variant, that is more contagious, assuming that

the increased contagiousness is due to increased viral emission or reduced infectious dose

(both of which would increase the quanta emission rate).[38,39] We note that some variants could

in principle also increase transmissibility by lengthening the period of infectiousness for a given

person, which by itself would not increase the quanta emission rate in a given situation. B_0 is

relatively well known, and varies with a susceptible person's age, sex, and body weight, in

addition to physical activity level. r_E and r_B are less uncertain than E_{p0} and are functions of the

specific physical and vocalization activities.[31,35,40] Thus, they are useful in capturing the

quantitative impact of specific controllable factors. There could be factors beyond those

considered here that lead to variation of viral emissions, such as the respiratory effort of patients

with breathing disorders, such as emphysema or asthma.[41] Such factors can be incorporated

into updated Tables in the future.

Then P can be expressed as a function of E_{p0}, B_0 and the product of the other controllable
factors as:
252
253 $\qquad$ $P = 1 - \exp(-E_{p0}\, B_0\, H_r) \sim E_{p0}\, B_0\, H_r$ $\qquad\qquad\qquad$ (9)
254
255 Where H_r is the relative risk parameter:
256
257 $\qquad$ $H_r = r_{ss}\, r_E\, r_B\, f_e\, f_i\, D\, /\, (V\, \lambda)$ $\qquad\qquad\qquad$ (10)

258
259

It has a unit of $h^2\, m^{-3}$, which indicates the increase of risk with duration (h), the inverse of the

ventilation rate expressed as air changes per hour ($1/h^{-1} = h$), and the inverse of the volume of

the space ($1/m^3$). The other parameters such as the effect of masking are dimensionless. H_r

includes the relative increase of the emission with activity (r_E), but not the quanta emission rate

by a resting and orally breathing infector (E_{p0}). This allows using the same risk parameters for

different diseases, which will naturally separate in the graphs according to their transmissibility.

The four terms that make up λ may vary in relative importance for different diseases and

conditions. $\lambda_{dec} \sim 1.1\ h^{-1}$ [42] has been reported for COVID-19. λ_{dec} depends on temperature and

relative humidity.[43,44] λ_{dep} depends on particle size and the geometry and airflow in a given

space. Respiratory particle sizes in the range from 1-5 µm are thought to play a role in aerosol

transmission of COVID-19, due to a combination of high emission rates by activities such as

talking[45] and low deposition rates. λ_{dep} for a typical furnished indoor space span 0.2-2 h^{-1} over

this size range, with faster deposition for larger particles.[46] λ_0 varies from ~12 h^{-1} for airborne

infection isolation rooms,[47] ~6 h^{-1} for laboratories, ~0.5 h^{-1} for residences,[48] and ~1 h^{-1} for

offices.[1,49] Very little ventilation data is available for many semi-public spaces such as shops,

restaurants and bars or transportation. λ_{cle} can vary from 0, if such systems are not in use, to

several h^{-1} for adequately sized systems. Ventilation with clean outdoor air will be important in

most situations, while virus decay and deposition likely contribute but are more uncertain for

COVID-19, based on current information. In particular, the size distribution of aerosols

containing infectious viruses is uncertain.

We consider a worst-case scenario where rates of deposition and infectivity decay are small

compared with ventilation and air cleaning and can therefore be neglected. This also allows

using the same relative risk parameter to compare different airborne diseases. This yields:

284
285          $H_r = r_{ss}\, r_E\, r_B\, f_e\, f_i\, D\, /\, (V\, (\lambda_0 + \lambda_{cle}))$ (11)
286
287   H_r can be recast as:
288
289          $H_r = r_{ss}\, r_E\, r_B\, f_e\, f_i\, D\, /\, (L\, N_{sus})$ (12)

290
291

where:

$L = V\, (\lambda_0 + \lambda_{cle})\, /\, N_{sus}$ (13)

Assuming that all of the people present in a space are susceptible to infection, L is equivalent to

the ventilation plus air cleaning rate per person present in the space, (typically expressed in

liters s^{-1} $person^{-1}$ in standards and guidelines such as from refs [50–52]. If some fraction of the

people present are immune to the disease, then L is larger than the corresponding personal

ventilation rate in the guidance. While this recasting will be useful to persons familiar with

ventilation guidelines, we keep the form in equation (11) for most further analyses, since the

number of people allowed in a space is one of the critical variables that can be examined with

this relative risk parameter.

We insert equation (9) into equation (8) and obtain

$N_{si} = N_{sus} [1 - \exp(-E_{p0} B_0 H_r)] \sim N_{sus} E_{p0} B_0 H_r = E_{p0} B_0 H$ (14)

where we define the risk parameter

$H = N_{sus} H_r = r_{ss} r_E r_B f_e f_i D N_{sus} / (V (\lambda_0 + \lambda_{cle})) = r_{ss} r_E r_B f_e f_i D / L$ (15)

When there is only one infector present and n is small, H is proportional to N_{si}, i.e., the outbreak

size. When it is unknown whether an infector is present, H is an approximate indicator of the

absolute probability of infection (P_a), since the expected value of number of infectors (N_i) is the

product of number of occupants (N) and probability of an occupant being infectious, a measure

of prevalence of infectious people in local population (η_I), as shown below:

$P_a \sim N_i r_{ss} E_p f_e f_i B D / (V \lambda) = \eta_I N r_{ss} E_{p0} B_0 r_E r_B f_e f_i D / (V \lambda)$

$\sim \eta_I N_{sus} H_r E_{p0} B_0 = \eta_I E_{p0} B_0 H$ (16)

The precise estimation of η_I is complex for several reasons. Most transmission may be

associated with those infected with high viral loads,[53,54] as many infected people may not shed

virus into the air.[37] Also much spread is by people with few or no symptoms who may not know

that they are infected,[55] however a fraction of symptomatic infectious people are typically in

isolation. There is also significant variation in viral load and infectivity during the course of the

disease.[56] For these reasons, it is very difficult to determine η_I precisely based on test data. For

a situation with multiple potential infectors present (e.g., a COVID ward in a hospital), the risk

parameters should be multiplied by the number of infectors.

For the analysis later in the paper that does not involve activity type or face covering choice

(and thus does not involve r_E, r_B, f_e, or f_i), we define another parameter (H'), which is closely

related to H:

$$H' = D\, N_{sus} / (V\, (\lambda_0 + \lambda_{cle})) = r_{ss}\, D\, /\, L \qquad\qquad (17)$$

This parameter only captures the characteristics of susceptible people's presence in the indoor

space, not of their behavior.

Value of the risk parameters for documented outbreaks of COVID-19

An important advantage of the simple risk parameters is that their values can be calculated for

outbreaks that are documented in the scientific literature. Values for documented COVID-19

outbreaks are shown in Table 1 (r_E and r_B are estimated based on the likely types of activities in

each case,[31,35,40] see Table S2 for typical values). Also included are values for outbreaks

documented in the literature for tuberculosis and measles, which are widely accepted to

transmit through the air, and an influenza outbreak that was clearly due to airborne

transmission. We have included all the outbreaks known to us for which sufficient information

was available to estimate airborne infection risk. Most public health investigations so far in this

pandemic have neglected to report ventilation rates, the volume of the space, filter and air

cleaner efficiencies, and other building science details, and thus their airborne risk cannot be

estimated. It is important that future outbreak reports include this information, to allow

expanding our knowledge of the circumstances conducive to airborne transmission of different

diseases.

Disease	Outbreak (reference)	r_E Relative shedding rate factor	r_B Relative breathing rate factor	D (h)	N_{sus}	V (m^3)	λ_0 (h^{-1})	L (liter s^{-1} person^{-1})	r_{ss}	H (persons h^2 m^{-3})	H' (persons h^2 m^{-3})	H_r (h^2 m^{-3})	Attack rate (%)	Number of secondary cases
COVID-19	Guangzhou restaurant[4]	9.3[a]	1	1.2	20	97	0.67	0.9	0.31	1.1	0.11	0.054	45	9
	Big bus outbreak[19] (ventilation from pers. comm. Y. Li)	1	1	3.3	46	60	4.7	1.7	0.94	0.50	0.50	0.011	17	8
	Small bus outbreak[19] (ventilation from pers. comm. Y. Li)	1	1	1	17	22	8.9	3.2	0.89	0.077	0.077	0.0045	12	2
	Skagit Choir[11]	85[b]	2.5[c]	2.5	60	810	0.7	2.6	0.53	30	0.14	0.5	87	53
	Call center[57]	30[d]	1	8	216	630	6	4.9	0.98	13	0.45	0.062	44	94
	Aircraft[58]	50[e]	1	11	19[f]	60	21	18	1	8.4	0.17	0.44	63	12
	Slaughterhouse[59]	4.3[g]	5[h]	8		3000	0.53		0.77			0.083	26	
	Berlin Choir[60]	85[b]	2.5[c]	2.5		1200	0.17		0.19			0.49	91	

	Berlin School 1[60]	1	1	4.5		180	8.3		0.97			0.0029	10	
	Berlin School 2[60]	1	1	1.5		150	10		0.93			0.00093	6	
	Israel School[61]	5.7[i]	1.1[j]	4.5		150	2.7		0.92			0.1	43	
	Germany Meeting[60]	1.7[k]	1	2		170	1.2		0.62			0.012	17	
Tuberculosis	Office[62]	1.7[k]	1	160	67			7.1	1[l]	11	6.3	0.16	40	27
	Hospital[63]	1.9[m]	1.7[n]	1800	25	200	6	13	1[l]	120	37.5	4.8	28	7
Influenza	Aircraft[e] [64]	50	1	4.3	29	168	0.5	0.45	0.59	44	0.88	1.5	86	25
Measles	School[28]	1	1	10	48			150[o] (7.6)	1[l]	0.019	0.019	0.0004	52	25
	School[p] [28]	1	1	30	31			170[o] (5.5)	1[l]	0.05	0.05	0.0016	23	7
	Physician's Office[65]	1	1	1	12	250	1.2	6.9	0.42	0.017	0.017	0.00014	33	4

Footnotes: choice of parameters for specific cases. [a] Talking during half of the time and half normal / half loud talking assumed; [b] Light exercise - loudly speaking; [c] Light intensity for 61-<71 years; [d] Resting - loudly speaking; [e] Estimate for coughing. The value is the product of r_E for resting - speaking and the ratio of the average expired aerosol counts for coughing and talking;[66] [f] only the business class cabin is considered; [g] Moderate exercise - oral breathing; [h] Moderate intensity for all age groups; [i] Standing - speaking for the infectious teacher; [j] Sedentary/passive for students aged 12-18; [k] Resting - speaking during ⅓ of the time assumed; [l] Event long enough for the assumption of unity for r_{ss}; [m] Half resting - oral breathing / half light exercise -oral breathing assumed; [n] Half sedentary/passive / half light intensity assumed; [o] Ventilation rate per susceptible person. The number in parentheses is for the ventilation rate per

Table 1: Parameters for outbreaks documented in the literature. Missing parameters could not

be calculated from the information given in the literature references.

We see that the COVID-19 outbreaks that have been documented span ~2.5 orders of

magnitude range of the risk parameter H ~ 0.09-30 persons h^2 m^{-3}. Numbers of secondary

cases of these outbreaks generally increase with H (Figure 1a). Aiming to maintain values far

below the threshold of 0.05 persons h^2 m^{-3} should help reduce outbreaks.

H_r correlates well with the attack rates for the outbreaks reported in Table 1 (Figure 1b, H_r can

be calculated for more literature outbreaks than H). COVID-19 outbreaks are observed for H_r >

0.001 h^2 m^{-3}, and thus indoor activities should be limited to conditions below this value during

the pandemic whenever possible.

A trend line can be fitted to the attack rate vs. H_r dataset with the Box/Wells-Riley model (Figure

1b), with the fitting parameter being E_{p0}, i.e. the basic quanta shedding rate (when breathing

only, no vocalization). A best-fit E_{p0} of 18.6 quanta h-1 was obtained (with B_0 = 0.288 m^3 h^{-1}

assumed for all occupants for simplicity). When the uncertainties of H_r and attack rates are

considered, the uncertainty of E_{p0} can also be estimated through Monte Carlo uncertainty

propagation, described in detail in Section S2. The 5[th] and 95[th] percentiles of the E_{p0} values are

8.7 and 45.4 quanta h^{-1}, respectively. This range is higher than that suggested by Buonanno et

al. (2 quanta h^{-1}),[31,35] but overlapping with the uncertainty range provided by those authors. Note

that outbreaks are typically only observed for individuals with higher quanta emission rates;

many infected individuals have low emission rates and the risk in those situations will be lower

than estimated here.[31,35] The attack rates estimated according to this trend line have a high

correlation with the actual attack rates (r^2 = 0.90; Figure S1). Given the small size of the dataset

of H_r and attack rates, we cross-validate this fitting by the leave-one-out method.[67] The 12

values of E_{p0} obtained in the cross validation have maximum and mean relative absolute

deviations of 20% and 6%, respectively, from the best-fit value, showing the robustness of the

fitting.

Close alignment supports the dominant shared-room airborne character of these COVID-19

outbreaks. If the outbreaks had major components of other transmission modes (e.g., fomite or

close-range transmission), we would expect a dependence on other parameters not considered

here and overall much lower correlation with the risk parameters. Nevertheless, it can be

observed that the attack rates of the outbreaks at low H_r (~0.01 h^2 m^{-3} or lower) are higher than

the fitted curve. This can be due to several factors, including i) other transmission routes (e.g.,

short-range airborne transmission, for which the risk cannot be well captured by the model in

this study and can still be significant at low H_r) or ii) the detection of only outlier cases of long-

range airborne transmission resulting from the variability of E_{p0} (e.g., cases where the infector's

actual quanta emission rate was extremely high), as the other cases may have too few

secondary infections to be documented in the literature.

(a)

412
413 *(b)*

414
Figure 1: (a) Number of secondary cases vs. the risk parameter H and (b) attack rate vs. the

relative risk parameter H_r for outbreaks of COVID-19, tuberculosis, influenza, and measles

reported in the literature. The fitted trend line of attack rate as a function of H_r and its estimated

uncertainty range (5th and 95th percentiles) are also shown in (b). All of the outbreaks

investigated here involve the original variants of the virus. A variant twice as contagious should

result in moving the results to the left by a factor of two or so.

Effect of building parameters vs. human activities

The type of activity performed in each case (captured by the product of r_E and r_B) contributes

substantially to the difference in H between these cases. When human activities are not taken

into account, the parameter H' only spans a narrow range of 0.09-0.56 person h^2 m^{-3}. This is

probably due to similar per-person ventilation rates in many public indoor spaces (on the order

of a few liter s^{-1} person^{-1})[50] and similar lengths of common events (in hours).

Similar to H, the variation in the values of H_r for the outbreaks in Table 1 is also largely

determined by r_E and r_B. If they are not taken into account, H_r for all outbreaks would vary in the

narrow range 0.001 to ~0.01 h^2 m^{-3}, as V and λ_0 are building characteristics and D, as discussed

above, is usually in hours. This implies that, in the presence of a single infector, reducing

vocalization and/or physical intensity levels of the indoor activity is a very effective way to lower

the infection risk of susceptible individuals. Reducing event length can also help, while reducing

occupancy cannot in this case, as shown by equation (10).

It is possible that some of the most visible outbreaks are associated with super-emitter

individuals, who shed virus particles at higher rates than others.[41,68–70] If that is the case, the

actual H_r values at which significant transmission starts to appear in the presence of individuals

that are not super emitters may be higher than those determined here. However, if super-

emitters are important, so will be their contribution to total spread, and thus one should try to

reduce the risk to reduce the probability of such events occurring.

Values of the risk parameters for outbreaks of other airborne diseases

In Table 1 and Figure 1 we also include a few reported indoor outbreaks of three other diseases

with significant airborne transmission, i.e., tuberculosis, influenza, and measles. For outbreaks

to have a similar number of secondary cases or attack rate, H or H_r needs to be higher for

tuberculosis and influenza and lower for measles than that for COVID-19 (Figure 1). Note that

many of the children present in the measles outbreak were vaccinated, but the risk parameter

framework can still be applied by considering the number of susceptible children present. This

difference is mainly due to differences in E_{p0} (lower for tuberculosis and influenza and higher for

measles; Figure 1b). A higher E_{p0} for measles may indicate a larger amount of airborne measles

virus in breath or a steeper dose-response curve for the measles virus than SARS-CoV-2, or

both. A novel disease as contagious as measles would make almost any indoor situation prone

to superspreading. On the other hand, tuberculosis and influenza are less contagious.

Tuberculosis transmission is propagated because untreated infected people remain contagious

for years.[71] The influenza outbreak occurred in an airplane without ventilation with the index

case constantly coughing, and represents an extreme for this disease.[64] Most influenza patients

emit significantly less virus.[72] More discussions about quanta emission rates of different

diseases can be found in refs [35,73].

Given that both the measles and tuberculosis pathogens are widely accepted as airborne, the

intermediate risk profile for COVID-19 in Figure 1b is not inconsistent with airborne

transmission, contrary to frequently made arguments.[74,75] Contagiousness of a disease does not

necessarily indicate the transmission route.[76] Airborne diseases can vary in their

contagiousness depending on parameters such as the amount of virus shed, the survival of the

virus in the air, the dose-response relationship for infection, and other parameters. The only

fundamental requirement is that transmission needs to be sufficient for the disease to survive as

such, something COVID-19 has had no trouble with so far.

Graphical representation of relative risks of different situations

When it is not known whether infectors are present at an indoor event, all occupants must be

considered possible infectors. We assume that the probability of an occupant being infectious is

the same as the fraction of infectious people in the local population (η_I). H indicates the risk of

an outbreak. Consequently, the risk also depends on the number of occupants in addition to

vocalization level, event duration, ventilation, and mask wearing. Jones et al.[25] estimated the

dependency of the infection risk on these factors and tabulated it in a manner similar to Table 2.

However, they only did so qualitatively. Having defined H as a risk parameter, we can assess

the risk more quantitatively based on H values (as well as contact times allowed until outbreak

risk is significant (H = 0.05 persons h^2 m^{-3}) and attack rates) under different conditions (Table 2).

Although the actual risk also depends on η_l and the choice of the threshold for high risk (red

cells in Table 2) is subjective, the risk parameter (H value) in Table 2 seems to vary in a smaller

range than the corresponding table in Jones et al..[25] We also show that being outdoors (with

much better ventilation than indoors) has a greater expected benefit than they estimated.

(a) Risk parameter H (persons h^2 m^{-3})

Type and level of group activity	Low occupancy				High occupancy		
	Outdoor and well ventilated	Indoor and well ventilated	Poorly ventilated		Outdoor and well ventilated	Indoor and well ventilated	Poorly ventilated
Wear face coverings, contact for short time							
Silent	2.33E-05	1.17E-03	1.17E-02		2.33E-04	1.17E-02	1.17E-01
Speaking	1.17E-04	5.83E-03	5.83E-02		1.17E-03	5.83E-02	5.83E-01
Shouting, singing	7.00E-04	3.50E-02	3.50E-01		7.00E-03	3.50E-01	3.50E+00
Heavy exercise	1.63E-03	8.17E-02	8.17E-01		1.63E-02	8.17E-01	8.17E+00
Wear face coverings, contact for prolonged time							
Silent	2.33E-04	1.17E-02	1.17E-01		2.33E-03	1.17E-01	1.17E+00
Speaking	1.17E-03	5.83E-02	5.83E-01		1.17E-02	5.83E-01	5.83E+00
Shouting, singing	7.00E-03	3.50E-01	3.50E+00		7.00E-02	3.50E+00	3.50E+01
Heavy exercise	1.63E-02	8.17E-01	8.17E+00		1.63E-01	8.17E+00	8.17E+01
No face coverings, contact for short time							
Silent	6.67E-05	3.33E-03	3.33E-02		6.67E-04	3.33E-02	3.33E-01
Speaking	3.33E-04	1.67E-02	1.67E-01		3.33E-03	1.67E-01	1.67E+00
Shouting, singing	2.00E-03	1.00E-01	1.00E+00		2.00E-02	1.00E+00	1.00E+01
Heavy exercise	4.67E-03	2.33E-01	2.33E+00		4.67E-02	2.33E+00	2.33E+01
No face coverings, contact for prolonged time							
Silent	6.67E-04	3.33E-02	3.33E-01		6.67E-03	3.33E-01	3.33E+00
Speaking	3.33E-03	1.67E-01	1.67E+00		3.33E-02	1.67E+00	1.67E+01
Shouting, singing	2.00E-02	1.00E+00	1.00E+01		2.00E-01	1.00E+01	1.00E+02
Heavy exercise	4.67E-02	2.33E+00	2.33E+01		4.67E-01	2.33E+01	2.33E+02

494 *(b) Exposure time (in h) corresponding to an infection risk parameter (H) value of 0.05 person h^2*

495 *m^{-3}*

Type and level of group activity	Low occupancy			High occupancy		
	Outdoor and well ventilated	Indoor and well ventilated	Poorly ventilated	Outdoor and well ventilated	Indoor and well ventilated	Poorly ventilated
Wear face coverings						
Silent	2142.86	42.86	4.29	214.29	4.29	0.43
Speaking	428.57	8.57	0.86	42.86	0.86	0.09
Shouting, singing	71.43	1.43	0.14	7.14	0.14	0.01
Heavy exercise	30.61	0.61	0.06	3.06	0.06	0.01
No face coverings						
Silent	750.00	15.00	1.50	75.00	1.50	0.15
Speaking	150.00	3.00	0.30	15.00	0.30	0.03
Shouting, singing	25.00	0.50	0.05	2.50	0.05	0.01
Heavy exercise	10.71	0.21	0.02	1.07	0.02	0.00

(c) Estimated attack rate when 0.1% of the local population are infectious

Type and level of group activity	Low occupancy			High occupancy		
	Outdoor and well	Indoor and well	Poorly ventilated	Outdoor and well	Indoor and well	Poorly ventilated
Wear face coverings, contact for short time						
Silent	0.00%	0.01%	0.06%	0.00%	0.06%	0.62%
Speaking	0.00%	0.03%	0.31%	0.01%	0.31%	3.08%
Shouting, singing	0.00%	0.19%	1.86%	0.04%	1.86%	17.10%
Heavy exercise	0.01%	0.44%	4.28%	0.09%	4.28%	35.43%
Wear face coverings, contact for prolonged time						
Silent	0.00%	0.06%	0.62%	0.01%	0.62%	6.06%
Speaking	0.01%	0.31%	3.08%	0.06%	3.08%	26.84%
Shouting, singing	0.04%	1.86%	17.10%	0.37%	17.10%	84.66%
Heavy exercise	0.09%	4.28%	35.43%	0.87%	35.43%	98.74%
No face coverings, contact for short time						
Silent	0.00%	0.02%	0.18%	0.00%	0.18%	1.77%
Speaking	0.00%	0.09%	0.89%	0.02%	0.89%	8.54%
Shouting, singing	0.01%	0.53%	5.22%	0.11%	5.22%	41.47%
Heavy exercise	0.02%	1.24%	11.75%	0.25%	11.75%	71.35%
No face coverings, contact for prolonged time						
Silent	0.00%	0.18%	1.77%	0.04%	1.77%	16.35%
Speaking	0.02%	0.89%	8.54%	0.18%	8.54%	59.05%
Shouting, singing	0.11%	5.22%	41.47%	1.07%	41.47%	99.53%
Heavy exercise	0.25%	11.75%	71.35%	2.47%	71.35%	100.00%

Risk evaluation for indoor spaces with pre-pandemic and mitigation scenarios

Values of the risk parameter H for some typical public spaces under pre-pandemic conditions are tabulated in Table S4 and shown in Figure 2. H in all pre-pandemic settings is on the order of 0.05 persons h^2 m^{-3} or higher, implying significant risk of outbreak during the pandemic. Often, ventilation rates may be lower than official guidance due to e.g. malfunction, lack of maintenance, or attempts to save energy. Substandard ventilation, coupled with poor air distribution, substantially increases the risk of an outbreak and its size. This is consistent with observations that indicate that COVID-19 outbreaks are disproportionately observed in poorly-ventilated environments, which are specifically spaces with little to no added outdoor air or adequately filtered air.[77]However, H and H_r of all of the pre-pandemic spaces are in a regime highly sensitive to mitigation efforts. Therefore mitigation measures such as increasing ventilation or air cleaning, reducing voice volume when speaking, reducing occupancy, shortening duration of occupancy and mask wearing are required to reduce the risk of transmission in similar settings. With mitigation measures implemented, H in these settings can be lowered to the order of 0.01 persons h^2 m^{-3}, low enough to avoid major outbreaks. Particularly, for hospital general examination room, a high-risk setting where there can be coughing infectors emitting quanta at a high rate, a combination of an improvement of ventilation rate to 6 h^{-1}, application of higher efficiency air filters, a halved duration, and a requirement of fit-tested N95 respirators can lower the attack rate from ~90% to negligible (Figure 2c). Use of high-quality masks (e.g., N95/FFP3) is highly effective among the mitigation measures.

(a)

552   *(b)*

554   *(c)*

555
556

Figure 2: (a, b) same format as Figure 1, but for COVID-19 only. Also shown are the H and H_r

values for several common indoor situations listed in Table S4. The H values for the cases with

pre-pandemic settings except for a lower occupancy and the H and H_r values for the ASHRAE

standard cases[50] with pre-pandemic settings except for a lower ventilation rate are shown for

comparison. The standalone legend box is for (a) and (b) only. (c) The approximately

multiplicative effects of various mitigation measures for the hospital general examination room

case are also shown as an example.

Calculation of risk parameters for specific situations

The calculation of H, H', and H_r for specific situations of interest has been implemented in the

COVID-19 aerosol transmission estimator, which is freely available online.[30] The estimator is a

series of spreadsheets that implement the same aerosol transmission model described by Miller

et al.[11] It allows the user to make a copy into an online Google spreadsheet or download it as a

Microsoft Excel file for adaptation to the situations of interest to each user. The model can be

used to estimate the risk of specific situations, to explore the reduction in transmission due to

different control measures (e.g. increased ventilation, masking etc.), and to understand aerosol

transmission modeling for incorporation into more complex models. The model also allows the

estimation of the average CO_2 concentration during an activity, as an additional indicator of

indoor risk, and to facilitate the investigation of the relationship between infection risk and CO_2

concentrations.[36,78] A screenshot of the estimator is shown in Figure S2.

In addition a sheet allows recalculating Table 2 in this paper for sets of parameters different

from those used here (and shown in Table S2).

Discussion

We have explored the relationship between airborne infection transmission when sharing indoor spaces and the parameters of the space using a box / Wells-Riley model. We have derived an expression for the number of secondary infections, and isolated the controllable terms in this expression in two airborne transmission risk parameters, H and H_r.

We find a consistent relationship, with increasing attack rate in the known COVID-19 outbreaks, as the value of H_r increases. This provides some confidence that airborne transmission is important in these outbreaks, and that the models used here capture the key processes important for airborne transmission.

Outbreaks have been observed when H_r is on the order of 0.001 h^2 m^{-3} and higher. A criterion based on H_r (e.g. H_r > 0.01 or 0.1 h^2 m^3, depending on available contact tracing resources) can also be used to determine if an occupant of an indoor space is a "close contact" of an identified infector in the same space through the shared-room air airborne transmission (note that this criterion does not apply to close contacts at risk of infection through short-range (<2 m) airborne transmission). The lowest H for the major COVID-19 outbreaks in indoor settings reported in the literature is ~0.1 person h^2 m^{-3}. Note that all the outbreaks investigated here concern the early to mid-2020 variants of SARS-CoV-2, and a variant twice as contagious as those should reduce the tolerable values of the parameters by about a factor of 2. H can be orders of magnitude higher for the superspreading events where most attendees were infected (e.g. the Skagit Valley choir rehearsal).[11] However, if human activity-dependent factors are not taken into account, H' for all the outbreaks discussed in this paper is ~0.1-0.5 person h^2 m^{-3}. H' values for public indoor spaces usually fall in or near this range primarily due to similar per-person ventilation rates and public event durations. Substandard ventilation, coupled with poor air

distribution, is associated with substantial increases in the risk of outbreak. However, all of the

pre-pandemic example spaces analyzed are in a regime in which they are highly sensitive to

mitigation efforts.

The relative risk of COVID-19 infection falls between that of two well-known airborne diseases:

the more transmissible measles and the less transmissible tuberculosis. This shows that the fact

that COVID-19 is less transmissible than measles does not rule out airborne transmission.

These risk parameters can be applied to other airborne diseases, if outbreaks are characterized

in this framework. This approach may be useful in the design and renovation of building

systems. For a novel disease that was as transmissible as measles, it would be very difficult to

make any indoor activities safe aside from vaccination.

Our analysis shows that mitigation measures to limit aerosol transmission are needed in most

indoor spaces whenever COVID-19 is spreading in a community. Among effective measures are

reducing vocalization, avoiding intense physical activities, shortening duration of occupancy,

reducing number of occupants, wearing high-quality well-fitting masks, increasing ventilation,

improving ventilation effectiveness and applying additional virus removal measures (such as

HEPA filtration and UVGI disinfection). The use of multiple "layers of protection" is needed in

many situations, while a single measure (e.g. masking) may not be able to reduce risk to low

levels. We have shown that combinations of some or all of these measures are able to lower H

close to 0.01 person h^2 m^{-3}, so that the expected number of secondary cases is substantially

lower than 1 even in the presence of an infectious person, hence would be likely to avoid major

outbreaks.

Acknowledgements

ZP and JLJ were partially supported by NSF AGS-1822664. TG was supported by ESRC

ES/V010069/1.

Competing interests

The authors declare no competing interests.

References

(1) Nazaroff, W. W. Indoor Bioaerosol Dynamics. *Indoor Air* **2016**, *26* (1), 61–78.

(2) Morawska, L.; Cao, J. Airborne Transmission of SARS-CoV-2: The World Should Face the Reality. *Environ. Int.* **2020**, *139*, 105730.

(3) Tellier, R. Review of Aerosol Transmission of Influenza A Virus. *Emerg. Infect. Dis.* **2006**, *12* (11), 1657–1662.

(4) Li, Y.; Qian, H.; Hang, J.; Chen, X.; Cheng, P.; Ling, H.; Wang, S.; Liang, P.; Li, J.; Xiao, S.; Wei, J.; Liu, L.; Cowling, B. J.; Kang, M. Probable Airborne Transmission of SARS-CoV-2 in a Poorly Ventilated Restaurant. *Build. Environ.* **2021**, *196*, 107788.

(5) Public Health England. Varicella: The Green Book, Chapter 34. *Immunisation against infectious disease: London, UK* **2015**.

(6) Tellier, R.; Li, Y.; Cowling, B. J.; Tang, J. W. Recognition of Aerosol Transmission of Infectious Agents: A Commentary. *BMC Infect. Dis.* **2019**, *19* (1), 101.

(7) Morawska, L.; Milton, D. K. It Is Time to Address Airborne Transmission of Coronavirus Disease 2019 (COVID-19). *Clin. Infect. Dis.* **2020**, *71* (9), 2311–2313.

(8) Lednicky, J. A.; Lauzardo, M.; Fan, Z. H.; Jutla, A.; Tilly, T. B.; Gangwar, M.; Usmani, M.; Shankar, S. N.; Mohamed, K.; Eiguren-Fernandez, A.; Stephenson, C. J.; Alam, M. M.; Elbadry, M. A.; Loeb, J. C.; Subramaniam, K.; Waltzek, T. B.; Cherabuddi, K.; Morris, J. G., Jr; Wu, C.-Y. Viable SARS-CoV-2 in the Air of a Hospital Room with COVID-19 Patients. *Int. J. Infect. Dis.* **2020**, *100*, 476–482.

(9) National Academies of Sciences, Engineering; Medicine; Others. Airborne Transmission of SARS-CoV-2: Proceedings of a Workshop in Brief. The National Academies Press, Washington, DC 2020.

(10) Prather, K. A.; Marr, L. C.; Schooley, R. T.; McDiarmid, M. A.; Wilson, M. E.; Milton, D. K. Airborne Transmission of SARS-CoV-2. *Science* **2020**, *370* (6514), 303–304.

(11) Miller, S. L.; Nazaroff, W. W.; Jimenez, J. L.; Boerstra, A.; Buonanno, G.; Dancer, S. J.; Kurnitski, J.; Marr, L. C.; Morawska, L.; Noakes, C. Transmission of SARS-CoV-2 by Inhalation of Respiratory Aerosol in the Skagit Valley Chorale Superspreading Event. *Indoor Air* **2021**, *31* (2), 314–323.

(12) Greenhalgh, T.; Jimenez, J. L.; Prather, K. A.; Tufekci, Z.; Fisman, D.; Schooley, R. Ten Scientific Reasons in Support of Airborne Transmission of SARS-CoV-2. *Lancet* **2021**. https://doi.org/10.1016/S0140-6736(21)00869-2.

(13) Tang, J. W.; Marr, L. C.; Li, Y.; Dancer, S. J. Covid-19 Has Redefined Airborne Transmission. *BMJ* **2021**, *373*, n913.

(14) Gelfand, H. M.; Posch, J. The Recent Outbreak of Smallpox in Meschede, West Germany. *Am. J. Epidemiol.* **1971**, *93* (4), 234–237.

(15)   Yu, I. T. S.; Li, Y.; Wong, T. W.; Tam, W.; Chan, A. T.; Lee, J. H. W.; Leung, D. Y. C.;
Ho, T. Evidence of Airborne Transmission of the Severe Acute Respiratory Syndrome
Virus. *N. Engl. J. Med.* **2004**, *350* (17), 1731–1739.
(16)   Dick, E. C.; Jennings, L. C.; Mink, K. A.; Wartgow, C. D.; Inhorn, S. L. Aerosol
Transmission of Rhinovirus Colds. *J. Infect. Dis.* **1987**, *156* (3), 442–448.
(17)   Chen, W.; Zhang, N.; Wei, J.; Yen, H.-L.; Li, Y. Short-Range Airborne Route Dominates
Exposure of Respiratory Infection during Close Contact. *Build. Environ.* **2020**, *176*
(January), 106859.
(18)   Katelaris, A. L.; Wells, J.; Clark, P.; Norton, S.; Rockett, R.; Arnott, A.; Sintchenko, V.;
Corbett, S.; Bag, S. K. Epidemiologic Evidence for Airborne Transmission of SARS-CoV-2
during Church Singing, Australia, 2020. *Emerg. Infect. Dis.* **2021**, *27* (6).
https://doi.org/10.3201/eid2706.210465.
(19)   Shen, Y.; Li, C.; Dong, H.; Wang, Z.; Martinez, L.; Sun, Z.; Handel, A.; Chen, Z.; Chen,
E.; Ebell, M. H.; Wang, F.; Yi, B.; Wang, H.; Wang, X.; Wang, A.; Chen, B.; Qi, Y.; Liang, L.;
Li, Y.; Ling, F.; Chen, J.; Xu, G. Community Outbreak Investigation of SARS-CoV-2
Transmission Among Bus Riders in Eastern China. *JAMA Intern. Med.* **2020**, *180* (12),
1665–1671.
(20)   Kwon, K. S.; Park, J. I.; Park, Y. J.; Jung, D. M.; Ryu, K. W.; Lee, J. H. Evidence of
Long-Distance Droplet Transmission of SARS-CoV-2 by Direct Air Flow in a Restaurant in
Korea. *J. Korean Med. Sci.* **2020**, *35* (46), e415.
(21)   Jang, S.; Han, S. H.; Rhee, J. Y. Cluster of Coronavirus Disease Associated with Fitness
Dance Classes, South Korea. *Emerg. Infect. Dis.* **2020**, *26* (8), 1917–1920.
(22)   Eichler, N.; Thornley, C.; Swadi, T.; Devine, T.; McElnay, C.; Sherwood, J.; Brunton, C.;
Williamson, F.; Freeman, J.; Berger, S.; Ren, X.; Storey, M.; de Ligt, J.; Geoghegan, J. L.
Transmission of Severe Acute Respiratory Syndrome Coronavirus 2 during Border
Quarantine and Air Travel, New Zealand (Aotearoa). *Emerg. Infect. Dis.* **2021**, *27* (5).
https://doi.org/10.3201/eid2705.210514.
(23)   Nissen, K.; Krambrich, J.; Akaberi, D.; Hoffman, T.; Ling, J.; Lundkvist, Å.; Svensson, L.;
Salaneck, E. Long-Distance Airborne Dispersal of SARS-CoV-2 in COVID-19 Wards. *Sci.*
Rep. **2020**, *10* (1), 19589.
(24)   Hwang, S. E.; Chang, J. H.; Oh, B.; Heo, J. Possible Aerosol Transmission of COVID-19
Associated with an Outbreak in an Apartment in Seoul, South Korea, 2020. *Int. J. Infect.*
Dis. **2021**, *104*, 73–76.
(25)   Jones, N. R.; Qureshi, Z. U.; Temple, R. J.; Larwood, J. P. J.; Greenhalgh, T.;
Bourouiba, L. Two Metres or One: What Is the Evidence for Physical Distancing in Covid-
19? *BMJ* **2020**, *370*, m3223.
(26)   Morawska, L.; Tang, J. W.; Bahnfleth, W.; Bluyssen, P. M.; Boerstra, A.; Buonanno, G.;
Cao, J.; Dancer, S.; Floto, A.; Franchimon, F.; Haworth, C.; Hogeling, J.; Isaxon, C.;
Jimenez, J. L.; Kurnitski, J.; Li, Y.; Loomans, M.; Marks, G.; Marr, L. C.; Mazzarella, L.;
Melikov, A. K.; Miller, S.; Milton, D. K.; Nazaroff, W.; Nielsen, P. V.; Noakes, C.; Peccia, J.;
Querol, X.; Sekhar, C.; Seppänen, O.; Tanabe, S.-I.; Tellier, R.; Tham, K. W.; Wargocki, P.;
Wierzbicka, A.; Yao, M. How Can Airborne Transmission of COVID-19 Indoors Be
Minimised? *Environ. Int.* **2020**, *142*, 105832.
(27)   Bond, T. C.; Bosco-Lauth, A.; Farmer, D. K.; Francisco, P. W.; Pierce, J. R.; Fedak, K.
M.; Ham, J. M.; Jathar, S. H.; VandeWoude, S. Quantifying Proximity, Confinement, and
Interventions in Disease Outbreaks: A Decision Support Framework for Air-Transported
Pathogens. *Environ. Sci. Technol.* **2021**, *55* (5), 2890–2898.
(28)   Riley, E. C.; Murphy, G.; Riley, R. L. Airborne Spread of Measles in a Suburban
Elementary School. *Am. J. Epidemiol.* **1978**, *107* (5), 421–432.
(29)   Noakes, C. J.; Sleigh, P. A. Mathematical Models for Assessing the Role of Airflow on
the Risk of Airborne Infection in Hospital Wards. *Journal of The Royal Society Interface*.

2009. https://doi.org/10.1098/rsif.2009.0305.focus.

(30)   Jimenez, J. L.; Peng, Z. COVID-19 Aerosol Transmission Estimator
https://tinyurl.com/covid-estimator (accessed Mar 26, 2021).

(31)   Buonanno, G.; Morawska, L.; Stabile, L. Quantitative Assessment of the Risk of Airborne
Transmission of SARS-CoV-2 Infection: Prospective and Retrospective Applications.
Environ. Int. **2020**, *145*, 106112.

(32)   Lelieveld, J.; Helleis, F.; Borrmann, S.; Cheng, Y.; Drewnick, F.; Haug, G.; Klimach, T.;
Sciare, J.; Su, H.; Pöschl, U. Model Calculations of Aerosol Transmission and Infection
Risk of COVID-19 in Indoor Environments. *Int. J. Environ. Res. Public Health* **2020**, *17* (21),
8114.

(33)   Jones, B.; Sharpe, P.; Iddon, C.; Hathway, E. A.; Noakes, C. J.; Fitzgerald, S. Modelling
Uncertainty in the Relative Risk of Exposure to the SARS-CoV-2 Virus by Airborne Aerosol
Transmission in Well Mixed Indoor Air. *Build. Environ.* **2021**, *191*, 107617.

(34)   Han, E.; Tan, M. M. J.; Turk, E.; Sridhar, D.; Leung, G. M.; Shibuya, K.; Asgari, N.; Oh,
J.; García-Basteiro, A. L.; Hanefeld, J.; Cook, A. R.; Hsu, L. Y.; Teo, Y. Y.; Heymann, D.;
Clark, H.; McKee, M.; Legido-Quigley, H. Lessons Learnt from Easing COVID-19
Restrictions: An Analysis of Countries and Regions in Asia Pacific and Europe. *Lancet*
2020, *396* (10261), 1525–1534.

(35)   Buonanno, G.; Stabile, L.; Morawska, L. Estimation of Airborne Viral Emission: Quanta
Emission Rate of SARS-CoV-2 for Infection Risk Assessment. *Environ. Int.* **2020**, *141*
(April), 105794.

(36)   Peng, Z.; Jimenez, J. L. Exhaled CO_2 as a COVID-19 Infection Risk Proxy for Different
Indoor Environments and Activities. *Environmental Science & Technology Letters* **2021**.
https://doi.org/10.1021/acs.estlett.1c00183.

(37)   Ma, J.; Qi, X.; Chen, H.; Li, X.; Zhang, Z.; Wang, H.; Sun, L.; Zhang, L.; Guo, J.;
Morawska, L.; Grinshpun, S. A.; Biswas, P.; Flagan, R. C.; Yao, M. COVID-19 Patients in
Earlier Stages Exhaled Millions of SARS-CoV-2 per Hour. *Clin. Infect. Dis.* **2020**.
https://doi.org/10.1093/cid/ciaa1283.

(38)   Volz, E.; Mishra, S.; Chand, M.; Barrett, J. C.; Johnson, R.; Geidelberg, L.; Hinsley, W.
R.; Laydon, D. J.; Dabrera, G.; O'Toole, Á.; Amato, R.; Ragonnet-Cronin, M.; Harrison, I.;
Jackson, B.; Ariani, C. V.; Boyd, O.; Loman, N. J.; McCrone, J. T.; Gonçalves, S.;
Jorgensen, D.; Myers, R.; Hill, V.; Jackson, D. K.; Gaythorpe, K.; Groves, N.; Sillitoe, J.;
Kwiatkowski, D. P.; COVID-19 Genomics UK (COG-UK) consortium; Flaxman, S.;
Ratmann, O.; Bhatt, S.; Hopkins, S.; Gandy, A.; Rambaut, A.; Ferguson, N. M. Assessing
Transmissibility of SARS-CoV-2 Lineage B.1.1.7 in England. *Nature* **2021**, 1–17.

(39)   Kidd, M.; Richter, A.; Best, A.; Cumley, N.; Mirza, J.; Percival, B.; Mayhew, M.; Megram,
O.; Ashford, F.; White, T.; Moles-Garcia, E.; Crawford, L.; Bosworth, A.; Atabani, S. F.;
Plant, T.; McNally, A. S-Variant SARS-CoV-2 Lineage B1.1.7 Is Associated with
Significantly Higher Viral Loads in Samples Tested by ThermoFisher TaqPath RT-qPCR. *J.*
Infect. Dis. **2021**. https://doi.org/10.1093/infdis/jiab082.

(40)   EPA. Chapter 6—Inhalation Rates. In *Exposure Factors Handbook*; U.S. Environmental
Protection Agency, 2011.

(41)   Edwards, D. A.; Ausiello, D.; Salzman, J.; Devlin, T.; Langer, R.; Beddingfield, B. J.;
Fears, A. C.; Doyle-Meyers, L. A.; Redmann, R. K.; Killeen, S. Z.; Maness, N. J.; Roy, C. J.
Exhaled Aerosol Increases with COVID-19 Infection, Age, and Obesity. *Proceedings of the*
National Academy of Sciences **2021**, *118* (8), e2021830118.

(42)   van Doremalen, N.; Bushmaker, T.; Morris, D. H.; Holbrook, M. G.; Gamble, A.;
Williamson, B. N.; Tamin, A.; Harcourt, J. L.; Thornburg, N. J.; Gerber, S. I.; Lloyd-Smith, J.
O.; de Wit, E.; Munster, V. J. Aerosol and Surface Stability of SARS-CoV-2 as Compared
with SARS-CoV-1. *N. Engl. J. Med.* **2020**, *382* (16), 1564–1567.

(43)   Chan, K. H.; Peiris, J. S. M.; Lam, S. Y.; Poon, L. L. M.; Yuen, K. Y.; Seto, W. H. The

Effects of Temperature and Relative Humidity on the Viability of the SARS Coronavirus. *Adv. Virol.* **2011**, *2011*, 734690.

(44)   Dabisch, P.; Schuit, M.; Herzog, A.; Beck, K.; Wood, S.; Krause, M.; Miller, D.; Weaver, W.; Freeburger, D.; Hooper, I.; Green, B.; Williams, G.; Holland, B.; Bohannon, J.; Wahl, V.; Yolitz, J.; Hevey, M.; Ratnesar-Shumate, S. The Influence of Temperature, Humidity, and Simulated Sunlight on the Infectivity of SARS-CoV-2 in Aerosols. *Aerosol Sci. Technol.* **2021**, *55* (2), 142–153.

(45)   Johnson, G. R.; Morawska, L.; Ristovski, Z. D.; Hargreaves, M.; Mengersen, K.; Chao, C. Y. H.; Wan, M. P.; Li, Y.; Xie, X.; Katoshevski, D.; Corbett, S. Modality of Human Expired Aerosol Size Distributions. *J. Aerosol Sci.* **2011**, *42* (12), 839–851.

(46)   Thatcher, T. L.; Lai, A. C. K.; Moreno-Jackson, R.; Sextro, R. G.; Nazaroff, W. W. Effects of Room Furnishings and Air Speed on Particle Deposition Rates Indoors. *Atmos. Environ.* **2002**, *36* (11), 1811–1819.

(47)   Ninomura, P.; Bartley, J. New Ventilation Guidelines for Health-Care Facilities. *ASHRAE J.* **2001**, *43* (6), 29–33.

(48)   Nazaroff, W. W. Residential Air-Change Rates: A Critical Review. *Indoor Air* **2021**, *31* (2), 282–313.

(49)   Persily, A. K.; Gorfain, J.; Brunner, G. Survey of Ventilation Rates in Office Buildings. *Build. Res. Inf.* **2006**, *34* (5), 459–466.

(50)   ASHRAE. *Ventilation for Acceptable Indoor Air Quality: ANSI/ASHRAE Standard 62.1-2019*; ANSI/ASHRAE, 2019.

(51)   ASHRAE. *ASHRAE Position Document on Infectious Aerosols*; American Society of Heating, Refrigerating and Air-Conditioning Engineers, 2020.

(52)   REHVA. *How to Operate HVAC and Other Building Service Systems to Prevent the Spread of the Coronavirus (SARS-CoV-2) Disease (COVID-19) in Workplaces*; Federation of European Heating, Ventilation and Air Conditioning Associations, 2020.

(53)   Chen, P. Z.; Bobrovitz, N.; Premji, Z.; Koopmans, M.; Fisman, D. N.; Gu, F. X. Heterogeneity in Transmissibility and Shedding SARS-CoV-2 via Droplets and Aerosols. *Elife* **2021**, *10*, e65774.

(54)   Yang, Q.; Saldi, T. K.; Gonzales, P. K.; Lasda, E.; Decker, C. J.; Tat, K. L.; Fattor, W. T.; Meyerson, N. R.; Paige, C. L.; Gilchrist, A. R.; Barbachano-guerrero, A. Just 2% of SARS-CoV-2−positive Individuals Carry 90% of the Virus Circulating in Communities. *Proceedings of the National Academy of Sciences* **2021**, *118* (21), e2104547118.

(55)   Wu, S. L.; Mertens, A. N.; Crider, Y. S.; Nguyen, A.; Pokpongkiat, N. N.; Djajadi, S.; Seth, A.; Hsiang, M. S.; Colford, J. M.; Reingold, A.; Arnold, B. F.; Hubbard, A.; Benjamin-Chung, J. Substantial Underestimation of SARS-CoV-2 Infection in the United States. *Nature Communications.* 2020. https://doi.org/10.1038/s41467-020-18272-4.

(56)   Jones, T. C.; Biele, G.; Mühlemann, B.; Veith, T.; Schneider, J.; Beheim-Schwarzbach, J.; Bleicker, T.; Tesch, J.; Schmidt, M. L.; Sander, L. E.; Kurth, F.; Menzel, P.; Schwarzer, R.; Zuchowski, M.; Hofmann, J.; Krumbholz, A.; Stein, A.; Edelmann, A.; Corman, V. M.; Drosten, C. Estimating Infectiousness throughout SARS-CoV-2 Infection Course. *Science* **2021**, *373* (6551). https://doi.org/10.1126/science.abi5273.

(57)   Park, S. Y.; Kim, Y. M.; Yi, S.; Lee, S.; Na, B. J.; Kim, C. B.; Kim, J. I.; Kim, H. S.; Kim, Y. B.; Park, Y.; Huh, I. S.; Kim, H. K.; Yoon, H. J.; Jang, H.; Kim, K.; Chang, Y.; Kim, I.; Lee, H.; Gwack, J.; Kim, S. S.; Kim, M.; Kweon, S.; Choe, Y. J.; Park, O.; Park, Y. J.; Jeong, E. K. Coronavirus Disease Outbreak in Call Center, South Korea. *Emerg. Infect. Dis.* **2020**, *26* (8), 1666–1670.

(58)   Khanh, N. C.; Thai, P. Q.; Quach, H.-L.; Thi, N.-A. H.; Dinh, P. C.; Duong, T. N.; Mai, L. T. Q.; Nghia, N. D.; Tu, T. A.; Quang, L. N.; Quang, T. D.; Nguyen, T.-T.; Vogt, F.; Anh, D. D. Transmission of SARS-CoV 2 During Long-Haul Flight. *Emerg. Infect. Dis.* **2020**, *26* (11), 2617–2624.

(59)   Günther, T.; Czech-Sioli, M.; Indenbirken, D.; Robitaille, A.; Tenhaken, P.; Exner, M.;
Ottinger, M.; Fischer, N.; Grundhoff, A.; Brinkmann, M. M. SARS-CoV-2 Outbreak
Investigation in a German Meat Processing Plant. *EMBO Mol. Med.* **2020**, *12* (12), e13296.

(60)   Kriegel, M.; Buchholz, U.; Gastmeier, P.; Bischoff, P.; Abdelgawad, I.; Hartmann, A.
Predicted Infection Risk for Aerosol Transmission of SARS-CoV-2. *medRxiv* **2020**,
2020.10.08.20209106.

(61)   Stein-Zamir, C.; Abramson, N.; Shoob, H.; Libal, E.; Bitan, M.; Cardash, T.; Cayam, R.;
Miskin, I. A Large COVID-19 Outbreak in a High School 10 Days after Schools' Reopening,
Israel, May 2020. *Eurosurveillance* **2020**, *25* (29), 1–5.

(62)   Nardell, E. A.; Keegan, J.; Cheney, S. A.; Etkind, S. C. Airborne Infection: Theoretical
Limits of Protection Achievable by Building Ventilation. *Am. Rev. Respir. Dis.* **1991**, *144* (2),
302–306.

(63)   Gammaitoni, L.; Nucci, M. C. Using a Mathematical Model to Evaluate the Efficacy of TB
Control Measures. *Emerg. Infect. Dis.* **1997**, *3* (3), 335–342.

(64)   Moser, M. R.; Bender, T. R.; Margolis, H. S.; Noble, G. R.; Kendal, A. P.; Ritter, D. G. An
Outbreak of Influenza Aboard a Commercial Airliner. *Am. J. Epidemiol.* **1979**, *110* (1), 1–6.

(65)   Remington, P. L. Airborne Transmission of Measles in a Physician's Office. *JAMA* **1985**,
253 (11), 1574.

(66)   Wilson, N. M.; Marks, G. B.; Eckhardt, A.; Clarke, A. M.; Young, F. P.; Garden, F. L.;
Stewart, W.; Cook, T. M.; Tovey, E. R. The Effect of Respiratory Activity, Non-Invasive
Respiratory Support and Facemasks on Aerosol Generation and Its Relevance to COVID-
19. *Anaesthesia* **2021**. https://doi.org/10.1111/anae.15475.

(67)   James, G.; Witten, D.; Hastie, T.; Tibshirani, R. *An Introduction to Statistical Learning:*
With Applications in R, 1st ed.; Springer texts in statistics; Springer: New York, NY, 2013.

(68)   Milton, D. K.; Fabian, M. P.; Cowling, B. J.; Grantham, M. L.; McDevitt, J. J. Influenza
Virus Aerosols in Human Exhaled Breath: Particle Size, Culturability, and Effect of Surgical
Masks. *PLoS Pathog.* **2013**, *9* (3), e1003205.

(69)   Lindsley, W. G.; Noti, J. D.; Blachere, F. M.; Thewlis, R. E.; Martin, S. B.; Othumpangat,
S.; Noorbakhsh, B.; Goldsmith, W. T.; Vishnu, A.; Palmer, J. E.; Clark, K. E.; Beezhold, D.
H. Viable Influenza A Virus in Airborne Particles from Human Coughs. *J. Occup. Environ.*
Hyg. **2015**, *12* (2), 107–113.

(70)   Yan, J.; Grantham, M.; Pantelic, J.; Bueno de Mesquita, P. J.; Albert, B.; Liu, F.;
Ehrman, S.; Milton, D. K. Infectious Virus in Exhaled Breath of Symptomatic Seasonal
Influenza Cases from a College Community. *Proceedings of the National Academy of*
Sciences **2018**, *115* (5), 1081–1086.

(71)   Tiemersma, E. W.; van der Werf, M. J.; Borgdorff, M. W.; Williams, B. G.; Nagelkerke, N.
J. D. Natural History of Tuberculosis: Duration and Fatality of Untreated Pulmonary
Tuberculosis in HIV Negative Patients: A Systematic Review. *PLoS One* **2011**, *6* (4),
e17601.

(72)   Bueno de Mesquita, P. J.; Noakes, C. J.; Milton, D. K. Quantitative Aerobiologic Analysis
of an Influenza Human Challenge-transmission Trial. *Indoor Air* **2020**, *30* (6), 1189–1198.

(73)   Mikszewski, A.; Stabile, L.; Buonanno, G.; Morawska, L. THE AIRBORNE
CONTAGIOUSNESS OF RESPIRATORY VIRUSES: A COMPARATIVE ANALYSIS AND
IMPLICATIONS FOR MITIGATION. *medRxiv* **2021**.
https://doi.org/10.1101/2021.01.26.21250580.

(74)   Conly, J.; on behalf of the WHO Infection Prevention and Control Research and
Development Expert Group for COVID-; Seto, W. H.; Pittet, D.; Holmes, A.; Chu, M.;
Hunter, P. R. Use of Medical Face Masks versus Particulate Respirators as a Component
of Personal Protective Equipment for Health Care Workers in the Context of the COVID-19
Pandemic. *Antimicrob. Resist. Infect. Control* **2020**, *9* (1), 126.

(75)   Klompas, M.; Baker, M. A.; Rhee, C. Airborne Transmission of SARS-CoV-2: Theoretical

Considerations and Available Evidence. *JAMA* **2020**, *324* (5), 441–442.

(76)   Tang, J. W.; Bahnfleth, W. P.; Bluyssen, P. M.; Buonanno, G.; Jimenez, J. L.; Kurnitski,
J.; Li, Y.; Miller, S.; Sekhar, C.; Morawska, L.; Marr, L. C.; Melikov, A. K.; Nazaroff, W. W.;
Nielsen, P. V.; Tellier, R.; Wargocki, P.; Dancer, S. J. Dismantling Myths on the Airborne
Transmission of Severe Acute Respiratory Syndrome Coronavirus-2 (SARS-CoV-2). *J.*
Hosp. Infect. **2021**, *110*, 89–96.

(77)   WHO. *Roadmap to Improve and Ensure Good Indoor Ventilation in the Context of*
COVID-19; World Health Organization, 2021.

(78)   Rudnick, S. N.; Milton, D. K. Risk of Indoor Airborne Infection Transmission Estimated
from Carbon Dioxide Concentration. *Indoor Air* **2003**, *13* (3), 237–245.