Aerosol SARS-CoV-2 in hospitals and long-term care homes during

the COVID-19 pandemic.

Gary Mallach[1][¶][*], Samantha B. Kasloff[2][¶], Tom Kovesi[3][¶], Anand Kumar[4][¶], Ryan Kulka[1], Jay Krishnan[2], Benoit

Robert[5], Michaeline McGuinty[6], Sophia den Otter-Moore[7], Bashour Yazji[6], Todd Cutts[2]

[1] Water and Air Quality Bureau, Health Canada, Ottawa, Canada.

[2] National Microbiology Laboratory, Public Health Agency of Canada, Winnipeg, Canada

[3] Children's Hospital of Eastern Ontario, University of Ottawa, Ottawa, Canada

[4] Sections of Critical Care Medicine and Infectious Diseases, Departments of Medicine, Medical

Microbiology and Pharmacology, University of Manitoba, Winnipeg, Canada

[5] Department of Family Medicine, University of Ottawa, Ottawa, Canada

[6] Department of Medicine, Ottawa Hospital, University of Ottawa, Ottawa, Canada

[7] Faculty of Medicine, Queen's University, Kingston, Canada

[*] Corresponding author

E-mail: gary.mallach@canada.ca (GM)

[¶]These authors contributed equally to this work and are considered to be First Author

Abstract:

Background: Few studies have quantified aerosol concentrations of SARS-CoV-2 in hospitals and long-term care homes, and fewer still have examined samples for viability. This information is needed to clarify transmission risks beyond close contact.

Methods: We deployed particulate air samplers in rooms with COVID-19 positive patients in hospital ward and ICU rooms, rooms in long-term care homes experiencing outbreaks, and a correctional facility experiencing an outbreak. Samplers were placed between 2 and 3 meters from the patient. Aerosol (small liquid particles suspended in air) samples were collected onto gelatin filters by Ultrasonic Personal Air Samplers (UPAS) fitted with <2.5μm (micrometer) and <10 μm size-selective inlets operated for 16 hours (total 1.92m^3), and with a Coriolis Biosampler over 10 minutes (total 1.5m^3). Samples were assayed for viable SARS-CoV-2 virus and for the viral genome by multiplex PCR using the E and N protein target sequences. We validated the sampling methods by inoculating gelatin filters with viable vesicular stomatitis virus (VSV), and with three concentrations of viable SARS-CoV-2, operating personal samplers for 16hrs, and quantifying viable virus recovery by TCID$_{50}$ assay.

Results: In total, 138 samples were collected from 99 rooms. RNA samples were positive in 9.1% (6/66) of samples obtained with the UPAS 2.5μm samplers, 13.5% (7/52) with the UPAS 10μm samplers, and 10.0% (2/20) samples obtained with the Coriolis samplers. Culturable virus was not recovered in any samples. Viral RNA was detected in 10.9% of the rooms sampled. There was no significant difference in viral RNA recovery between the different room locations or samplers. Method development experiments indicated minimal loss of SARS-CoV-2 viability via the personal air sampler operation.

Key Findings: Although a subset of aerosol samples exhibited detectable SARS-CoV-2 RNA at low titres, the presence of viable SARS-CoV-2 virus in aerosols appears to be infrequent at >2m distance.

Background:

SARS-CoV-2, the virus that causes COVID-19, predominantly spreads during close contact between

shedding individuals and susceptible persons. The virus spreads mainly by inhalation of small respiratory

particles, including from asymptomatic or pre-symptomatic individuals.[1-3] Transmission is most likely

to occur during close, sustained contact in indoor environments with a person who is in the early stages

of infection, where viral concentrations in the air are highest.[4-6] Once expelled, larger respiratory

droplets stay aloft for relatively short periods of time, and typically travel short distances (0 to 2m) while

smaller particles (aerosols) stay aloft for longer and are able to cover larger distances.[7] Although

transmission during close contact is believed to predominate, aerosol transmission has been reported to

occur beyond close contact (e.g., greater than 2m), when infectious respiratory particles are able to

accumulate to levels that can cause infection, such as in indoor environments with inadequate

ventilation or filtration.[1,8] Actions such as coughing, talking and breathing generate respiratory

particles of various sizes, including high numbers of particles smaller than 5-10μm in diameter.[5,9,10]

Particles up to 100μm may remain suspended in aerosols, accumulating and spreading through an

indoor space, again particularly in the absence of adequate ventilation or filtration.[7] Particles less than

5-10μm in diameter, which may remain airborne for extended periods,[11-13] have been shown to

contain infectious particles of SARS, MERS, and H1N1.[14] Indeed, tiny aerosolized particles <1μm may

remain airborne for upwards of 12 hours.[15] In addition to aerosols, fomites may contribute to

transmission, as the virus can remain viable on various surfaces for prolonged periods.[16-18] Additional

data specific to SARS-CoV-2 will help address uncertainties about viral concentrations in aerosols, and

whether aerosolized virus is infectious.[13,15,19,20]

Evidence from outbreak investigations supports the view that aerosol transmission beyond close contact

occurs in certain circumstances (e.g., when ventilation is inadequate); the frequency of this transmission

remains unclear, though it is likely to play a role in super-spreading events.[8,21,22] Moreover,

modelling studies show that even during close contact interactions, aerosols, rather than larger ballistic

droplets, drive viral exposures, as droplets are relatively unlikely to land on a mucus membrane,

compared to the higher likelihood of inhaling aerosols.[23]

Research studies mainly rely on molecular detection of the SARS-CoV-2 genome to determine viral

presence in aerosol samples. However, genome (RNA) presence alone is often seen as insufficient

evidence that aerosol transmission risk is present, as it does not indicate the presence of viable virus.

[24-26] In patient swabs, viable SARS-CoV-2 virus is generally detected only within eight days of

symptom onset, while viral RNA persists long beyond infectivity.[24,27] As such, to determine viral

infectivity, culturing samples in susceptible cells or animal hosts is needed. Persons that are infected

with variants such as B.1.1.7 may shed virus for longer, contributing to higher rates of

transmission.[28,29]

Although cellular assays are required to establish viral infectivity, air sampling campaigns using size-

selective inlets have rarely employed these methods for SARS-CoV-2, given technical challenges in viral

sampling.[13] Several hospital air monitoring studies found the genome of SARS-CoV-2, without

culturing the virus. [11,20,30] Sampling using a size selective inlet and outfitted with a gelatin filter, Liu

et al. found that the highest concentration of viral RNA was present in the size fraction <2.5µm, which

could remain suspended over long periods.[11] Likewise, SARS-CoV-2 RNA has been found on surfaces

far from infected individuals, including on exhaust outlets and ceiling fans where only fine, aerosolized

particles would be likely to reach.[31] These studies indicate that RNA is present in airborne

particles.[13,25] To determine infectiousness, Lednicky et. al. measured virus concentrations inside the

car of a person with COVID-19. They sampled in multiple size fractions and cultured for viability, finding

viable virus present only in the 0.25-0.5µm size fraction, which also had the highest concentration of

viral RNA.[12] It is possible that larger size fractions were preferentially filtered out by the vehicle's

ventilation system.

Lab-based studies generated viable aerosols of <5μm of SARS-CoV-2 that had a half-life of greater than

one hour while airborne.[18] Once airborne, virus viability is reduced by several environmental

pressures, including sunlight, temperature, and relative humidity, while ventilation and filtration reduce

risks of transmission beyond close contact.[32]

The size of a virus-containing particle may also affect infectivity. One study demonstrated that

macaques infected by the aerosol route had more severe disease compared to the

intratracheal/intranasal route.[33] Submicron particles are able to penetrate more deeply into the lungs,

depositing in the alveolar region where immune responses may be evaded.[15] Also, in the alveolar

region the ACE-2 receptors that the SARS-CoV-2 virus binds to are more accessible, possibly increasing

the likelihood of infection.[15,19] This underlines the importance of sampling for viable virus in fine size

fractions.

Organizations including the WHO, REHVA (the Federation of European Heating, Ventilation and Air

Conditioning Associations) and ASHRAE (the American Society of Heating, Ventilating, and Air-

Conditioning Engineers) have recognized the potential hazard of aerosol transmission indoors.[4,5,34]

As such, expert organizations are recommending COVID-19 specific control measures, including

increased ventilation rates, avoiding air recirculation, using air cleaning and disinfection devices, and

reducing the number of occupants.[4,34,35]

Our study objective was to quantify the concentration of SARS-CoV-2 RNA and viable virus in aerosols

collected greater than two meters from patients with COVID-19 infection, specifically in the <2.5um and

<10um size fractions. In order to examine the presence of SARS-CoV-2 in a wide range of high-risk

environments, we conducted air monitoring in hospital rooms, long-term care facility rooms,

penitentiary cells and personal residences housing people with recently diagnosed, active COVID-19

disease.

Methods and Materials:

Aerosol field sampling:

Sampling was conducted adjacent to COVID-19 confirmed-positive patients in hospital rooms (ICU and

medical ward beds), residential homes, exhaust (return) air ducts drawing air from inside penitentiary

cells and living areas, and in long term care home resident rooms. Respiratory particle samples were

collected using Ultrasonic Personal Aerosol Samplers (UPAS, Access Sensor Technologies, Fort Collins,

USA) operated at 2LPM (Liters per minute)(filter face velocity of 0.031 m/s), with either a 2.5µm or

10µm size selective inlet to exclude larger particles or droplets. The UPAS filter cartridge was loaded

with a sterile 37mm gelatin filter (12602-37-ALK, Sartorius, Göttingen, DE) to preserve the integrity and

viability of virus containing particles. UPAS samplers were placed 2 to 3 m from the patient's head for a

16-hour period sampling a total of $1.92m^3$ of air. Prior laboratory testing indicated that longer sampling

duration (larger air sample volumes) could lead to cracking of the gelatin filter membrane. Filters were

pre-loaded into the samplers in a HEPA filtered biological safety cabinet and sealed in a Ziploc bag prior

to sampling. Field and laboratory blanks were deployed to ensure that samples were not contaminated.

Within 2 hours post-collection, gelatin filters were removed from sampler inlets with sterile forceps,

dissolved into 2mL of pre-warmed (37^oC) Viral Transport Medium (VTM) (HBSS, FBS, Gentamycin and

Amphoteracin B) to maintain viability, and kept at 4°C until analyzed.[36,37]

In a subset of locations, we also deployed a Coriolis µ Biosampler (Montigny-le-Bretonneux, France) at

an inlet velocity of 150 LPM for 10 minutes ($1.5m^3$ sample volume). Coriolis air samples were collected

into sterile cones containing 5mL of VTM, which was reduced to 3mL by evaporation during sample

collection. The Coriolis sampler collects particles larger than 0.5µm in size, with no specified cutoff.

Clinician partners working in the respective institutions deployed instruments, pre-programmed to run

at a convenient time, when patients would remain in their rooms.

To ensure that no contaminated instrumentation was re-deployed, after sampling the UPAS and filter

cartridges were thoroughly cleaned and sterilized with 70% ethanol and wiped before being used again.

Prior to loading the gelatin filters, the UPAS filter cartridges and size selective inlets were washed in D.I.

water, dipped in 70% ethanol, and air-dried before assembly. All samples were collected between

September 22, 2020 and January 25, 2021.

140   Aerosol sample processing

Samples taken within the Winnipeg region were taken to the NML (National Microbiology Laboratory,

Winnipeg) within 2 hours post sampling, while samples from the Ottawa area were shipped overnight to

the NML in 2mLs of VTM at 4°C. VTM was pre-warmed at 37°C and incubated for 10 minutes to dissolve

the gelatin filters. Of the resulting solution, 500ul was aspirated into 6 well tissue culture plates for

safety testing to detect viable virus, and 140ul supernatant was used for viral genome detection using

the QIAmp Viral RNA minikit, as per the manufactures protocol. In control trials, we found that keeping

the dissolved filter at 4°C overnight did not reduce viability or nucleic acid detection, compared with

immediate processing.

149   Cell culture

African green monkey VeroE6 cells (ATCC CRL 1586; American Type Culture Collection, Manassas, VA,

United States) were maintained at 37°C+5% CO_2 in Cell Culture Medium (CCM) consisting of Dulbecco's

modified Eagle cell culture medium (DMEM; Hyclone SH3024302) supplemented with 10% Fetal Bovine

serum (FBS; Gibco 12484028) and 10 units per ml of Penicillin/Streptomycin (PS, Gibco 10378016).

Medium for virus cultures (VCM) consisted of DMEM supplemented with 2% FBS and 10 units per ml of

PS.

Virus viability and titration

VeroE6 cells were seeded the day prior in 96-well plates to attain 80% confluence on the day of

titrations.[38] Media from the previously seeded plates was aspirated and replaced with 150ul of fresh

VCM prior to the addition of the sample inoculum. VTM containing dissolved sample filters was added to

dilution blocks and 10-fold serially diluted in VCM where 50 ul was added to plates in replicates of 5 per

dilution series. Plates were incubated at 37°C +5% CO_2 for 5-7 days and examined for CPE where virus

titers were calculated.[38]

For qualitative detection of viable virus present (safety testing), media from previously seeded 6-well

plates was aspirated and 4 mls of fresh VCM was added. To this, 500ul of sample was added and

incubated at 37°C +5% CO_2 for 5-7 days. Wells were examined, compared to a negative control for CPE,

and scored positive or negative based on evident CPE in the cell monolayer.

Method validation using surrogate virus (VSV):

We evaluated the ability of the gelatin filters to maintain virus viability following a 16-hour sampling

period. Vesicular stomatitis virus (VSV) was diluted to 10^5-10^6 $TCID_{50}$ /ml in a tripartite soil load and

spotted onto gelatin filters over 5 different spots in 2ul volumes.[39] Three filters were used as a

positive control and processed immediately, three others were kept overnight in the Biosafety Cabinet

(BSC), and three gelatin filters were placed in a UPAS sampler where it was left running for 16 hours. The

following morning, we inoculated an additional 3 gelatin filters and set a sampling time for 4 hours.

After sampling times were complete, 2mLs of pre-warmed VCM was added to gelatin filters and

incubated for 10 minutes, centrifuged and tittered.

Method validation using SARS-C0V-2

To determine technical limits of detection of viable SARS-CoV-2 using UPAS sampling, and to correlate

viable particles with genomic detection, we spiked gelatin filters with 10ul of SARS-CoV-2 diluted to 10^3,

10^4, or 10^5 TCID$_{50}$ units/mL over five different spots as described above (3 filters per each of the three

dilutions). After a brief drying period under a biosafety cabinet, filters were loaded into the UPAS and

run under typical conditions (16hrs at 2 LPM). The third corresponding filter for each solution was

processed at time of UPAS run start, to be compared with the sampled filters to determine the degree

that viability decreases during sampling. Filters were then dissolved into 2 mL of pre-warmed DMEM,

and qualitative isolation and quantitative end-point titration was determined in Vero E6 cells.

Concentrations were selected to reflect the range of viable aerosol SARS-CoV-2 concentrations

previously reported in a hospital room in Florida.[40]

Molecular viral load (qRT-PCR)

Molecular viral load was determined by qRT-PCR (QuantStudio 5, Applied Biosytems, USA) using the Taq

Path One-Step multiplex mix (Applied Biosystems A28522) with primers and probes targeting the SARS-

CoV-2 nucleocapsid (N)[41] gene and envelope (E) protein (table 1).[42] Thermal cycling conditions were

53°C for 10 min for reverse transcription, followed by 95°C for 2 min and then 40 cycles of 95 °C for 2s,

60°C for 30s. Values are reported as log genome equivalents per mL based on cycle threshold (Ct) values

obtained with a standard curve of known concentration of viral RNA genome containing both the E and

N region.

Oligonucleotide	Sequence 5' to 3'	Volume
E_Sarbeco_F	ACAGGTACGTTAATAGTTAATAGCGT	20uM
E_Sarbeco_P1	ACACTAGCCATCCTTACTGCGCTTCG (FAM)	10uM
E_Sarbeco_R	ATATTGCAGCAGTACGCACACA	20uM
2019-nCoV_N1-F	GAC CCC AAA ATC AGC GAA AT	25uM
2019-nCoV_N1-R	TCT GGT TAC TGC CAG TTG AAT CTG	25uM

| 2019-nCoV_N1-P | ACC CCG CAT TAC GTT TGG TGG ACC-(VIC) | 6.25uM |

195   Table 1: SARS-CoV-2 qRT-PCR primers and probes.

196   We considered the E protein concentrations as more reliable than N, because the primer probe set is

197   much more sensitive than the N. Samples with a Ct values below 36 for either gene were deemed to be

198   RNA positive. If Ct values were above 36, samples were deemed positive only if detection was confirmed

199   on both the E and N protein target PCRs, with Ct values up to 40.

Statistical analysis

Data was tabulated in Excel spreadsheets and analyzed using SPSS version 27 (IBM corporation). One

sample had a borderline Ct, and was included as a "positive" sample in the analyses. Descriptive

statistics were performed. Differences in proportions between groups were evaluated using Chi-square

for large tables. Predictors of viral RNA detection were analyzed using Binomial Logistic Regression. As it

was unclear which sized particles were most likely to contain viral or viral RNA, if any sampler in a given

room was positive for virus, the room was considered to have aerosol virus/viral RNA. Differences

between room types for continuous variables were evaluated using One-Way Analysis of Variance.

Probability values (p) less than 0.05 were considered statistically significant.

Ethics

The following Research Ethics Boards were engaged prior to sampling: Health Canada/Public Health

Agency of Canada, Children's Hospital of Eastern Ontario; The Ottawa Hospital; and the Winnipeg

Hospital. The boards each determined that formal approval was not required for this study, because

sampling was environmental in nature, we did not propose to collect personal information such as time

of symptom onset or current symptomatology, and given the urgent need for this data. Moreover, as

personal information was not being collected, the boards felt that patient consent was not required.

Results

Method Validation Experiments

VSV method validation

Results of the VSV experiment are shown in figure 1. Of 5 logs of viable VSV inoculated onto the surface of the gelatin filters, 3 logs of viable virus remained after both 4 hours and 16 hours of drying without any air movement. For the filters that underwent 16 hours of air sampling, 3.5 logs of viable VSV remained, demonstrating that drawing air through the filter did not further reduce viability. It was thus determined that 16 hours would be the optimal sample duration, reflecting the maximum volume of air that could be drawn through the gelatin filter without leading to excessive drying and cracking, or other damage to the gelatin filter.

227   Figure 1: Impact of air sampling on VSV recovery from gelatin filters.

SARS-CoV-2 method validation

Figure 2 shows that the amount of viable SARS-CoV-2 virus recovered from the gelatin filters was only

minimally impacted by sampling in the UPAS for 16 hours (~2m^3 sample volume). Similarly, there was

minimal loss of viable SARS-CoV-2 when comparing filters processed immediately after inoculation

versus those held in VTM at 4°C overnight (Figure 2). Therefore, we are confident in the ability of the

UPAS to maintain viability of SARS-CoV-2 once collected into the sampler even at low titers of virus.

Furthermore, we compared recovery from samples either processed immediately after dissolving or

after dissolved media was placed at 4°C overnight and found no substantial difference.

Interestingly, SARS-CoV-2 maintained much more viability in the experiments compared to VSV, with the

latter undergoing a reduction of over 90% over the sampling period. As such, method development

experiments are required to quantify the ability of this sampling method to maintain viability for other

viruses of concern.

Treatment Group

Figure 2: Impact of air sampling on SARS-CoV-2 recovery from gelatin filters. Inocula (A), (B) and (C) were

intended to consist of approximately 3.5, 2.5, and 1.5 Log TCID50 of SARS-CoV-2/mL, respectively, with

(A) undiluted (neat), and (B) and (C) diluted from the initial Liquid Inoculum. Following one hour of

drying, inoculated filters were either placed in UPAS units for 16 hours (Air Sampler), dissolved in VTM

and processed immediately (Control), or dissolved at placed at 4°C overnight prior to processing (4°C).

Results represent viable virus recovered in VeroE6 cells by TCID$_{50}$ assay. Whiskers represent standard

deviation of replicate samples.

Air sampling for SARS-CoV-2

Samples were collected from 99 rooms located in ICUs, hospital ward rooms, rooms in long-term care

facilities and at a correctional institute, and a total of 138 samples were obtained. Of the samples, 23

(16.7%) were obtained in ICU rooms, 92 (66.7%) from hospital ward rooms, 15 (10.9%) from rooms in

long-term care facilities, and 8 (5.8%) in the correctional institute. 66 samples (47.8%) were obtained

using the UPAS 2.5μm sampler, 52 (37.7%) using the UPAS 10μm sampler, and 20 (14.5%) with the

Coriolis sampler. In accordance with our procedure, data on patient demographics was not obtained,

beyond the fact that all had SARS-CoV-2 infection confirmed by qRT-PCR. Given that symptoms in

COVID-19 patients take time to develop and worsen, we expect that symptom duration was shortest in

patients in long-term care home and correctional facilities, longer in patients admitted to hospital ward

rooms, and longest in patients residing in intensive care. Actual or approximate air change rates were

available in 85 rooms. The mean air change rate/hour was 12.6 in ICU rooms, 7.5 on ward rooms, and

3.8 in long term care rooms. Estimated air change rate varied from 2 to 16 air changes/hour (mean 8.4,

standard deviation [SD] 4.4).

In all, samples were positive for viral RNA in 15 (10.9%) of rooms sampled, though no viable virus was

detected in any air samples. Among samples we considered positive for our analyses, Ct values for N

protein ranged between 30.17 and 37.96, with a mean of 35.53 (n = 11, SD 2.06) (supplemental Table 1).

For the E protein, Ct ranged from 27.03 to 36.89, with a mean of 33.61 (n = 15, SD 2.33) (Table 2). Mean

RNA copy numbers for the E protein was 941.6 copy numbers/mL (range 61.3 – 11,462; standard error

[SE] 752.4) and mean RNA concentration in the air was 1202.4 copy numbers/m^3 (range 63.8 – 11939.9;

SE 977.2). The highest concentration was observed in a long-term care room, though positive samples

generally showed low air concentrations.

RNA samples were positive in 17.4% of ICU rooms (4/23), 7.6% of ward rooms (7/92), 20% of long-term

care rooms (3/15) and 12.5% of correctional facility rooms (1/8). There was no significant difference in

positivity rates between the different locations (Pearson Chi-Square 3.33; p = 0.34). The mean

concentration of the E protein in the air was 234.2 (SD 219.0; range 74.6 – 551.8) copies/m^3 in ICU

rooms, 139.9 (SD 93.4; range 63.8 – 287.5) copies/m^3 in ward rooms, 4133.7 (SD 6761.8; range 92.7 –

11939.9) copies/m^3 in long-term care rooms, and 394.6 copies/m^3 in one correctional facility return

duct. We also sampled the cold air return that serviced all the inmate's cells and living areas twice, and

did not find viral RNA.

RNA samples were positive in 9.1% (6/66) of samples obtained with the UPAS 2.5 samplers, 13.5% (7/52)

with the UPAS 10 samplers, and 10.0% (2/20) samples obtained with the Coriolis samplers (Table 3).

There was no significant difference in positivity rates with the different samplers (Pearson Chi-Square

0.59, p = 0.74). However, sampling results should not be directly compared between the UPAS and

Coriolis, because they were deployed for very different durations. A logistic regression was performed to

ascertain the effects of room and sampler type and estimated air change rate on the likelihood that a

positive RNA result would be observed. The logistic regression model was not statistically significant

(Table 4; p value for each independent variable > 0.15). There was no significant different in E protein

copy number, Ct value, or copy aerosol concentration in the various room types (data not presented).

287 Discussion:

COVID-19 infection due to the novel SARS-CoV-2 virus has caused a global pandemic, with over 165

million cases reported worldwide, and over 3.4 million deaths at the time of this writing.[43]

Furthermore, respiratory morbidity, activity limitation, and mental health conditions are prevalent,

among other complications.[44] Previous studies have suggested aerosol transmission is occurring

beyond close contact, as per evidence from super spreading events, transmission occurrences between

adjacent rooms, viable virus measurements in air, and animal studies.[8] Our data suggests that SARS-

CoV-2 RNA virus may be present at low levels in aerosols <10um in diameter, >2 m from COVID-19

patients in a variety of settings, but viable virus appears to be uncommon, as has been described

elsewhere.[6]

In classical terms, respiratory viruses have been considered to be spread by droplets. Large droplets

(e.g., > 5 microns in diameter) were believed to contaminate the immediate environment of an

infectious patient, including the air within 2m, leading to infection by direct deposition of virus onto

mucosal surfaces. In addition, large droplets settle in the proximal (within 2m) environment, leading to

fomite transmission where contaminated surfaces are contacted by another person prior to touching

their face thereby acquiring infection. In classical terms, aerosol (or "airborne") spread occurs via small

droplets (e.g., < 5µm) that can remain suspended in air more than 2m from a patient, leading to

infection of susceptible people, via inhalation at a distance.[45] Historically, most respiratory pathogens

are thought to be spread through larger droplets and fomites, with the exceptions of tuberculosis and

the measles and varicella viruses, which are known to exhibit distal aerosol spread.[46] There is also

evidence that influenza virus may be spread through the aerosol route.[19,46] However, the distinction

between droplet and aerosol spread is fairly artificial, whereas in actuality, aerosols and droplets may

both cause transmission within close contact where they are in highest concentrations, and particles

many times larger than the presumed > 5µm cut-off, and perhaps up to 100µm, remain suspended in air

for longer durations and distances.[25] Moreover, inhalation of aerosols may be an important, even

dominant transmission mode both within and beyond close contact.[8,23]

We sampled indoor air for viral RNA and viable SARS-CoV-2 virus in a large number of rooms in a variety

of settings and with a variety of room air change rates. We were careful to always sample two or more

meters from COVID-19 patients, to ensure that we were detecting virus only at distances traditionally

considered to be consistent with airborne transmission. Despite this variety of indoor environments,

viral RNA was detected infrequently. Only 10.9% of rooms contained viral RNA, and while detection

rates were highest in ICU rooms and rooms in long-term care facilities, the differences between room

types were not statistically significant. Differences in detection rates likely reflect a multiplicity of

factors, including each patient's infectivity and duration of illness, room size, and ventilation rates.[24]

No viable virus was found. This likely reflects the same factors. In addition, Ct values were low, and

there is good evidence that detection of viable virus is unlikely when the Ct value is greater than 24.[27]

Our mean Ct values were just over and under 34 for the N and E proteins, respectively. The Ct value was

under 34 for the N protein in only one room, and under 34 for the E protein in eight rooms. We did not

observe a significant difference of RNA positivity rates using samplers capturing larger (10μm) or smaller

particles (2.5μm) or non-sized particles, suggesting viral RNA may be present in a range of particle sizes.

Within the potential limitations of our methodology, our results suggest that aerosol transmission risk

beyond 2m was low in hospital rooms, at the time of our sampling. While hospitalization is more likely

to occur later in the disease course, when infectivity is lower, caution is still warranted.

Expert groups have examined the plausibility of aerosol spread of SARS-CoV-2 virus to beyond 2m, with

some groups reporting that such spread was likely or occurring.[5,8,45,46] However, air sampling data

supporting this assertion is limited, and as such, a recent WHO-funded panel maintains that additional

air sampling data is needed to draw conclusions, due to the lack of viable SARS-CoV-2 detected in

air.[26] Reports in the literature present contradicting data points but all agree that there is detectable

virus within aerosol samples. Liu and colleagues reported finding SARS-CoV-2 RNA in several aerosol

samples in hospitals in China, including a patient toilet room and isolation anterooms where personal

protective equipment was doffed, although resuspension of contaminated surfaces can't be

excluded.[11] In contrast, Cheng and colleagues did not detect viral RNA very close to patients in

isolation rooms with an air change rate of 12 air changes per hour.[47] Razzini and coworkers obtained

five air samples and detected viral RNA in converted negative pressure operating room air and a

corridor.[48] Chia found viral RNA in two of three air samples from airborne isolation rooms in a hospital

in Singapore, including particles 1 to 4 and > 4 microns in size.[30] An air exhaust vent and many room

surfaces had RNA present.[30] Santarpia detected viral RNA in a biocontainment unit in Nebraska, USA

in an air handling grate, 58.3% of corridor samples, and a sample at a doorway over 2m from a patient

receiving oxygen by nasal cannula. Some evidence for viable virus was detected.[49] Numerous room

surfaces also had viral RNA. However, in a small study of 6 hospital patient rooms in this unit, viral RNA

was detected at the foot of each patient's bed, and 3/18 samples had culturable virus, including 2 of the

1-4 micron samples.[50] Similarly, in a small study of 2 patients in hospital in Florida, USA where

sampling was designed to prevent any damage to virions, Lednicky and coworkers observed viral RNA

and viable virus 2 to 4.8 m away from both patients. The air change rate was 6 air changes per hour. [40]

Lednicky also reported finding viable virus in particles 0.25 – 0.5 microns about 1 m from a patient with

minimal symptoms, inside her car.[12] In a larger study of 20 patient rooms in North Carolina, USA

where the air change rate was about 14 air changes per hour, viral RNA was found in three rooms (15%):

particles < 4 microns about 1.4 and 2.2 meters from the head of the bed, and over 4 microns 2.2 meters

from the head of the bed, respectively. No viable virus was detected. Hallway and clinician work stations

did not have detectable virus.[51] Similarly, a study of 22 patient rooms in Quebec, Canada found viral

RNA in six rooms (27.2%), but no viable virus. Rooms had a mean air change rate of 4.85 air changes per

hour, and samplers were located at a window, an unspecified distance from the patient's head.[52]

These studies were generally limited by small sample sizes, inadequate description of the distance

between the patient and the sampler, inconsistent methodologies and reporting, and lack of

determination whether viable virus was present.[26]

The UPAS sampler was appropriate for use in this study, and provided flexibility for collecting aerosol

samples in multiple environments. It is compact, lightweight and quiet, so it is easily deployable and

suitable for personal monitoring. In addition, its internal pump, internal battery, and lack of protruding

pieces or external tubing made it more acceptable for sampling in clinical environments, where clinicians

have limited time, and would be averse to deploying samplers that may increase contamination risks or

disturb patients. Its main benefit for this study was that it can be fitted with validated size-selective

inlets, which allowed us to collect only respiratory particles in the size fractions conventionally defined

as aerosols.

It is worth noting that aerosol sampling, and subsequent culturing, may not be a necessary indicator of

whether or not a virus is spread through aerosols. Infectious and non-infectious virus are expelled by the

respiratory tract via similar mechanisms, so the presence of RNA in air may indicate that aerosol

transmission is possible. Indeed, recognized airborne diseases such as measles and tuberculosis have

never been successfully cultured from indoor air.[8]

Our study had several limitations, which may have affected our ability to detect airborne viral RNA and

viable virus. In accordance with REB requirements, no direct sampling of patients was performed to

determine their infectiousness, and we did not have access to patient history, including demographics or

symptoms, or illness duration. Almost all hospitalized patients were admitted at least five days after

symptom onset, when they are less likely to be shedding infectious virus, though they may still shed

non-infectious RNA. [24] Studies have shown that patients shed viable virus for a fairly short period of

time (on average for several days before the onset of symptoms, and for 8 days or less after symptom

onset), and it is possible that sampling earlier in the course of these patients' illness would have had a

higher positivity rate.[53] Also, viral shedding may not be a continuous event, even during the infectious

stage. It is possible that shedding is intermittent, and our 16hr sampling may have missed these events.

Furthermore, the amount of shedding varies substantially between people, and we may not have

sampled near high-emitters.[6,54] Our data is consistent with observations that the window of time

where infectious aerosol may be present is generally short.[53] While no viable virus was detected, we

believe that if sampling was conducted earlier in the course of infection, it would be more likely that

viable virus would be detected, as viable virus is present in the same size fraction as the non-infectious

virus we detected, occasionally in high concentrations.[12] However, sampling was also conducted near

penitentiary prisoners many of whom were asymptomatic when diagnosed or were within a day or two

of symptoms; and in LTC and ward patient rooms identified through routine testing as part of an

outbreak. Viable virus was not detected in those samples. Unexpectedly, higher rates of viral RNA

detection did not occur during sampling in rooms in several long-term care facilities and in penitentiary

cells during institutional outbreaks, despite these patients being in early stages of infection, when they

were asymptomatic or had likely only recently developed symptoms. Moreover, these sampling events

took place in locations where room air changes rates were either known or presumed to be lower than

hospital settings. Room ventilation data was obtained by hospital facilities management departments; in

many cases, these were measured directly in study rooms, but in other cases, only data from "typical" or

similar rooms in the facility were available.

Several issues could have affected our ability to capture viable virus beyond close contact. The vast

majority of our collections took place in well-ventilated environments, where it is less likely to find

aerosols. It remains possible that the act of sample collection (i.e., initial path of virus through size-

selective inlet and into sampler) could reduce virus viability, as we could not test this experimentally.

However, Lednicky et. al., successfully captured viable SARS-CoV-2 using a similar size selective inlet in

similar conditions.[12] Also, if the samplers led to fragmentation of virus, we should have observed

relatively large quantities of fragmented RNA, which was not the case. To mitigate this risk, we chose a

gelatin filter to collect any virus drawn into the samplers, to maximize viability of the virus. We

confirmed through method validation experiments that SARS-CoV-2 viability would be preserved on the

gelatin media. Given the low Ct values of viral RNA we observed, it was unlikely we would observe viable

virus, as has been observed elsewhere.[13,55] Specifically, Bullard et al. reported that no viral growth

was observed when the Ct was greater than 24.[24] It is possible that our airborne sampling degraded

virus making the detection of viable virus unlikely, but we confirmed that our samplers preserved the

viability of a surrogate virus, and if we captured viable virus that had disintegrated during capture in our

samplers, we would expect low Ct values reflecting large amount of fragmented viral RNA.

Conclusions:

This study carefully assessed whether infectious SARS-CoV-2 virus is present in indoor air at distances

felt to be compatible with aerosol transmission of virus. In generally well-ventilated spaces, we found

only low concentrations of viral RNA at >2m distance, and we did not detect viable virus. Concentrations

in the air averaged 1202 copies/m^3 and ranged up to 11939 copies/m^3. Previous studies found viable

SARS-CoV-2 aerosols in samples with similar RNA concentrations.[12,40]

Restricting the sampling to the <2.5µm and <10µm size fractions ensured that only viruses present in

aerosols were captured, and provided additional information on the size fractions containing the virus.

Together with the field data collection, our method development experiments demonstrate that

conventional air sampling equipment (i.e., personal air sampling equipment) may be used for the

purpose of virus sampling, with the support and expertise on particle capture from the aerosol sciences,

and lab analysis and interpretation from virology and medicine.

The information present here on levels of virus in respiratory particles, their presence in aerosols >2

metres from patients, and their size, may support infection control measures and PPE guidelines in

buildings preparing for re-occupancy, medical facilities, long term care facilities, and other common

spaces. Our data are consistent with existing public health guidance to maintain physical distance, wash

hands, wear high quality and well-fitted masks, avoid crowded and confined indoor spaces, and ensure

indoor spaces are well-ventilated.

Acknowledgements

437   We would like to thank Dr. Kathryn Suh from The Ottawa Hospital, and Lynn Kyte from the Children's

438   Hospital of Eastern Ontario Research Institute for their support, and Health Canada and the Public

439   Health Agency of Canada for funding support.

References

References

(1) Morawska L, Cao J. Airborne transmission of SARS-CoV-2: The world should face the reality. Environ

Int 2020:105730.

(2) Anderson EL, Turnham P, Griffin JR, Clarke CC. Consideration of the Aerosol Transmission for COVID-

19 and Public Health. Risk Analysis 2020.

(3) Asadi S, Bouvier N, Wexler A, Ristenpart W. The coronavirus pandemic and aerosols: Does COVID-19

transmit via expiratory particles? Aerosol Science and Technology 2020:1-4.

(4) World Health Organization (WHO). Roadmap to improve and ensure good indoor ventilation in the

context of COVID-19. Geneva: World Health Organization; 2021. Licence: CC BY-NC-SA 3.0 IGO.

2021;ISBN 978-92-4-002128-0.

(5) World Health Organization (WHO). **Coronavirus disease (COVID-19): How is it transmitted?**. 2020;

Available at: https://www.who.int/news-room/q-a-detail/coronavirus-disease-covid-19-how-is-it-

transmitted. Accessed May/, 2021.

(6) Yang Q, Saldi TK, Lasda E, Decker CJ, Paige CL, Muhlrad DG, et al. Just 2% of SARS-CoV-2-positive

individuals carry 90% of the virus circulating in communities. medRxiv 2021.

(7) Wells WF. On air-borne infection. Study II. Droplets and droplet nuclei. American Journal of Hygiene

1934;20:611-618.

(8) Greenhalgh T, Jimenez JL, Prather KA, Tufekci Z, Fisman D, Schooley R. Ten scientific reasons in

support of airborne transmission of SARS-CoV-2. The Lancet 2021.

(9) Miller SL, Nazaroff WW, Jimenez JL, Boerstra A, Buonanno G, Dancer SJ, et al. Transmission of SARS-

CoV-2 by inhalation of respiratory aerosol in the Skagit Valley Chorale superspreading event. Indoor Air

2021;31(2):314-323.

(10) Fennelly K. Particle sizes of infectious aerosols: implications for infection control.Lancet Respir

Med.2020; 8 (9): 914-24 .

(11) Liu Y, Ning Z, Chen Y, Guo M, Liu Y, Gali NK, et al. Aerodynamic analysis of SARS-CoV-2 in two

Wuhan hospitals. Nature 2020:1-6.

(12) Lednicky JA, Lauzardo M, Alam MM, Elbadry MA, Stephenson CJ, C.Gibson J, et al. Isolation of SARS-

CoV-2 from the air in a car driven by a COVID patient with mild illness. medRxiv 2021 Cold Spring Harbor

Laboratory Press:2021.01.12.21249603.

(13) Birgand G, Peiffer-Smadja N, Fournier S, Kerneis S, Lescure F, Lucet J. Assessment of Air

Contamination by SARS-CoV-2 in Hospital Settings. JAMA network open 2020;3(12):e2033232-

e2033232.

(14) Wu Z, Harrich D, Li Z, Hu D, Li D. The unique features of SARS-CoV-2 transmission: Comparison with

SARS-CoV, MERS-CoV and 2009 H1N1 pandemic influenza virus. Rev Med Virol 2020:e2171.

(15) Prather KA, Wang CC, Schooley RT. Reducing transmission of SARS-CoV-2. Science 2020.

(16) Kasloff SB, Leung A, Strong JE, Funk D, Cutts T. Stability of SARS-CoV-2 on critical personal protective

equipment. Scientific reports 2021;11(1):1-7.

(17) Riddell S, Goldie S, Hill A, Eagles D, Drew TW. The effect of temperature on persistence of SARS-

CoV-2 on common surfaces. Virology journal 2020;17(1):1-7.

(18) van Doremalen N, Bushmaker T, Morris DH, Holbrook MG, Gamble A, Williamson BN, et al. Aerosol

and surface stability of SARS-CoV-2 as compared with SARS-CoV-1. N Engl J Med 2020;382(16):1564-

1567.

(19) Tellier R, Li Y, Cowling BJ, Tang JW. Recognition of aerosol transmission of infectious agents: a

commentary. BMC infectious diseases 2019;19(1):101.

(20) Santarpia JL, Rivera DN, Herrera V, Morwitzer MJ, Creager H, Santarpia GW, et al. Transmission

potential of SARS-CoV-2 in viral shedding observed at the University of Nebraska Medical Center.

MedRxIV 2020.

(21) Fang FC, Benson CA, Del Rio C, Edwards KM, Fowler VG, Fredricks DN, et al. COVID-19—Lessons

Learned and Questions Remaining. Clinical Infectious Diseases 2020.

(22) Miller SL, Nazaroff WW, Jimenez JL, Boerstra A, Buonanno G, Dancer SJ, et al. Transmission of SARS-

CoV-2 by inhalation of respiratory aerosol in the Skagit Valley Chorale superspreading event. Indoor Air

2020.

(23) Gao CX, Li Y, Wei J, Cotton S, Hamilton M, Wang L, et al. Multi-route respiratory infection: when a

transmission route may dominate. Sci Total Environ 2021;752:141856.

(24) Bullard J, Dust K, Funk D, Strong JE, Alexander D, Garnett L, et al. Predicting infectious SARS-CoV-2

from diagnostic samples. Clinical Infectious Diseases 2020.

(25) Wilson N, Norton A, Young F, Collins D. Airborne transmission of severe acute respiratory syndrome

coronavirus―2 to healthcare workers: a narrative review. Anaesthesia 2020.

(26) Heneghan C, Spencer EA, Brassey J, Plüddemann A, Onakpoya IJ, Evans D, et al. SARS-CoV-2 and the

role of airborne transmission: a systematic review. F1000Research 2021;10(232):232.

(27) Engelmann I, Alidjinou EK, Ogiez J, Pagneux Q, Miloudi S, Benhalima I, et al. Preanalytical issues and

cycle threshold values in SARS-CoV-2 real-time RT-PCR testing: should test results include these? ACS

omega 2021;6(10):6528-6536.

(28) Calistri P, Amato L, Puglia I, Cito F, Di Giuseppe A, Danzetta ML, et al. Infection sustained by lineage

B. 1.1. 7 of SARS-CoV-2 is characterised by longer persistence and higher viral RNA loads in

nasopharyngeal swabs. International Journal of Infectious Diseases 2021;105:753-755.

(29) Kissler SM, Fauver JR, Mack C, Tai C, Breban M, Watkins AE, et al. Densely sampled viral trajectories

suggest longer duration of acute infection with B. 1.1. 7 variant relative to non-B. 1.1. 7 SARS-CoV-2.

medRxiv 2021.

(30) Chia PY, Coleman KK, Tan YK, Ong SWX, Gum M, Lau SK, et al. Detection of Air and Surface

Contamination by Severe Acute Respiratory Syndrome Coronavirus 2 (SARS-CoV-2) in Hospital Rooms of

Infected Patients. medRxiv 2020.

(31) Ong SWX, Tan YK, Chia PY, Lee TH, Ng OT, Wong MSY, et al. Air, surface environmental, and

personal protective equipment contamination by severe acute respiratory syndrome coronavirus 2

(SARS-CoV-2) from a symptomatic patient. JAMA 2020;323(16):1610-1612.

(32) Dabisch P, Schuit M, Herzog A, Beck K, Wood S, Krause M, et al. The influence of temperature,

humidity, and simulated sunlight on the infectivity of SARS-CoV-2 in aerosols. Aerosol Science and

Technology 2021;55(2):142-153.

(33) Bixler SL, Stefan CP, Jay A, Rossi FD, Ricks KM, Shoemaker CJ, et al. Aerosol Exposure of Cynomolgus

Macaques to SARS-CoV-2 Results in More Severe Pathology than Existing Models. bioRxiv 2021.

(34) Morawska L, Tang JW, Bahnfleth W, Bluyssen PM, Boerstra A, Buonanno G, et al. How can airborne

transmission of COVID-19 indoors be minimised? Environ Int 2020:105832.

(35) American Society for Heating, Refrigeration, and Air-Conditioning Engineers. ASHRAE position

document on infectious aerosols. 2020.

(36) Rogers AA, Baumann RE, Borillo GA, Kagan RM, Batterman HJ, Galdzicka MM, et al. Evaluation of

Transport Media and Specimen Transport Conditions for the Detection of SARS-CoV-2 by Use of Real-

Time Reverse Transcription-PCR. J Clin Microbiol 2020 Jul 23;58(8):10.1128/JCM.00708-20. Print 2020

Jul 23.

(37) Chin AWH, Chu JTS, Perera MRA, Hui KPY, Yen HL, Chan MCW, et al. Stability of SARS-CoV-2 in

different environmental conditions. Lancet Microbe 2020 May;1(1):e10-5247(20)30003-3. Epub 2020

Apr 2.

(38) Reed LJ, Muench H. A simple method of estimating fifty per cent endpoints. Am J Epidemiol

1938;27(3):493-497.

(39) American Society for Testing and Materials. Standard quantitative disk carrier test method for

determining the bactericidal, virucidal, fungicidal, mycobactericidal and sporicidal activities of liquid

chemical germicides. : ASTM International; 2002.

(40) Lednicky JA, Lauzard M, Fan ZH, Jutla A, Tilly TB, Gangwar M, et al. Viable SARS-CoV-2 in the air of a

hospital room with COVID-19 patients. International Journal of Infectious Diseases 2020;100:476-482.

(41) Centers for Disease Control and Prevention (CDC). Research use only 2019-novel coronavirus (2019-

nCoV) real-time rt-pcr primer and probe information. 2020; Available at:

https://www.cdc.gov/coronavirus/2019-ncov/lab/rt-pcr-panel-primer-probes.html. Accessed March/25,

2021.

(42) Corman VM, Landt O, Kaiser M, Molenkamp R, Meijer A, Chu DK, et al. Detection of 2019 novel

coronavirus (2019-nCoV) by real-time RT-PCR. Eurosurveillance 2020;25(3):2000045.

(43) Worldometers. COVID-19 Coronavirus Pandemic. 2021; Available at:

https://www.worldometers.info/coronavirus/. Accessed May/19, 2021.

(44) Huang C, Huang L, Wang Y, Li X, Ren L, Gu X, et al. 6-month consequences of COVID-19 in patients

discharged from hospital: a cohort study. The Lancet 2021.

(45) Tang S, Mao Y, Jones RM, Tan Q, Ji JS, Li N, et al. Aerosol transmission of SARS-CoV-2? Evidence,

prevention and control. Environ Int 2020 Nov;144:106039.

(46) MacIntyre CR, Ananda-Rajah MR. Scientific evidence supports aerosol transmission of SARS-COV-2.

Antimicrobial Resistance & Infection Control 2020;9(1):1-3.

(47) Cheng VC, Wong S, Chan VW, So SY, Chen JH, Yip CC, et al. Air and environmental sampling for

SARS-CoV-2 around hospitalized patients with coronavirus disease 2019 (COVID-19). Infection Control &

Hospital Epidemiology 2020;41(11):1258-1265.

(48) Razzini K, Castrica M, Menchetti L, Maggi L, Negroni L, Orfeo NV, et al. SARS-CoV-2 RNA detection in

the air and on surfaces in the COVID-19 ward of a hospital in Milan, Italy. Sci Total Environ

2020;742:140540.

(49) Santarpia JL, Rivera DN, Herrera VL, Morwitzer MJ, Creager HM, Santarpia GW, et al. Aerosol and

surface contamination of SARS-CoV-2 observed in quarantine and isolation care. Scientific reports

2020;10(1):1-8.

(50) Santarpia JL, Herrera VL, Rivera DN, Ratnesar-Shumate S, Denton PW, Martens JW, et al. The

infectious nature of patient-generated SARS-CoV-2 aerosol. MedRxiv 2020.

(51) Binder RA, Alarja NA, Robie ER, Kochek KE, Xiu L, Rocha-Melogno L, et al. Environmental and

aerosolized severe acute respiratory syndrome coronavirus 2 among hospitalized coronavirus disease

2019 patients. J Infect Dis 2020;222(11):1798-1806.

(52) Dumont-Leblond N, Veillette M, Mubareka S, Yip L, Longtin Y, Jouvet P, et al. Low incidence of

airborne SARS-CoV-2 in acute care hospital rooms with optimized ventilation. Emerging microbes &

infections 2020;9(1):2597-2605.

(53) Singanayagam A, Patel M, Charlett A, Bernal JL, Saliba V, Ellis J, et al. Duration of infectiousness and

correlation with RT-PCR cycle threshold values in cases of COVID-19, England, January to May 2020.

Eurosurveillance 2020;25(32):2001483.

(54) Fisman DN, Bogoch I, Lapointe-Shaw L, McCready J, Tuite AR. Risk factors associated with mortality

among residents with coronavirus disease 2019 (COVID-19) in long-term care facilities in Ontario,

Canada. JAMA network open 2020;3(7):e2015957-e2015957.

(55) Bullard J, Funk D, Dust K, Garnett L, Tran K, Bello A, et al. Infectivity of severe acute respiratory

syndrome coronavirus 2 in children compared with adults. CMAJ 2021 Apr 26;193(17):E601-E606.

Location	Number of Samples	Mean Air Exchange Rate	Number (%) positive	Mean (SD) Air concentration (copies/M³) (E target)	Range of air concentrations (copies/M³) (E target)	Mean (SD) copy number (E target):	Range of copy numbers/mL (E target):	Mean (SD) of Ct value (E target):	Range of Ct values (E target)
ICU	23	12.8	4 (17%)	234.2 (219.0)	74.6 – 551.8	224.8 (210.2)	71.6-529.7	33.0 (1.4)	31.2-34.3
Ward	92	8.4	7 (8%)	139.9 (93.4)	63.8 – 287.5	134.3 (89.6)	61.3-276.0	35.0 (1.2)	33.3-36.89
Long-term care	15	3.85	3 (20%)	4133.7 (6761.8)	92.7 – 11939.9	3968.3 (6491.3)	89.0-11462.3	31.6 (4.1)	27.0-35.0
Correctional Facility	8	n/a	1 (13%)	394.6	n/a	378.9	378.9	32.4	32.4

Table 2a. Positive SARS-CoV-2 RNA samples by room type, including Ct values for E target.

Location	Number of Samples	N target: mean Ct (SD) for positive samples	N target: Ct range for positive samples
ICU	23	35.7 (1.4)	34.3-37.1
Ward	92	36.4 (0.4)	36.0-37.0
Long-term care	15	34.3 (3.9)	30.2-38.0
Correctional Facility	8	35.5	35.5

Table 2b. Positive SARS-CoV-2 RNA samples by room type, including Ct values for N target.

Location	Total number of Collection events	Sampler	Number of samples by sampler type (n)	Number (%) Positive by sampler	Mean Ct for positive samples (E target)	Range of Ct for positive samples (E target):	Mean Ct for positive samples (N target):
ICU		2.5 Micron	11	2 (18%)	32.75	32.75	37.06
	12	10 Micron	1	0	n/a	n/a	n/a
		Coriolis	11	2 (18%)	32.5	31.23-33.77	34.96
Ward		2.5 Micron	49	4 (8%)	35.29	33.71-36.89	36.48
	51	10 Micron	34	3 (9%)	34.60	33.30-35.61	36.23
		Coriolis	9	0	n/a	n/a	n/a
Long-term Care		2.5 Micron	2	0	n/a	n/a	n/a
	15	10 Micron	13	3 (23%)	31.59	27.03-35	34.30
		Coriolis	0	n/a	n/a	n/a	n/a
Correctional Facility		2.5 Micron	4	0	n/a	n/a	n/a a
	8	10 Micron	4	1 (25%)	32.44	32.44	35.47
		Coriolis	0	n/a	n/a	n/a	n/a

Table 3. SARS-CoV-2 RNA sample results by location, sampler type

	B	S.E.	Wald	df	Sig.	Exp(B)
Air Change Rate	-.039	.128	.090	1	.764	.962
Room Type			3.749	2	.153	
Sampler Type			.238	2	.888	
Constant	-1.096	1.141	.922	1	.337	.334

Table 4. Logistic Regression results showing likelihood of positive RNA by air exchange rate, room type, and sample type.