2 Can 10x cheaper, lower-efficiency particulate air filters and box fans

3 complement High-Efficiency Particulate Air (HEPA) purifiers to help control

4 the COVID-19 pandemic?

5 Devabhaktuni Srikrishna, Patient Knowhow, Inc.

6 sri.devabhaktuni@gmail.com, www.patientknowhow.com

Abstract: Public health departments such as CDC and California Department of Public Health (CA-DPH) advise HEPA-purifiers to limit transmission of SARS-CoV-2 indoor spaces. CA-DPH recommends air exchanges per hour (ACH) of 4-6 air for rooms with marginal ventilation and 6-12 in classrooms often necessitating multiple HEPA-purifiers per room, unaffordable in under-resourced community settings. Pressure to seek cheap, rapid air filtration resulted in proliferation of lower-cost, Do-It-Yourself (DIY) air purifiers whose performance is not well characterized compared to HEPA-purifiers. Primary metrics are clean air delivery rate (CADR), noise generated (dBA), and affordability ($$). CADR measurement often requires hard-to-replicate laboratory experiments with generated aerosols. We use simplified, low-cost measurement tools of ambient aerosols enabling scalable evaluation of aerosol filtration efficiencies (0.3 to 10 microns), estimated CADR, and noise generation to compare 3 HEPA-purifiers and 9 DIY purifier designs. DIY purifiers consist of one or two box fans coupled to single MERV 13-16 filters (1"-5" thick) or quad filters in a cube. Accounting for reduced filtration efficiency of MERV 13-16 filters (versus HEPA) at the most penetrating particle size of 0.3 microns, estimated CADR of DIY purifiers using 2" (67%), 4" (66%), and 5" (85%) filters at lowest fan speed was 293 cfm ($35), 322 cfm ($58), and 405 cfm ($120) comparable to best-in-class, low-noise generating HEPA-purifier running at maximum speed with at 282 cfm ($549). Quad filter designs, popularly known Corsi-Rosenthal boxes, achieved gains in estimated CADR below 80% over single filter designs, less than the 100% gain by adding a second DIY purifier. Replacing one of the four filters with a second fan resulted in gains of 125%-150% in estimated CADR. Tested DIY alternatives using lower-efficiency, single filters compare favorably to tested HEPA-purifiers in estimated CADR, noise generated at five to ten times lower cost, enabling cheap, rapid aerosol removal indoors.

9 **Conflicts of Interest**

10 I have no relevant interests to declare. I am not associated with any of the manufacturers

11 mentioned in this research.

Introduction

Recent studies demonstrate live SARS-CoV-2 in micron[1,2] and submicron[3] aerosols from the

exhaled breath of infected people. Pathogen-carrying aerosols have potential to accumulate in

airspaces of poorly ventilated, indoor spaces such as classrooms, clinics, offices, homes,

restaurants, and bars and other community settings, and if inhaled may result in COVID-19

infections.[4] Separately, toxic aerosol pollution such as from wildfires, wood burning, and

other sources can be encountered in these same locations with ventilation using unfiltered,

outdoor air. Portable air filtration in the form of commercially available, high efficiency

particulate air purifiers (HEPA-purifiers) is useful to remove both types of aerosols without

relying on centralized air-handling systems designed to turn on / off to control temperature,

not necessarily to run continuously to sanitize the air.

Indoor ventilation upgrades, HEPA-purifiers, and respirators (e.g. N95) can reduce inhalation

of SARS-CoV-2 and its variants, other airborne viruses, aerosolized bacteria, and particulate

pollution, including allergens such as pollen, dust, bacteria, fungi, etc. However,

purifiers/ventilation can be expensive[71] and respirators can be difficult to wear for an

extended period of time causing many organizations or households to hesitate. To mitigate

COVID exposures in non-healthcare settings (including businesses, companies, offices,

restaurants, schools, faith-based organizations, etc.), recent guidance by California

Department of Public Health is that air in rooms with marginal ventilation be filtered 4 to 6

times per hour (i.e. 4-6 air exchanges per hour or ACH), and in classrooms, 6 ACH minimum

with as high as 12 ACH preferable (page 5 of "Ventilation and Filtration to Reduce Long-

Range Airborne Transmission of COVID-19 and Other Respiratory Infections:

Considerations for Reopened Schools"[90]). A recent study from Italy suggests infection rates

were cut by 40% to 80% in classrooms that implemented mechanical ventilation of from 2 to

6 ACH respectively still allowing some level of transmission.[84,87] For comparison, CDC and

WHO recommend an airborne isolation room in a hospital to have a minimum of 12 ACH

based on the time required for airborne-contaminant removal[54] and estimated risk of

infection.[91] To meet or exceed any of these ACH targets, high price-points for select HEPA-

purifier models without incurring excessive noise generation make them unaffordable for

many households and communities.

For example, in a typical classroom (30'x30'x8'), a HEPA-purifier with clean air delivery rate

(CADR) of 300 cubic feet per minute (cfm) needs 24 minutes to cycle the air once (2.5 air

exchanges per hour or ACH) under ideal mixing conditions.[5 6] This classroom would require

2-3 air HEPA-purifiers with low-noise generation costing $400-$500 each (with periodic

$40-$80 filter replacements) to achieve 4-6 ACH costing approximately $1000-$1500 per

classroom, outside the budget of many schools. If needed, getting to 12 ACH as in hospitals

would require proportionally more HEPA-purifiers putting it further out of reach.

Lower-cost alternatives to HEPA-purifiers have been in use for a decade, but their air

filtration and safety properties have not been examined in detail until recently. A Minimum

Efficiency Rating Value-13 (MERV-13) filter attached to a box fan (e.g. using duct tape,

bungee cord, rubber band, clips) was demonstrated to effectively filter wildfire PM2.5 and

submicron particles.[7] Ford Motor Company sponsored "Scrappy Filtration" which donated

20,000 box-fan and air filters held together with a cardboard structure for use in classrooms

to underserved communities.[8 9] However, the published literature regarding these lower-cost

box-fan-filters is lacking key metrics such as filtration efficiency (%), air flow (CADR), and

noise generation (dBA) and does not use lower-cost, rapid test methods (e.g. that do not

require a potentially more expensive, sealed test chamber) which would more readily enable

comparisons to a wider range of HEPA-purifiers.

Below, we compare cost-effectiveness of aerosol filtration by best-in-class, portable HEPA-

purifiers and do-it-yourself (DIY) alternatives built from box fans and HVAC filters rated at

MERV-13, 14, 15 and 16. Comparison is based on three metrics: estimated clean air delivery

rate (CADR), the noise generated (dBA), and initial cost or affordability ($). Measurement

devices include an ISO-certified, calibrated aerosol meter for input/output particle filtration

of sizes ranging from 0.3 μm to 10 μm, airspeed meter to measure airflow, and NIOSH sound

meter app to measure noise. Leveraging these test methods, we were able to evaluate and

compare three different HEPA-purifiers against common DIY fan-filter configurations.

Tested DIY configurations include box fans with six single-filter configurations in Table 2,

and five multiple filter configurations in Table 3 (four quad filter with one box fan and one

triple filter with two box fans). Each configuration utilized the same make/model of box fan

tested at speeds 1 and 3 as shown in the columns of Tables 2 and 3. Specifications are

provided in the Methods section. Tested configurations with the quad filter design are based

on a cube formation, popularly known on social media as the Corsi-Rosenthal box, proposed

to enhance airflow and CADR over single filter designs. In order to examine how CADR is

impacted by additional flow, the Corsi-Rosenthal DIY cube (4 filters and 1 fan) was

compared to a cube design replacing one of the four filters with an additional fan (i.e., 3

filters 2 fans). A preview of these results showing estimated CADR versus cost is shown in

Figure 1 with examination of the multidimensional tradeoffs between filtration efficiency at

different particle sizes, airflow, estimated CADR, noise generated, number of fans and filters,

and unit cost in the remainder.

91 **Figure 1: comparison of CADR (estimated by airflow x filtration efficiency) and cost of**
92 **HEPA purifiers and DIY box fan-filters e.g., 3x2 means three filters were used with two**
93 **box fans**
94

Safety Notes: California Air Resource Board recommends never leaving box-fan air filters

unattended while turned on, and to use box fans manufactured after 2012 and are clearly

identified with the UL or ETL safety markings because it is likely they have a fused plug to

prevent electrical fires e.g. if the device is inadvertently knocked over.[10] Chemical Insights, a

subsidiary of Underwriters Laboratories, recently tested five different electric box fan models

(approximately 20" × 20" in size) with attached air filters and concluded that all measured

temperatures fell below the maximum acceptable thresholds defined by the market safety

standard for electric fans (UL 507).[11] In detail, in addition to assessing DIY fans with clean

MERV 13s, DIYs were tested with filters loaded with two types of particles (ASHRAE dust

and smoke from biomass burning to represent a loaded filter due to a wildfire), and test

scenarios also included fully sealing the box fans in plastic and running fans for over 7 hours

face-down on the floor. Even under those scenarios, the fans' surface components did not

reach temperatures that would cause minor burn/injury, and all fan models were able to

operate continuously throughout all test scenarios without reaching UL 507 thresholds. The

resources and information in this article (the "Content") are for informational purposes only

and should not be construed as professional advice. The Content is intended to complement,

not substitute, the advice of your doctor. You should seek independent professional advice

from a person who is licensed and/or qualified in the applicable area. No action should be

taken based upon any information contained in this article. Use of the article is at your own

risk. Patient Knowhow, Inc. takes no responsibility and assumes no liability for any Content

made available in this article.

Usage Notes: Commercially available HEPA-purifiers typically have "smart" settings. Based

on the presence of particulate matter in the air, they use a built-in sensor to automatically

adjust their fan speed. These built-in sensors are not typically triggered by the respiratory

aerosols that carry SARS-Cov-2 viruses. Although this maybe acceptable if you're concerned

only about smoke, if the goal is to reduce COVID-19 risk, fan speed settings for HEPA-

purifiers need to be set to operate at a constant speed to continuously filter the air regardless

of particular matter detected by the sensor, higher the better. A best practice for shared spaces

such as classrooms and offices where viral transmission is a primary concern is to run the

HEPA-purifier at its maximum fan speed or the highest fan speed tolerable to the occupants

of the room.

Methods

Traditional methods that measure the effect of the air purifier (and its CADR) using the decay

rate of aerosols generated or injected into an isolated, unoccupied room require greater

investment of time, effort, risk of inhalation of the generated aerosols, and training/expertise

compared to the much simpler DIY test methods described here.[78][79] We use ambient aerosols

to rapidly compare different filters, fans, and configurations with low-cost, measurement

tools available online (e.g. Amazon) also making these results easy to replicate and verify

with limited resources.

HEPA-purifiers. Three models evaluated include the Coway Airmega 300 ($549, 285 cfm),

Coway AP-1512HH ($229, 233 cfm), and Airthereal AHG550 ($233, 324 cfm). Unit prices

are as listed on Amazon and "smoke" clean air delivery rate (CADR) in units of cubic feet

per minute (cfm) is as listed on manufacturer website. The HEPA air purifiers were chosen to

be a selection of models known to be most quiet or well-reviewed. Note: "smoke" in this

context of manufacturer-reported CADR typically refers to tobacco smoke not wildfire

smoke. The tests for the HEPA air purifiers were conducted on November 11, 2021.

HVAC filters with box fan. For DIY configurations, the box fans used are 20" Lasko Fan

($20) along with 20" x 20" HVAC filters made by Nordic Pure of width and rating 1"

MERV-14 ($11), 2" MERV-13 ($15), 4" MERV-14 ($38), 4" MERV-15 ($42), by 3M of

width and rating 1" MERV 14 ($26), and by Lennox of width and rating 5" MERV-16 ($99).

MERV stands for minimum efficiency reporting values. The single and quad filter designs

pictured in Figure 2 use one fan, and the triple filter design uses two fans with one fan

replacing one of the filters. The square-shaped 20" box fans tend to pull in air from their front

at their corners of the box[80][81], and a cardboard shroud of 14" diameter was attached to the

output side (front) of each fan to enhance airflow through the filter by reducing flow

recirculation (via the corners of the front of the box fan) and eddies at the fan blade tips. For

comparison, three methods of attaching the box fan to the air filters included vacuum (i.e. no

attachment just relying on airflow), duct tape, and velcro. Unit prices are as listed on Home

Depot, Amazon, or Walmart. The tests for the HVAC filters with box fans (DIY air purifiers)

were conducted January 10 to 13, 2022.

Figure 2: Do-It-Yourself Box Fan and Filters (single, quad filter designs with one fan

and triple filter design with two fans). Blue arrows indicate direction of airflow

Aerosol filtration efficiency. For each HEPA-purifier or box fan filter, counts at each

particle size bin (0.3, 0.5, 0.7, 1.0, 2.5, 5, and 10 µm) were tested using an ISO-certified,

particle counter (Temtop Particle Counter PMD 331 available on Amazon) with the each

device (its fan) turned 'on' and 'off' consecutively. The tests were conducted in a house near

an open window with fan blowing air through the window to allow for aerosols (particles)

from outdoors to continuously enter the room. Five counts were recorded and averaged on the

particle counter when its input was placed directly at the output of the air purifier/filter for 30

seconds. The filtration efficiency[89] at each particle size was estimated by the formula,

efficiency = 1 - on / off. To compare each fan-filter configuration in this study, the filtration

efficiency depends only on the ratio of on to off, not on their absolute values. The five counts

were recorded individually over no more than 15 minutes, however the filtration efficiencies

were computed using consecutively recorded counts no more than 2 minutes apart.

Air flow. For each HEPA-purifier or DIY box fan filter, the airspeed was measured using an

anemometer (BTMETER BT-100 Handheld Anemometer available on Amazon) held at the

output perpendicular to the airflow. An average of three or more airspeed measurements (feet

per minute) were multiplied by area of output to estimate the airflow (cubic feet per minute).

Noise. Noise measurements were taken for each air purifier/filter using an iPhone app

maintained by National Institute for Occupational Safety and Health (NIOSH).[12] Three or

more noise measurements were taken at a 9" distance perpendicular to the direction of the

output airflow and averaged.

CADR (estimated). For each HEPA-purifier or DIY box fan filter, the Clean Air Delivery

Rate (CADR) was estimated as the product of the measured air flow (cfm) and aerosol

filtration efficiency (%) at 0.3 microns.

Results

Note: Measurements in each table below are shown as averages (standard deviation in

parentheses).

HEPA-purifiers. As shown in Table 1, the results for the HEPA-purifiers show particle

filtration efficiencies near or exceeding 95% at most particle sizes ranging from 0.3 to 10 μm

and higher in many cases. At their maximum fan speed, the noise generated by the Coway

Airmega 300 (59.3 ± 2.1 dBA) was roughly ~5 dBA lower than the the Coway AP 1512 (64.7

± 0.57 dBA) and Airthereal (66.3 ± 0.6 dBA). To achieve comparable noise levels to the

Coway Airmega 300, both the Coway AP-1512 and the Airthereal AGH550 had to be set at

fan speed 2 which cut their estimated airflow (CADR) roughly in half. As a verification of

the estimation methodology, the estimated CADR using airflow (cfm) and filtration

efficiency at 0.3 microns was within 10% of the the smoke CADR rating from the

manufacturer's website. Based on this data it also appears some HEPA air purifiers may have

higher or lower rate of filtration at 0.3 microns than others although well below the 99.97%

typically assumed for HEPA. These differences appear to reflect properties of the filters

themselves rather than sample size. In Table 1, the standard deviations for the filtration

efficiency at 0.3 microns are small even for five measurements (3.5% for Airthereal and less

than 1% for both of the Coway models). This suggests it is not simply a reflection of the

sample size of 5 measurements but rather a property of the filters themselves. There is even

an observable difference between the two Coway models as shown in Table 1.

Setup		Noise and Airflow			CADR (cfm)		Filtration Efficiency (%) avg of five measurements at each particle size bin (μm)						
	Price (est.)	Fan speed	Noise (dBA) avg. of three samples 9" away	Est. Airflow (output) cfm	From Manufacturer (smoke CADR)	Est. using airflow x filtration eff. @ 0.3 μm	0.3	0.5	0.7	1.0	2.5	5.0	10.0
Coway Airmega 300	$549	3	59.3 (2.1)	282 (61)	285	265	94.1 (0.9)	94.5 (1.1)	97.0 (0.96)	97.4 (0.92)	98.3 (1.5)	98.3 (1.8)	98.0 (1.6)
Coway AP-1512	$229	3	64.7 (0.57)	223 (3.7)	233	216	97.4 (0.3)	98.1 (0.4)	98.5 (0.6)	98.7 (0.8)	98.4 (1.7)	98.0 (3.0)	97.6 (5.5)
Coway AP-1512	$229	2	46.0 (3.5)	97 (5.7)		94							
Airthereal AGH550	$233	5	66.3 (0.6)	410 (81)	324	354	86.5 (3.5)	89.5 (0.9)	90.6 (2.1)	92.7 (1.9)	93.9 (3.2)	96.0 (2.4)	98.6 (2.1)
Airthereal AGH550	$233	2	47.3 (1.5)	206 (42)		178							

Table 1: Performance of HEPA-purifiers

Single filter configurations with box fan. The noise generated by the box fan was tolerable

(subjectively to the author, without it feeling stressful) only at fan speed #1 (out of three)

with a measured noise level of 54 dBA comparable to the Coway Airmega 300 at 59 dBA. As

shown in Table 2, the filtration efficiency of the MERV-13, 14, 15, or 16 filters at the most

penetrating particle size of 0.3 μm varied by thickness from approximately 60% to 85% with

highest observed for MERV-16 filter and lowest for the MERV 13 filter, well below the

HEPA filters. Even though MERV-13 filters may remove less than 80% of particles in just

one pass, if the air recirculates multiple times through filter the aerosol concentrations can be

rapidly reduced.[7] The filtration efficiency exceeded 90% in some cases at particle sizes above

1 μm.

For all filters, filtration efficiencies were measured at fan speed #3, but also at fan speed #1

for the 2" MERV 13 and 1" MERV 14 filters at which the filtration efficiencies were higher.

In general, that is expected to hold true with the other filters so the estimated CADR for each

filter at fan speed #1 (above) would be commensurately higher as well.

Table 2: Performance of single-filter configurations with a box fan

Setup					Noise and Airflow		CADR (cfm)	Filtration Efficiency (%) avg of five measurements at each particle size bin (μm)						
Filter Mfr.	Filter Type	Price (est.)	Seal	Fan speed	Noise (dBA) avg. of three samples 9" away	Est. Airflow (output) cfm	**Est. using airflow x filtration eff. @ 0.3 μm**	0.3	0.5	0.7	1.0	2.5	5.0	10.0
Lennox	5" MERV-16	$120	vacuum	3		759 (72)	645	85 (2.6)	86 (3.0)	85 (0.45)	86 (1.6)	86 (4.8)	86 (7.1)	82 (13)
Lennox	**5" MERV-16**	**$120**	**vacuum**	**1**		**476 (35)**	**405**							
Nordic Pure	4" MERV-15	$63	vacuum	3		782 (23)	516	66 (6.9)	70 (5.0)	81 (3.0)	85 (3.9)	87 (1.6)	90 (1.8)	90 (4.4

Brand	Filter	Cost	Attach	N										)
Nordic Pure	**4" MERV-15**	**$63**	**vacuum**	**1**		510 (44)	336							
Nordic Pure	4" MERV-14	$58	vacuum	3	62.7 (0.6)	740 (50)	488	66 (6.8)	69 (6.3)	80 (3.6)	86 (2.4)	92 (2.2)	92 (4.2)	92 (5.3)
Nordic Pure	4" MERV-14	$58	vacuum	2	60.0 (0.0)									
Nordic Pure	**4" MERV-14**	**$58**	**vacuum**	**1**	**54.0 (0.0)**	488 (48)	322							
Nordic Pure	2" MERV-13	$35	vacuum	3	62.0 (0.0)	664 (57)	392	59 (6.0)	60 (5.7)	68 (4.2)	69 (7.8)	70 (11)	71 (8.5)	70 (17)
Nordic Pure	2" MERV-13	$35	vacuum	2	58.3 (0.6)									
Nordic Pure	**2" MERV-13**	**$35**	**vacuum**	**1**	**52.3 (0.6)**	437 (53)	293	**67 (2.0)**	**69 (2.2)**	**74 (3.2)**	**77 (3.9)**	**78 (2.7)**	**78 (3.0)**	**79 (6.0)**
3M (Filtrete)	1" MERV-14	$46	vacuum	3		590 (60)	460	78 (1.4)	79 (1.3)	78 (0.9)	77 (1.4)	77 (4.0)	77 (6.2)	77 (6.7)
3M (Filtrete)	**1" MERV-14**	**$46**	**vacuum**	**1**		381 (51)	298							
Nordic Pure	1" MERV-14	$31	velcro	3	64 (2)	571 (36)	342	60 (1.1)	65 (1.3)	78 (1.5)	83 (1.6)	86 (1.7)	88 (1.4)	81 (6.0)
Nordic Pure	1" MERV-14	$31	velcro	2	60.3 (1.5)									
Nordic Pure	**1" MERV-14**	**$31**	**velcro**	**1**	**55.3 (3.2)**	381 (47)	244	64 (4.1)	67 (4.5)	74 (4.6)	77 (4.2)	78 (5.0)	81 (3.8)	77 (6.2)

Cube configurations with box fan(s). Using comparably rated filters and fan speeds, the quad filter design with one box fan (4x1), popularly known as the Corsi-Rosenthal box, showed significant improvement in airflow and filtration efficiency over single filters (Table 3). Whereas results from attaching the filters were similar with duct tape (to seal up any gaps) or velcro (leaving small airgaps), suggesting any leaks created by a loose fit may not make much difference. Notably, the filtration efficiency of the quad filter design was marginally better than the corresponding single filter design possibly due to lower pressure across the filters. The three extra filters in the CR box (4x1) increased airflow by less than 50% over

241 equivalently rated single filter configuration (1x1), whereas it took adding an extra fan and

242 two extra filters in the cube formation (3x2) to double the airflow and estimated CADR.

244 **Table 3: Performance of cube configurations (filters x fans: 4x1 and 3x2)**

Setup						Noise and Airflow		CADR (cfm)	Filtration Efficiency (%) avg of five measurements at each particle size bin (µm)						
Filter Mfr.	Filter Type	filters x fans	Price (est.)	Seal	Fan speed	Noise (dBA) avg. of three samples 9" away	Est. Airflow (output) cfm	Est. using airflow x filtration eff. @ 0.3 µm	0.3	0.5	0.7	1.0	2.5	5.0	10.0
n/a	No filter	0x1	$20	n/a	3		965 (30)	n/a	0%	0%	0%	0%	0%	0%	0%
n/a	No filter	0x1	$20	n/a	1		664 (24)	n/a							
Nordic Pure	2" MERV-13	4x1	$80	velcro	3		903 (36)	659	73 (2.0)	74 (2.1)	76 (4.0)	79 (4.5)	78 (5.1)	74 (8.4)	65 (17)
Nordic Pure	**2" MERV-13**	**4x1**	**$80**	**velcro**	**1**		**645 (27)**	**471**							
Nordic Pure	2" MERV-13	4x1	$80	tape	3		851 (66)	570	67 (3.4)	67 (3.3)	74 (3.5)	79 (3.4)	80 (6.8)	87 (2.5)	86 (6.4)
Nordic Pure	**2" MERV-13**	**4x1**	**$80**	**tape**	**1**		**543 (42)**	**364**							
Nordic Pure	2" MERV-13	3x2	$85	velcro	3		Fan #1: 748 (27) / Fan #2: 792 (35)	494 / 523	66 (3.0)	68 (2.8)	75 (2.6)	78 (2.4)	78 (5.3)	78 (7.3)	74 (10)
Nordic Pure	**2" MERV-13**	**3x2**	**$85**	**velcro**	**1**		**Fan #1: 524 (34) / Fan #2: 476 (29)**	**346 / 314**							
Nordic Pure	1" MERV-14	4x1	$64	tape	3		851 (66)	570	67 (3.4)	67 (3.3)	74 (3.5)	79 (3.4)	80 (6.8)	87 (2.5)	86 (6.4)
Nordic Pure	**1" MERV-**	**4x1**	**$64**	**tape**	**1**		**542 (42)**	**363**							

	14													
Nordic Pure	1" MERV-14	4x1	$64	velcro	3		858 (44)	609	71 (1.5)	75 (1.1)	86 (1.2)	89 (1.3)	89 (1.5)	90 (1.7)	86 (8.3)
Nordic Pure	**1" MERV-14**	**4x1**	**$64**	**velcro**	**1**		**546 (24)**	**388**						

Discussion

Accounting for lower filtration efficiency of MERV-13,14,16 filters at the most penetrating

particle size of 0.3 μm compared to HEPA, the estimated clean air delivery rate (CADR) of a

do-it-yourself (DIY) setup using 2" MERV-13 (67%), 4" MERV-14 (66%), 5" MERV 16

(85%) filters with a box fan running at fan speed 1 for tolerable noise was 293 cfm, 322 cfm,

405 cfm as shown in Figure 3. This is comparable or better than a best-in-class, low-noise

generating HEPA-purifier running at maximum speed with at 282 cfm. Yet the upfront cost

of the components of the DIY setup were approximately 5 to 10 times less ($35-$58-$120)

than best-in-class HEPA-purifiers ($549).

Figure 3: Estimated CADR (cfm) and filtration efficiency (%) for DIY Air Purifiers (filters x

fans) @ speed #1 e.g., 3x2 means three filters were used with 2 box fans

At least two studies have measured the CADR of cube configurations (popularly known as

the Corsi-Rosenthal box or CR box) by observing the decay rates of generated aerosols. The

first study is by UC-Davis[78] measured 600 cfm at lowest fan speed to 850 cfm at highest fan

speed. The second study is by Illinois Institute of Technology[79] (IIT), measured below 300

cfm in the range of 0.5 to 3 μm (dust) at the highest fan speed but above 450 cfm in the range

of 5-11 μm (pollen). Both used five 2" MERV-13 filters (instead of four in our study) of

similar dimensions so it is unclear why the studies by UC-Davis and IIT differ by a factor of

two. Our results were in between these two studies but more consistent with the UC-Davis

study. The estimated CADR of cube configurations with four 2" MERV 13 filters was 471

cfm at lowest fan speed 1 and 659 cfm at the highest fan speed 3 using 73% filtration

efficiency at 0.3 μm (most penetrating particle size). It is possible that greater filtration

efficiencies at larger particle sizes may account for this difference with UC-Davis results

which is based on generated salt aerosols. Other differences that may account for it are the

number of filters (4 vs 5), fans, differences in estimation methodology, box fans from

different manufacturers may differ substantially in terms of their flowrate at "free flow" (i.e.

without any pressure drops from filters) and when installed in DIY air cleaners with filters,

and differences in particles generated and measured at different aerodynamic particle sizes.

Further investigation would be required to fully understand why there is such a range.

However at all fan speeds the quad filter design, CR box, did not achieve gains in CADR of

more than 80% over a single filter design which is in contrast to the 200-250% gains also

reported by UC-Davis (also with shroud and 20" Lasko box fan),[13] separate from the UC-

Davis study in the prior paragraph. CR boxes are unlikely to exceed the airflow with no

filters. At fan speed 1, the airflow of quad 1" MERV 14 filter design (546 cfm) was within

25% of that with no filters (646 cfm), and the airflow of the single 1" MERV 14 (381 cfm)

was within 50% of no filters. This suggests the quad 1" design is close to optimal but cannot

be improved by a factor of 200% over the single 1" filter. At fan speed 1, the airflow with no

filter (646 cfm) was measured to be 70% more than the airflow with a single 1" filter (381

cfm), 47% more than 2" MERV-13 filter (437 cfm), and only 32% more than the 4" MERV-

14 filter (488 cfm). The cost and extra setup effort from the quad filters (CR box) can be

alternatively expended on more simply replicating a new box fan filter (+ 100% gain) so that

the airflow is then distributed to different locations in the room or classroom. To illustrate

this, replacing one of the 2" MERV-13 filters in the quad filter configuration with a second

fan resulted in gains of approximately 125%-150% in estimated CADR (at fan speeds 1 and

3) which is notably better than 100% possibly due to improved filtration efficiency.

Regardless, our results suggest a sweet spot between speed of setup, simplicity, size, and cost

is a single 20" box fan with 2" MERV-13 ($35), 4" MERV-14 filter ($58) of 20" length and

width. Single filter is easier and simpler to setup than multi-filter designs which is an

advantage for scaling up DIY approaches. A second box fan and single filter provide more air

cleaning than one CR box with the possibility of benefits for air cleaner placement.

Alternatively, if higher filtration efficiency is desired a 5" MERV-16 filter can be used

($120). Given the simplicity and low-cost of the box-fan design using single 2" or 4" MERV-

13/14 filters, form-factor improvements at a marginal cost may include a more stable,

cardboard box frame so it is not so easy to knock over with printed designs to make it

aesthetically pleasing. An aluminum screen fixed to the shroud in front of the fan can help

keep small objects (e.g. fingers or pencils) from contacting the fan blade which may be

especially important for classroom[70] and home applications when young children are present.

Limitations

Although SARS-Cov-2 is extremely small (approximately 100 nanometers in diameter[87]), it

may be exhaled in respiratory aerosols and droplets that are much larger (several hundreds of

nanometers to several microns). The research on which are the most common COVID

transmission modes (aerosol, droplet, or surfaces), and what is the most common aerosol

particle sizes by which it is transmitted continues to evolve as new variants emerge. Multiple

studies demonstrate SARS-CoV-2 in micron and submicron aerosols from the exhaled breath

of infected people.[1][2][3] In one study, more of the viable virus from human subjects was

observed in submicron respiratory aerosols than micron and above.[3] One potential limitation

is in extrapolating results from the ambient test aerosols used in this study to real-world

applications for removal aerosols relevant to SARS-Cov-2.

'Filtration efficiency and CADR results from DIY air cleaners highlight potential

performance differences between filters made by different manufacturers of comparably rated

MERV 13, 14, 15, 16 filters. Hence filter selection is critical to achieving the results desired.

There may also be variability in filter performance due to manufacturing defects or variations

among fans and filters from the same manufacturer. The long-term durability of filtration

efficiency and airflow of these filters after extended use with box fans is also uncharacterized

unlike HEPA-purifiers which have well-understood operational history.

Since measurements of particle concentration were made by placing the inlet of the particle

counter towards the outlet of the air purifier, there could be some re-entrainment in the

shearing flow leaving the air cleaners that differs as a function of the design of each air

cleaner which may impact the measurements.

The aerosol measurements were conducted with a device which is an optical particle counter

(OPC) called the PMD 311 manufactured by Temtop. The OPC counts particles in 7 bins

(0.3, 0.5, 0.7, 1.0, 2.5, 5, and 10 microns). Possible sources of uncertainty in an OPC based

are extremes of relative humidity and differences between optical properties of the aerosol

particles measured in this study versus those particles used to calibrate the sensor by the

manufacturer.[82] Extreme relative humidity appears unlikely to be a source uncertainty based

on the environmental conditions under which this study was conducted. However, the

manufacturer used polystyrene aerosols to calibrate the sensor of the measurement device

within 10% at each particle size. The choice of polystyrene material may have some

systematic impact on the accuracy of the absolute counts when measuring aerosols made of

other materials. The principle of operation of the OPC is it uses a sensor which measures

laser light scattered from each particle to estimate its size, with larger (smaller) particles

having a greater (lower) scattering cross section which is used to differentiate the size of each

particle counted. As shown in Figure 3 of Hagan et, al.,[82] somewhat surprisingly the

scattering cross section of black carbon is higher (or lower) than polystyrene depending on

whether particle size is smaller (or larger) than a threshold which is approximately 0.3

microns. If some fraction of the particles that are part of the ambient aerosols measured in our

study were much more (or much less) absorptive than polystyrene in a particle-size

dependent manner, such as black carbon, it is possible these particles could have a lower (or

higher) scattering cross section than the calibration aerosol of same size, respectively. If so

they could be counted as part of smaller (or larger) bins than their actual size. The

measurements of the OPC in each bin will vary to some extent based on the distribution of

absorptive and scattering properties of ambient aerosols relative to the polystyrene aerosol

used to calibrate the OPC. However, any such systematic differences between the ambient

aerosols and the calibration aerosols might be expected to apply uniformly to both the 'in'

and 'out' measurements and therefore would not necessarily affect the computed filtration

efficiency for the particles actually counted (measured) in each bin by the OPC, just that their

size distribution might be shifted over by one or more bins based on how each particle's

individual optical properties differs from the calibration aerosol.

For each HEPA-purifier or DIY box fan filter, the Clean Air Delivery Rate (CADR) was

estimated as the product of the measured air flow (cfm) and aerosol filtration efficiency (%)

at 0.3 microns. Strictly speaking, the CADR estimate would apply to the particles that are

counted by the measurement device in the 0.3 micron bin of the Temtop PMD 331 subject to

the differences described between calibration and ambient aerosols in the prior paragraph,

and therefore may not apply for other particle sizes. The three tested HEPA purifiers are not

representative of all HEPA purifiers and likewise tested DIY configurations are not

representative of all DIY configurations in terms of cost, noise generation, CADR, etc..

Conclusions

Given the fact that the SARS-CoV-2 pandemic is largely sustained by superspreading events,

there are opportunities to use air cleaning principles to improve the indoor air environments

where these superspreading events occur and if applied widely enough to potentially control

the pandemic. To date there is no large-scale, real-world data to validate a minimum

threshold of ACH to control SARS-Cov-2 transmission in a room. The SARS-CoV-2

pandemic is sustained largely by superspreading events: approximately 80% of cases are

transmitted by only 10% to 20% of the infected (super spreaders).[1,14,15] Unlike healthcare

facilities where there are minimum specifications[54] for ventilation and air filtration in many

cases exceeding 15 air exchange per hour (ACH), in community settings[55] and schools[56] the

CDC (US) recommends increasing air filtration "as high as possible." Specific targets for

ACH in community settings are needed.

Best practices recommended by the state of California in the US are only 4 to 6 air exchanges

per hour (ACH),[58] and 6 to 12 ACH in classrooms.[90] As an illustrative example, the

University of San Diego publicly posts its ACH levels for classrooms, with almost all

classrooms exceeding 6 ACH and many exceeding 12 ACH.[93] A UK study[85] in a hospital

setting measured reduced viral load of indoor air in rooms with Covid positive subjects when

air is filtered less than 4.5 ACH versus faster than 9 ACH (Figure 5c of that study). Another

study[92] in a hospital recorded (super) spreading of SARS-CoV-2 in general wards with 6

ACH but also noted the virus was undetectable in the air of airborne isolation rooms at 12

ACH (See the Discussion section of that study). A recent study from Italy suggests infection

rates were cut by 80% in classrooms that implemented mechanical ventilation of 6 ACH,

suggesting perhaps even 6 ACH may be insufficient to control the spread.[84 87] For

comparison, CDC recommends an airborne isolation room in a hospital to have a minimum

of 12 ACH.[54]

Fundamentally, the rate of aerosol (particulate) removal by air filters (HEPA, DIY, etc.) in a

room as measured by clean air delivery rate (CADR) must exceed the rate of introduction of

these aerosols by a significant margin in order to avoid accumulation of aerosols and achieve

rapid clearance (e.g. when introduced by an infected person or smoky source). Outdoor

ventilation is generally complementary or beneficial to indoor air filtration (in terms of ACH)

except on days when the outdoor air is polluted with wildfire or smoky particulates (e.g. PM

2.5) in which case outdoor air ventilation would introduce additional aerosol further

increasing the need for indoor air filtration. Experts at Boston School of Public Health[57] and

the California Department of Public Health[58] recommend 4 to 6 ACH in community settings

to prevent COVID-19. Researchers measuring traces of the SARS-CoV2 coronavirus in the

air of a COVID-19 ward of a UK hospital reported they were undetectable once air filtration

machines filtered the air in each room every 6 to 12 minutes (5-10 ACH).[73] Although very

effective at removing the virus from the air, achieving these higher ACH targets often incur

noise generation intolerable to end-users or may be unaffordable or both. Cost and excessive

noise are key factors that limit the use of portable air cleaners.[59 60]

Indoor air cleaning and filtration can also be potentially useful mitigation (to reduce

inhalation dose by some amount) in response to other airborne viruses (e.g. respiratory RNA

viruses[76]) or release of bioterrorism or biowarfare agents such as anthrax[77 86] However, these

can be unaffordable to much of the US and world population.

421
As we discovered in the test results, lower-efficiency air filtration by combining off-the-shelf

components (box fans with heating, ventilation and cooling or HVAC filters) in tested DIY

configurations compares favorably in performance (clean air delivery rate, noise) to the tested

HEPA air purifiers but at approximately five to ten times lower cost, and can be an

affordable, complementary option for rapid aerosol removal indoors in homes, clinics,

schools, offices, and other public venues.

References

1. Coleman KK, Tay DJW, Sen Tan K, Ong SWX, Son TT, Koh MH, Chin YQ, Nasir H,

Mak TM, Chu JJH, Milton DK, Chow VTK, Tambyah PA, Chen M, Wai TK. Viral Load of

SARS-CoV-2 in Respiratory Aerosols Emitted by COVID-19 Patients while Breathing,

Talking, and Singing. Clin Infect Dis. 2021 Aug 6:ciab691. doi: 10.1093/cid/ciab691. Epub

ahead of print. PMID: 34358292; PMCID: PMC8436389.

2. Adenaiye OO, Lai J, de Mesquita PJB, Hong F, Youssefi S, German J, Tai SS, Albert B,

Schanz M, Weston S, Hang J, Fung C, Chung HK, Coleman KK, Sapoval N, Treangen T,

Berry IM, Mullins K, Frieman M, Ma T, Milton DK; University of Maryland StopCOVID

Research Group. Infectious SARS-CoV-2 in Exhaled Aerosols and Efficacy of Masks During

Early Mild Infection. Clin Infect Dis. 2021 Sep 14:ciab797. doi: 10.1093/cid/ciab797. Epub

ahead of print. PMID: 34519774; PMCID: PMC8522431.

3. Santarpia JL, Herrera VL, Rivera DN, Ratnesar-Shumate S, Reid SP, Ackerman DN,

Denton PW, Martens JWS, Fang Y, Conoan N, Callahan MV, Lawler JV, Brett-Major DM,

Lowe JJ. The size and culturability of patient-generated SARS-CoV-2 aerosol. J Expo Sci

Environ Epidemiol. 2021 Aug 18:1–6. doi: 10.1038/s41370-021-00376-8. Epub ahead of

print. PMID: 34408261; PMCID: PMC8372686.

4. Scientific Brief: SARS-CoV-2 Transmission. Centers for Disease Control and Prevention.

May 7, 2021. https://www.cdc.gov/coronavirus/2019-ncov/science/science-briefs/sars-cov-2-

transmission.html

5. Patient Knowhow, "AIR PURIFIERS (HEPA FILTERS) FOR YOUR CLASSROOM,

OFFICE, OR HOME" https://www.patientknowhow.com/hepacalculator.html

6. https://www.hsph.harvard.edu/news/hsph-in-the-news/experts-offer-advice-on-air-

purifiers-for-classrooms/

7. May, N.W., Dixon, C., Jaffe, D.A. (2021). Impact of Wildfire Smoke Events on Indoor Air

Quality and Evaluation of a Low-cost Filtration Method. Aerosol Air Qual. Res. 21, 210046.

https://doi.org/10.4209/aaqr.210046

8. Ford Media Center, May 12, 2021. "FORD DIY AIR FILTRATION KIT THAT

REDUCES COVID-19 IN THE AIR VALIDATED BY PEER-REVIEWED SCIENTIFIC

RESEARCH JOURNAL"

https://media.ford.com/content/fordmedia/fna/us/en/news/2021/05/12/ford-diy-air-filtration-

kit-covid-19-validated.html

9. Ruichen He, Wanjiao Liu, John Elson, Rainer Vogt, Clay Maranville, and Jiarong Hong,

"Airborne transmission of COVID-19 and mitigation using box fan air cleaners in a poorly

ventilated classroom", Physics of Fluids 33, 057107 (2021)

https://doi.org/10.1063/5.0050058

10. California Air Resources Board. "Protecting Yourself from Wildfire Smoke"

https://ww2.arb.ca.gov/protecting-yourself-wildfire-smoke

11. Aika Davis, Marilyn Black. Chemical Insights. An Evaluation of DIY Air Filtration.

https://chemicalinsights.org/wp-content/uploads/DIY-Box-Fan-Report-2021.pdf

12. The National Institute for Occupational Safety and Health (NIOSH). "NIOSH Sound

Level Meter App" https://www.cdc.gov/niosh/topics/noise/app.html

13. UC-Davis Western Cooling Eciency Center. August, 2021. "TESTING DIFFERENT

CONFIGURATIONS OF DO-IT-YOURSELF PORTABLE AIR CLEANERS"

https://energy.ucdavis.edu/wp-content/uploads/Case-Study_DIY-Portable-Air-Cleaners-

083121.pdf

14. Chen PZ, Koopmans M, Fisman DN, Gu FX. Understanding why superspreading drives

the COVID-19 pandemic but not the H1N1 pandemic. Lancet Infect Dis. 2021

Sep;21(9):1203-1204. doi: 10.1016/S1473-3099(21)00406-0. Epub 2021 Aug 2. PMID:

34352224; PMCID: PMC8328407.

15. Sun K, Wang W, Gao L, Wang Y, Luo K, Ren L, Zhan Z, Chen X, Zhao S, Huang Y, Sun

Q, Liu Z, Litvinova M, Vespignani A, Ajelli M, Viboud C, Yu H. Transmission

heterogeneities, kinetics, and controllability of SARS-CoV-2. Science. 2021 Jan

15;371(6526):eabe2424. doi: 10.1126/science.abe2424. Epub 2020 Nov 24. PMID:

33234698; PMCID: PMC7857413.

16. Osterholm MT, Moore KA, Kelley NS, Brosseau LM, Wong G, Murphy FA, Peters CJ,

LeDuc JW, Russell PK, Van Herp M, Kapetshi J, Muyembe JJ, Ilunga BK, Strong JE, Grolla

A, Wolz A, Kargbo B, Kargbo DK, Sanders DA, Kobinger GP. Transmission of Ebola

viruses: what we know and what we do not know. mBio. 2015 Feb 19;6(2):e00137. doi:

10.1128/mBio.00137-15. Erratum in: MBio. 2015;6(4):e01154. Formenty, Pierre [Deleted].

PMID: 25698835; PMCID: PMC4358015.

17. "How does #COVID19 spread? What are some modes of transmission? What can you do

to protect yourself? @DrMikeRyan explains."

https://twitter.com/WHO/status/1473387274159149063

18. "Coronavirus disease (COVID-19): How is it transmitted?" https://www.who.int/news-

room/questions-and-answers/item/coronavirus-disease-covid-19-how-is-it-transmitted

19. Lee EC, Wada NI, Grabowski MK, Gurley ES, Lessler J. The engines of SARS-CoV-2

spread. Science. 2020 Oct 23;370(6515):406-407. doi: 10.1126/science.abd8755. PMID:

33093098.

20. Greenhalgh T, Jimenez JL, Prather KA, Tufekci Z, Fisman D, Schooley R. Ten scientific

reasons in support of airborne transmission of SARS-CoV-2. Lancet. 2021 May

1;397(10285):1603-1605. doi: 10.1016/S0140-6736(21)00869-2. Epub 2021 Apr 15. Erratum

in: Lancet. 2021 May 15;397(10287):1808. PMID: 33865497; PMCID: PMC8049599.

21. Robert T Schooley, Ferric C Fang, Reply to Meyerowitz and Richterman, Clinical

Infectious Diseases, Volume 73, Issue 7, 1 October 2021, Pages 1319–1320, https://doi-

org.eres.qnl.qa/10.1093/cid/ciab017

22. Escandón, K., Rasmussen, A.L., Bogoch, I.I. et al. COVID-19 false dichotomies and a

comprehensive review of the evidence regarding public health, COVID-19 symptomatology,

SARS-CoV-2 transmission, mask wearing, and reinfection. BMC Infect Dis 21, 710 (2021).

https://doi.org/10.1186/s12879-021-06357-4

23. Zhou, L., Ayeh, S.K., Chidambaram, V. et al. Modes of transmission of SARS-CoV-2

and evidence for preventive behavioral interventions. BMC Infect Dis 21, 496 (2021).

https://doi.org/10.1186/s12879-021-06222-4

24. Centers for Disease Control and Prevention. SARS-CoV-2 and Surface (Fomite)

Transmission for Indoor Community Environments. https://www.cdc.gov/coronavirus/2019-

ncov/more/science-and-research/surface-transmission.html

25. California Division of Occupational Safety and Health (Cal-OSHA). COVID-19

Prevention. https://www.dir.ca.gov/title8/3205.html

26. US Department of Labor Occupational Safety and Health Administration (OSHA).

COVID-19 Vaccination and Testing; Emergency Temporary Standard.

https://www.osha.gov/coronavirus/ets2

27. Swadi T, Geoghegan JL, Devine T, McElnay C, Sherwood J, Shoemack P, Ren X, Storey

M, Jefferies S, Smit E, Hadfield J, Kenny A, Jelley L, Sporle A, McNeill A, Reynolds GE,

Mouldey K, Lowe L, Sonder G, Drummond AJ, Huang S, Welch D, Holmes EC, French N,

Simpson CR, de Ligt J. Genomic Evidence of In-Flight Transmission of SARS-CoV-2

Despite Predeparture Testing. Emerg Infect Dis. 2021 Mar;27(3):687-693. doi:

10.3201/eid2703.204714. Epub 2021 Jan 5. PMID: 33400642; PMCID: PMC7920679.

28. Khanh NC, Thai PQ, Quach HL, Thi NH, Dinh PC, Duong TN, Mai LTQ, Nghia ND, Tu

TA, Quang N, Quang TD, Nguyen TT, Vogt F, Anh DD. Transmission of SARS-CoV 2

During Long-Haul Flight. Emerg Infect Dis. 2020 Nov;26(11):2617-2624. doi:

10.3201/eid2611.203299. Epub 2020 Sep 18. PMID: 32946369; PMCID: PMC7588538.

29. Speake H, Phillips A, Chong T, Sikazwe C, Levy A, Lang J, Scalley B, Speers DJ, Smith

DW, Effler P, McEvoy SP. Flight-Associated Transmission of Severe Acute Respiratory

Syndrome Coronavirus 2 Corroborated by Whole-Genome Sequencing. Emerg Infect Dis.

2020 Dec;26(12):2872-2880. doi: 10.3201/eid2612.203910. Epub 2020 Sep 29. PMID:

32990563; PMCID: PMC7706937.

30. Nir-Paz R, Grotto I, Strolov I, Salmon A, Mandelboim M, Mendelson E, Regev-Yochay

G. Absence of in-flight transmission of SARS-CoV-2 likely due to use of face masks on

board. J Travel Med. 2020 Dec 23;27(8):taaa117. doi: 10.1093/jtm/taaa117. PMID:

32662832; PMCID: PMC7454758.

31. Freedman DO, Wilder-Smith A. In-flight transmission of SARS-CoV-2: a review of the

attack rates and available data on the efficacy of face masks. J Travel Med. 2020 Dec

23;27(8):taaa178. doi: 10.1093/jtm/taaa178. PMID: 32975554; PMCID: PMC7543400.

32. Eric A Meyerowitz, Aaron Richterman, A Defense of the Classical Model of

Transmission of Respiratory Pathogens, Clinical Infectious Diseases, Volume 73, Issue 7, 1

October 2021, Page 1318, https://doi.org/10.1093/cid/ciab016

33. Bielecki M, Patel D, Hinkelbein J, Komorowski M, Kester J, Ebrahim S, Rodriguez-

Morales AJ, Memish ZA, Schlagenhauf P. Air travel and COVID-19 prevention in the

pandemic and peri-pandemic period: A narrative review. Travel Med Infect Dis. 2021 Jan-

Feb;39:101915. doi: 10.1016/j.tmaid.2020.101915. Epub 2020 Nov 10. PMID: 33186687;

PMCID: PMC7655026.

34. Kelly D, Bambury N, Boland M. In-flight transmission of wild-type SARS-CoV-2 and

the outbreak potential of imported clusters of COVID-19: a review of published evidence.

Global Health. 2021 Aug 21;17(1):93. doi: 10.1186/s12992-021-00749-6. PMID: 34419084;

PMCID: PMC8379567.

35. Blomquist PB, Bolt H, Packer S, Schaefer U, Platt S, Dabrera G, Gobin M, Oliver I. Risk

of symptomatic COVID-19 due to aircraft transmission: a retrospective cohort study of

contact-traced flights during England's containment phase. Influenza Other Respir Viruses.

2021 May;15(3):336-344. doi: 10.1111/irv.12846. Epub 2021 Mar 1. PMID: 33650201;

PMCID: PMC8013760.

36. Murphy N, Boland M, Bambury N, Fitzgerald M, Comerford L, Dever N, O'Sullivan MB,

Petty-Saphon N, Kiernan R, Jensen M, O'Connor L. A large national outbreak of COVID-19

linked to air travel, Ireland, summer 2020. Euro Surveill. 2020 Oct;25(42):2001624. doi:

10.2807/1560-7917.ES.2020.25.42.2001624. PMID: 33094715; PMCID: PMC7651877.

37. Toyokawa T, Shimada T, Hayamizu T, Sekizuka T, Zukeyama Y, Yasuda M, Nakamura

Y, Okano S, Kudaka J, Kakita T, Kuroda M, Nakasone T. Transmission of SARS-CoV-2

during a 2-h domestic flight to Okinawa, Japan, March 2020. Influenza Other Respir Viruses.

2021 Oct 3. doi: 10.1111/irv.12913. Epub ahead of print. PMID: 34605181.

38. Eichler N, Thornley C, Swadi T, Devine T, McElnay C, Sherwood J, Brunton C,

Williamson F, Freeman J, Berger S, Ren X, Storey M, de Ligt J, Geoghegan JL.

Transmission of Severe Acute Respiratory Syndrome Coronavirus 2 during Border

Quarantine and Air Travel, New Zealand (Aotearoa). Emerg Infect Dis. 2021

May;27(5):1274-1278. doi: 10.3201/eid2705.210514. Epub 2021 Mar 18. PMID: 33734063;

PMCID: PMC8084504.

39. Klompas M, Baker MA, Griesbach D, Tucker R, Gallagher GR, Lang AS, Fink T,

Cumming M, Smole S, Madoff LC, Rhee C. Transmission of Severe Acute Respiratory

Syndrome Coronavirus 2 (SARS-CoV-2) From Asymptomatic and Presymptomatic

Individuals in Healthcare Settings Despite Medical Masks and Eye Protection. Clin Infect

Dis. 2021 Nov 2;73(9):1693-1695. doi: 10.1093/cid/ciab218. PMID: 33704451; PMCID:

PMC7989527.

40. John Paul Tasker. COVID-19 transmission on flights 'extremely rare,' Dr. Tam says. CBC

News. Nov 10, 2020. https://www.cbc.ca/news/politics/covid-transmission-flights-extremely-

rare-1.5797065

41. Harvard University. Assessment of Risks of SARS-CoV-2 Transmission During Air

Travel and Non-Pharmaceutical Interventions to Reduce Risk: Phase One Report: Gate-to-

Gate Travel Onboard Aircraft. 2020-10-27. https://cdn1.sph.harvard.edu/wp-

content/uploads/sites/2443/2020/10/HSPH-APHI-Phase-I-Report.pdf

42. Air Traffic By The Numbers. Federal Avaiation Administration.

https://www.faa.gov/air_traffic/by_the_numbers/

43. Edwards DA, Ausiello D, Salzman J, Devlin T, Langer R, Beddingfield BJ, Fears AC,

Doyle-Meyers LA, Redmann RK, Killeen SZ, Maness NJ, Roy CJ. Exhaled aerosol increases

with COVID-19 infection, age, and obesity. Proc Natl Acad Sci U S A. 2021 Feb

23;118(8):e2021830118. doi: 10.1073/pnas.2021830118. Erratum in: Proc Natl Acad Sci U S

A. 2021 Jul 6;118(27): PMID: 33563754; PMCID: PMC7923364.

44. Choi EM, Chu DKW, Cheng PKC, Tsang DNC, Peiris M, Bausch DG, Poon LLM,

Watson-Jones D. In-Flight Transmission of SARS-CoV-2. Emerg Infect Dis. 2020

Nov;26(11):2713-2716. doi: 10.3201/eid2611.203254. Epub 2020 Sep 18. PMID: 32946370;

PMCID: PMC7588512.

45. Dhanasekaran V, Edwards KM, Xie R, Gu H, Adam DC, Chang LDJ, Cheuk SSY,

Gurung S, Krishnan P, Ng DYM, Liu GYZ, Wan CKC, Cheng SSM, Tsang DNC, Cowling

BJ, Peiris M, Poon LLM. Air travel-related outbreak of multiple SARS-CoV-2 variants. J

Travel Med. 2021 Sep 20:taab149. doi: 10.1093/jtm/taab149. Epub ahead of print. PMID:

34542623.

46. Warish Ahmed, Aaron Bivins, Stuart L. Simpson, Paul M. Bertsch, John Ehret, Ian

Hosegood, Suzanne Metcalfe, Wendy J.M. Smith, Kevin V. Thomas, Josh Tynan, Jochen F.

Mueller, Wastewater surveillance demonstrates high predictive value for COVID-19

infection on board repatriation flights to Australia, Environment International, 2021, 106938,

ISSN 0160-4120, https://doi.org/10.1016/j.envint.2021.106938.

47. Elliott P, Haw D, Wang H, et al; COVID-19 Genomics UK (COG-UK) Consortium11.

Exponential growth, high prevalence of SARS-CoV-2, and vaccine effectiveness associated

with the Delta variant.   Science. 2021;eabl9551. Published online November 2, 2021.

doi:10.1126/science.abl9551

48. El Sahly HM, Baden LR, Essink B, et al; COVE Study Group. Efficacy of the mRNA-

1273 SARS-CoV-2 vaccine at completion of blinded phase.   N Engl J Med. Published online

September 22, 2021. doi:10.1056/NEJMoa2113017

49. Dietrich WL, Bennett JS, Jones BW, Hosni MH. Laboratory Modeling of SARS-CoV-2

Exposure Reduction Through Physically Distanced Seating in Aircraft Cabins Using

Bacteriophage Aerosol - November 2020. MMWR Morb Mortal Wkly Rep. 2021 Apr

23;70(16):595-599. doi: 10.15585/mmwr.mm7016e1. PMID: 33886531; PMCID:

PMC8061797.

50. Hertzberg VS, Weiss H, Elon L, Si W, Norris SL; FlyHealthy Research Team. Behaviors,

movements, and transmission of droplet-mediated respiratory diseases during

transcontinental airline flights. Proc Natl Acad Sci U S A. 2018 Apr 3;115(14):3623-3627.

doi: 10.1073/pnas.1711611115. Epub 2018 Mar 19. PMID: 29555754; PMCID:

PMC5889623.

51. Mossong J, Hens N, Jit M, Beutels P, Auranen K, Mikolajczyk R, Massari M, Salmaso S,

Tomba GS, Wallinga J, Heijne J, Sadkowska-Todys M, Rosinska M, Edmunds WJ. Social

contacts and mixing patterns relevant to the spread of infectious diseases. PLoS Med. 2008

Mar 25;5(3):e74. doi: 10.1371/journal.pmed.0050074. PMID: 18366252; PMCID:

PMC2270306.

52. Leung K, Jit M, Lau EHY, Wu JT. Social contact patterns relevant to the spread of

respiratory infectious diseases in Hong Kong. Sci Rep. 2017 Aug 11;7(1):7974. doi:

10.1038/s41598-017-08241-1. PMID: 28801623; PMCID: PMC5554254.

53. Bhuvan KC, Shrestha R, Leggat PA, Ravi Shankar P, Shrestha S. Safety of air travel

during the ongoing COVID-19 pandemic. Travel Med Infect Dis. 2021 Sep-Oct;43:102103.

doi: 10.1016/j.tmaid.2021.102103. Epub 2021 Jun 7. PMID: 34111566; PMCID:

PMC8180446.

54. Centers for Disease Control and Prevention. Infection Control Guidelines for

Environmental Infection Control in Health-Care Facilities (2003): Ventilation Specifications

for Health-Care Facilities.

https://www.cdc.gov/infectioncontrol/guidelines/environmental/appendix/air.html

55. Ventilation in Buildings. Centers for Disease Control and Prevention. June 2, 2021.

https://www.cdc.gov/coronavirus/2019-ncov/community/ventilation.html

56. Centers for Disease Control and Prevention. "Ventilation in Schools and Childcare

Programs" https://www.cdc.gov/coronavirus/2019-ncov/community/schools-

childcare/ventilation.html

57. Allen JG, Ibrahim AM. Indoor Air Changes and Potential Implications for SARS-CoV-2

Transmission. JAMA. 2021;325(20):2112–2113. doi:10.1001/jama.2021.5053

58. Tomas Aragon, California Department of Public Health, "Interim Guidance for

Ventilation, Filtration, and Air Quality in Indoor Environments"

https://www.cdph.ca.gov/Programs/CID/DCDC/Pages/COVID-19/Interim-Guidance-for-

Ventilation-Filtration-and-Air-Quality-in-Indoor-Environments.aspx

59. Duill FF, Schulz F, Jain A, Krieger L, van Wachem B, Beyrau F. The Impact of Large

Mobile Air Purifiers on Aerosol Concentration in Classrooms and the Reduction of Airborne

Transmission of SARS-CoV-2. Int J Environ Res Public Health. 2021 Nov 2;18(21):11523.

doi: 10.3390/ijerph182111523. PMID: 34770037.

60. Bluyssen PM, Ortiz M, Zhang D. The effect of a mobile HEPA filter system on

'infectious' aerosols, sound and air velocity in the SenseLab. Build Environ. 2021 Jan

15;188:107475. doi: 10.1016/j.buildenv.2020.107475. Epub 2020 Dec 3. PMID: 33293755;

PMCID: PMC7711180.

61. Bae SH, Shin H, Koo HY, Lee SW, Yang JM, Yon DK. Asymptomatic Transmission of

SARS-CoV-2 on Evacuation Flight. Emerg Infect Dis. 2020 Nov;26(11):2705-2708. doi:

10.3201/eid2611.203353. Epub 2020 Aug 21. PMID: 32822289; PMCID: PMC7588520.

62. Abraar Karan, Ranu Dhillon and Devabhaktuni Srikrishna. America needs better masks to

fight Covid-19. CNN Opinion. February 1, 2021.

https://www.cnn.com/2021/01/29/opinions/covid-19-n95-masks-availability-karan-dhillon-

srikrishna/index.html

63. David Ignatius. Transcript: Coronavirus: Leadership During Crisis with Anthony S.

Fauci. Washington Post Live. February 2, 2021.

https://www.washingtonpost.com/washington-post-live/2021/02/02/transcript-coronavirus-

leadership-during-crisis-with-anthony-s-fauci/

64. Arumuru V, Samantaray SS, Pasa J. Double masking protection vs. comfort-A

quantitative assessment. Phys Fluids (1994). 2021 Jul;33(7):077120. doi: 10.1063/5.0058571.

Epub 2021 Jul 21. PMID: 34335010; PMCID: PMC8320463.

65. Sickbert-Bennett EE, Samet JM, Clapp PW, Chen H, Berntsen J, Zeman KL, Tong H,

Weber DJ, Bennett WD. Filtration Efficiency of Hospital Face Mask Alternatives Available

for Use During the COVID-19 Pandemic. JAMA Intern Med. 2020 Dec 1;180(12):1607-

1612. doi: 10.1001/jamainternmed.2020.4221. PMID: 32780113; PMCID: PMC7420816.

66. Brosseau LM. Fit testing respirators for public health medical emergencies. J Occup

Environ Hyg. 2010 Nov;7(11):628-32. doi: 10.1080/15459624.2010.514782. PMID:

20853203.

67. Steinle S, Sleeuwenhoek A, Mueller W, Horwell CJ, Apsley A, Davis A, Cherrie JW,

Galea KS. The effectiveness of respiratory protection worn by communities to protect from

volcanic ash inhalation. Part II: Total inward leakage tests. Int J Hyg Environ Health. 2018

Jul;221(6):977-984. doi: 10.1016/j.ijheh.2018.03.011. Epub 2018 Mar 28. PMID: 29861400.

68. McMahon K, Jeanmonod D, Check R, Rivard L, Balakrishnan V, Kelly B, Pester J,

Jeanmonod R. The pragmatic use of industrial elastomeric facemasks in health care practice

during the COVID-19 pandemic. Am J Emerg Med. 2021 Oct;48:273-275. doi:

10.1016/j.ajem.2021.05.025. Epub 2021 May 13. PMID: 34022633; PMCID: PMC8116120.

69. Prince SE, Chen H, Tong H, Berntsen J, Masood S, Zeman KL, Clapp PW, Bennett WD,

Samet JM. Assessing the effect of beard hair lengths on face masks used as personal

protective equipment during the COVID-19 pandemic. J Expo Sci Environ Epidemiol. 2021

Nov;31(6):953-960. doi: 10.1038/s41370-021-00337-1. Epub 2021 May 18. PMID:

34006963; PMCID: PMC8130778.

70. Lam-Hine T, McCurdy SA, Santora L, Duncan L, Corbett-Detig R, Kapusinszky B,

Willis M. Outbreak Associated with SARS-CoV-2 B.1.617.2 (Delta) Variant in an

Elementary School - Marin County, California, May-June 2021. MMWR Morb Mortal Wkly

Rep. 2021 Sep 3;70(35):1214-1219. doi: 10.15585/mmwr.mm7035e2. PMID: 34473683;

PMCID: PMC8422870.

71. Dancer SJ, Bluyssen PM, Li Y, Tang JW. Why don't we just open the windows? BMJ.

2021 Nov 26;375:n2895. doi: 10.1136/bmj.n2895. PMID: 34836876.

72. Natasha Khan. Covid-19 Case Cluster Linked to One Flight Stirs Debate Among Health

Experts. Wall Street Journal. April 24, 2021.

73. Andrew Conway Morris, Katherine Sharrocks, Rachel Bousfield, Leanne Kermack,

Mailis Maes, Ellen Higginson, Sally Forrest, Joana Pereira-Dias, Claire Cormie, Tim Old,

Sophie Brooks, Islam Hamed, Alicia Koenig, Andrew Turner, Paul White, R Andres Floto,

Gordon Dougan, Effrossyni Gkrania-Klotsas, Theodore Gouliouris, Stephen Baker, Vilas

Navapurkar, The Removal of Airborne Severe Acute Respiratory Syndrome Coronavirus 2

(SARS-CoV-2) and Other Microbial Bioaerosols by Air Filtration on Coronavirus Disease

2019 (COVID-19) Surge Units, Clinical Infectious Diseases, 2021;, ciab933,

https://doi.org/10.1093/cid/ciab933

74. Brandal Lin T., MacDonald Emily, Veneti Lamprini, Ravlo Tine, Lange Heidi, Naseer

Umaer, Feruglio Siri, Bragstad Karoline, Hungnes Olav, Ødeskaug Liz E., Hagen Frode,

Hanch-Hansen Kristian E., Lind Andreas, Watle Sara Viksmoen, Taxt Arne M., Johansen

Mia, Vold Line, Aavitsland Preben, Nygård Karin, Madslien Elisabeth H.. Outbreak caused

by the SARS-CoV-2 Omicron variant in Norway, November to December 2021. Euro

Surveill. 2021;26(50):pii=2101147. https://doi.org/10.2807/1560-

7917.ES.2021.26.50.2101147

75. Gu H, Krishnan P, Ng DYM, Chang LDJ, Liu GYZ, Cheng SSM, Hui MMY, Fan MCY,

Wan JHL, Lau LHK, Cowling BJ, Peiris M, Poon LLM. Probable Transmission of SARS-

CoV-2 Omicron Variant in Quarantine Hotel, Hong Kong, China, November 2021. Emerg

Infect Dis. 2021 Dec 3;28(2). doi: 10.3201/eid2802.212422. Epub ahead of print. PMID:

34860154.

76. Chapter 18, Gottlieb, S. Uncontrolled Spread: Why COVID-19 Crushed Us and How We

Can Defeat the Next Pandemic. Harper. September 21, 2021.

77. Pile JC, Malone JD, Eitzen EM, Friedlander AM. Anthrax as a Potential Biological
Warfare Agent. Arch Intern Med. 1998;158(5):429–434. doi:10.1001/archinte.158.5.429
803
804   78. Rachael Dal Porto, Monet N. Kunz, Theresa Pistochini, Richard L. Corsi & Christopher
805   D. Cappa (2022) Characterizing the performance of a do-it-yourself (DIY) box fan air filter,
806   Aerosol Science and Technology, DOI: 10.1080/02786826.2022.2054674
807
808   79. Yicheng Zeng, Mohammad Heidarinejad, PhD, and Brent Stephens, PhD, "Portable Air
809   Cleaner Test Report 'Corsi-Rosenthal' Box Fan Air Cleaner w/ MERV 13 Filters"
810   https://www.built-envi.com/wp-content/uploads/IIT-CADR-Testing-C-R-Box-September-
811   2021.pdf
812
813   80. Elfstrom, D. "Effect of shroud size on outlet flow."
814   https://twitter.com/DavidElfstrom/status/1457390757703208966
815
816   81. Rosenthal, J. "How to Improve the Efficiency of the "Box Fan and MERV 13 Filter" Air
817   Cleaner" https://www.texairfilters.com/how-to-improve-the-efficiency-of-the-box-fan-and-
818   merv-13-filter-air-cleaner/
819
820   82. Hagan DH, Kroll JH. Assessing the accuracy of low-cost optical particle sensors using a
821   physics-based approach. Atmos Meas Tech. 2020;13(11):6343-6355. doi: 10.5194/amt-13-
822   6343-2020. Epub 2020 Nov 26. PMID: 33777248; PMCID: PMC7995643.
823
824   83. Alondra Nelson, "Let's Clear The Air On COVID", White House Office of Science
825   Technology and Policy, https://www.whitehouse.gov/ostp/news-updates/2022/03/23/lets-
826   clear-the-air-on-covid/
827
828   84. "Italian study shows ventilation can cut school COVID cases by 82%" Reuters
829   https://www.reuters.com/world/europe/italian-study-shows-ventilation-can-cut-school-covid-
830   cases-by-82-2022-03-22/
831

832   85. Hooman Parhizkar, Leslie Dietz, Andreas Olsen-Martinez, Patrick F Horve, Liliana
833   Barnatan, Dale Northcutt, Kevin G Van Den Wymelenberg, Quantifying Environmental
834   Mitigation of Aerosol Viral Load in a Controlled Chamber With Participants Diagnosed With
835   Coronavirus Disease 2019, Clinical Infectious Diseases, 2022;, ciac006,
836   https://doi.org/10.1093/cid/ciac006
837
838   86. "The effectiveness of stand alone air cleaners for shelter-in-place"
839   https://pubmed.ncbi.nlm.nih.gov/15737155/
840
841   87. Bar-On YM, Flamholz A, Phillips R, Milo R. SARS-CoV-2 (COVID-19) by the numbers.
842   Elife. 2020 Apr 2;9:e57309. doi: 10.7554/eLife.57309. PMID: 32228860; PMCID:
843   PMC7224694.
844
845   88. David Hume Foundation, March 25, 2022. "Controlled Mechanical Ventilation (CMV)
846   works" https://www.fondazionehume.it/data-analysis/controlled-mechanical-ventilation-cmv-
847   works/
848
849   89. Churchill, H. Filtration efficiency of HVAC air filters versus particle size.
850   https://twitter.com/hughchurchill/status/1428701398691102729
851
90. Indoor Air Quality Section, Environmental Health Laboratory Branch, Center for Healthy
Communities, California Department of Public Health, July 2021, "Ventilation and Filtration
to Reduce Long-Range Airborne Transmission of COVID-19 and Other Respiratory
Infections: Considerations for Reopened Schools"
https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/CDPH%20Document%2
0Library/School_ventilation_and_filtration_ADA.pdf
858
859   91. Atkinson J, Chartier Y, et. al. "Appendix E: Rationale for determining the minimum
860   ventilation rate requirements." Natural Ventilation for Infection Control in Health-Care
861   Settings. Geneva: World Health Organization; 2009. ISBN-13: 978-92-4-154785-7
862   https://www.ncbi.nlm.nih.gov/books/NBK143268/
863
92. Vincent Chi-Chung Cheng, Kitty Sau-Chun Fung, Gilman Kit-Hang Siu, Shuk-Ching
Wong, Lily Shui-Kuen Cheng, Man-Sing Wong, Lam-Kwong Lee, Wan-Mui Chan, Ka-Yee
Chau, Jake Siu-Lun Leung, Allen Wing-Ho Chu, Wai-Shan Chan, Kelvin Keru Lu, Kingsley
King-Gee Tam, Jonathan Daniel Ip, Kenneth Siu-Sing Leung, David Christopher Lung,
Herman Tse, Kelvin Kai-Wang To, Kwok-Yung Yuen, Nosocomial Outbreak of Coronavirus
Disease 2019 by Possible Airborne Transmission Leading to a Superspreading Event,
Clinical Infectious Diseases, Volume 73, Issue 6, 15 September 2021, Pages e1356–e1364,
https://doi.org/10.1093/cid/ciab313
872
873   93. "Classroom Air Change," University of San Diego COVID-19 Campus Action Plan.
874   https://www.sandiego.edu/onward/classroom-air-quality.php
875
876