

Devabhaktuni Srikrishna, Patient Knowhow Inc.

Price-performance comparison of HEPA air purifiers and lower-cost MERV 13/14 filters with box fans for filtering out SARS-Cov-2 and other particulate aerosols in indoor community settings

Devabhaktuni Srikrishna, Patient Knowhow, Inc.

sri.devabhaktuni@gmail.com

Background: SARS-Cov-2 has the potential to accumulate in the airspace of poorly ventilated, indoor spaces such as classrooms, offices, homes, restaurants, and bars because it has been detected in aerosols from exhaled breath. Separately, toxic aerosol pollution such as from wildfires, wood burning, and other sources is frequently encountered in these same locations especially with ventilation using outside air. Portable high efficiency particulate air (HEPA) air purifiers are useful to remove both types of aerosols without relying on ventilation from outside the room. However in order to meet or exceed the recommended 4 to 6 air exchanges per hour (ACH), high price-points and filter replacement costs for select HEPA air purifier models without incurring excessive noise generation make them unaffordable for many households and communities.

Objective: To compare the cost-effectiveness of aerosol filtration by commercially available, portable air cleaning devices with HEPA filters and do-it-yourself (DIY) alternatives built from box fans and HVAC filters rated at MERV 13 or 14 using single and quad filter designs.

Methods: The comparison is based on three metrics: clean air delivery rate (CADR), the noise generated (dBA), and affordability (\$\$) using an ISO-certified aerosol measurement device to measure input/output particle filtration of particles sizes ranging from 0.3 microns to 10 microns, airspeed meter to measure airflow, and NIOSH sound meter app to measure noise.

Results: Accounting for reduced filtration efficiency of MERV 13/14 filters compared to HEPA, the estimated clean air delivery rate (CADR) of a do-it-yourself (DIY) setup using 2" and 4" filters with a box fan running at fan speed 1 for tolerable noise was 278 cfm to 371 cfm, comparable or better than a commercial HEPA air purifier running at maximum speed with low noise generation at 282 cfm. The upfront cost of the components of the DIY setup were \$35-\$58 compared to the commercial HEPA air purifier at \$375. However the quad filter design, popularly known as the Corsi-Rosenthal box, did not achieve gains in CADR of more than 60% over a single filter design which is in sharp contrast to the 200-250% gains reported by UC-Davis.

Conclusions: DIY alternatives using single 1", 2" and 4" MERV 13/14 filters compare favorably to commercially available systems in terms of estimated CADR and dBA but at five to ten times lower cost. Compared to use of one filter, an improvement in CADR (air flow) was observed with a popular DIY configuration involving quad filter design, popularly known as the Corsi-Rosenthal box, not as high as reported by a recent study by UC-Davis.

Devabhaktuni Srikrishna, Patient Knowhow Inc.

Introduction

Recent studies have demonstrated the presence of live SARS-Cov-2 in micron [1] [2] and submicron [3] aerosols from the exhaled breath of infected people. Virus-carrying aerosols have the potential to accumulate in the airspace of poorly ventilated, indoor spaces such as classrooms, offices, homes, restaurants, and bars and other community settings, and if inhaled may result in COVID-19 infections [4]. Separately, toxic aerosol pollution such as from wildfires, wood burning, and other sources can be encountered in these same locations with ventilation using unfiltered, outdoor air. Portable air filtration in the form of high efficiency particulate air (HEPA) air purifiers is useful to remove both types of aerosols without relying on ventilation from outside the room.

Although in healthcare settings there are minimum specifications for ventilation and air filtration up to 15 air exchange per hour (ACH), in community settings the US-CDC does not specify a target but recommends increasing air filtration as high as possible [5]. Whereas experts recommend 4 to 6 ACH in community settings [6].

For example, in a typical classroom of size 30' x 30' classroom with 8' foot ceilings, a HEPA air purifier rated at a CADR of 300 cubic feet per minute needs 24 minutes to cycle the air once (2.5 ACH) [7] [8]. This classroom would therefore require two to three such air HEPA purifiers with sufficiently low noise generation typically costing \$400-\$500 each (with periodic \$40-\$80 filter replacements) to achieve the target ACH exceeding 4 to 6 ACH. For an upfront cost of approximately \$1000-\$1500 per classroom, this level of air filtration may be outside the budget of many schools in the US and worldwide. Approaching 15 ACH as in hospitals and passenger aircraft [9] would require further HEPA units putting it further out of reach. If portable HEPA air purifiers of sufficiently low noise generation with sufficiently high clean air delivery rate (CADR) are unaffordable for many communities, how else can they achieve target ACH while addressing [10] [11] both cost and noise generation concerns?

Lower cost alternatives to HEPA air purifiers have been investigated for air filtration and safety. For example, a Minimum Efficiency Rating Value-13 (MERV-13) filter attached to a box fan using duct tape or a bungee cord has been demonstrated to effectively filter wildfire PM2.5 and submicron particles [12]. California Air Resource Board recommends never leaving such devices unattended, and only using box fans manufactured in or after 2012 because these fans will have a fused plug to prevent electrical fires if the device is inadvertently knocked over [13]. Chemical Insights, a subsidiary of Underwriter Laboratories, recently tested five different electric box fan models (approximately 20" x 20" in size) with attached air filters and concluded that all measured temperatures fell below the maximum acceptable thresholds defined by the market safety standard for electric fans (UL 507) [14].

These lower-cost alternatives have not yet been directly compared to commercially available HEPA air purifiers in terms of filtration efficiency (%), air flow and clean air delivery rate (CADR), and noise generation (dBA). Below, we compare the cost-effectiveness of aerosol filtration by commercially available, portable air cleaning devices with HEPA filters and do-it-yourself (DIY)

Devabhaktuni Srikrishna, Patient Knowhow Inc.

alternatives built from box fans and HVAC filters rated at MERV 13 or 14. The comparison is based on three metrics: clean air delivery rate (CADR), the noise generated (dBA), and affordability (\$\$). The test devices include an ISO-certified aerosol measurement device to measure input/output particle filtration of particles sizes ranging from 0.3 microns to 10 microns, airspeed meter to measure airflow, and NIOSH sound meter app to measure noise. We also evaluate a DIY configuration involving quad filter design, popularly known as the Corsi-Rosenthal box, that has been in use to enhance the airflow and CADR over a single filter design.

Devabhaktuni Srikrishna, Patient Knowhow Inc.

Methods

Aerosol filtration efficiency. For each HEPA air purifier or box fan filter, counts at each particle size (0.3, 0.5, 0.7, 1.0, 2.5, 5, and 10 in microns) were tested using an ISO-certified particle counter (Temtop Particle Counter PMD 331) with the filter turned 'on' and 'off' consecutively. Five counts were recorded and averaged on the particle counter when its input was placed directly at the output of the air purifier/filter for 30 seconds. The efficiency at each particle size was estimated by the formula, efficiency = 1 - on / off.

Air flow. For each HEPA air purifier or box fan filter, the airspeed was measured using an anemometer (BTMETER BT-100 Handheld Anemometer) held at the output and also input (if possible). An average of four airspeed measurements (feet per minute) were multiplied by the area of the input or output to estimate the airflow (cubic feet per minute).

Noise. Noise measurements were taken for each air purifier/filter using an iPhone app maintained by National Institute for Occupational Safety and Health (NIOSH) [15]. Three noise measurements were taken at a 9" distance perpendicular to the direction of the output airflow and averaged.

Commercially available HEPA air purifiers. Three models evaluated include the Coway Airmega 300, Coway AP-1512HH, and Airthereal AHG550.

Commercial Air Purifier	Price (Amazon)	CADR (cubic feet per minute)
Coway Airmega 300	\$375	285 [16]
Coway AP-1512HH	\$164	233 [17]
Airthereal AHG550	\$229	324 [18]

HVAC filters with box fan. For DIY configurations, the box fan used is a 20" Lasko Fan which costs \$20 (Home Depot) along with the following HVAC filters made by Nordic Pure. A shroud made of cardboard of 14" diameter was attached to the output side (front) of the fan to improve airflow. For comparison, two methods of attaching the box fan to the air filters included vacuum (no attachment just relying on airflow), duct tape, and velcro.

HVAC Filter size	MERV rating	Unit Price (Amazon)
20" x 20" x 1"	14	\$11
20" x 20" x 2"	13	\$15
20" x 20" x 4"	14	\$38

Devabhaktuni Srikrishna, Patient Knowhow Inc.

Results

Commercial HEPA air purifiers. The results for the commercial air purifiers show particle filtration efficiencies near or exceeding 90% at all particle sizes ranging from 0.3 to 10 microns. At their maximum fan speed, the noise generated by the Coway Airmega 300 was lowest and most (subjectively) tolerable of the three models. To achieve similar tolerability levels both the Coway AP-1512 and the Airthereal AGH550 had to be set at fan speed 2 which cut their estimated airflow (CADR) roughly in half.

		Coway Airmega 300	Coway AP-1512	Coway AP-1512	Airthereal AGH550	Airthereal AGH550
	Price (est.)	\$375	\$164	\$164	\$229	\$229
	Fan speed	3	3	2	5	2
	Noise (dBA) avg of three measurements 9" away	59	64	46	66	47
	Estimated Airflow (output) cfm	282	222	97	410	206
Filtration Efficiency (%) avg of five measurements						
	0.3 microns	94.00%	97.00%		87.00%	
	0.5 microns	95.00%	98.00%		90.00%	
	0.7 microns	97.00%	99.00%		91.00%	
	1.0 microns	97.00%	99.00%		93.00%	
	2.5 microns	98.00%	98.00%		94.00%	
	5 microns	98.00%	98.00%		96.00%	
	10 microns	98.00%	98.00%		98.00%	

Devabhaktuni Srikrishna, Patient Knowhow Inc.

Box fan plus single MERV 13/14 filter. The filtration efficiency of the MERV 13/14 filters varied by thickness with highest observed for 4” filters compared to 1” filters, and also at higher particle sizes above 1 micron exceeding 90%. The box fan was (subjectively) tolerable only at fan speed one (out of three). Compared to 282 cfm for the Coway Airmega 300 (\$375) at fan speed 3, at fan speed 1, the box fan has estimated CADR of 371 cfm at for 70% filtration efficiency with the 4” MERV 14 filter (\$58) and 278 cfm at 60% efficiency for the 2” MERV 13 filter (\$38),

		4” MERV 14	4” MERV 14	4” MERV 14	2” MERV 13	2” MERV 13	2” MERV 13	1” MERV 14	1” MERV 14	1” MERV 14	1” MERV 14	1” MERV 14	1” MERV 14
Price (est.)		\$58	\$58	\$58	\$35	\$35	\$35	\$31	\$31	\$31	\$31	\$31	\$31
Seal		vacuum	tape	tape	tape								
Fan speed		3	2	1	3	2	1	3	2	1	3	2	1
Noise (dBA) avg of three measurements 9" away		63	60	54	62	58	52	64	60	55			
Estimated Airflow (input) cfm		997	709	556	644	491	382	545	361	228			
Estimated Airflow (output) cfm		700	649	530	660	588	464	618	538	386			
Filtration Efficiency (%) avg of five measurements													
	0.3 microns	70.00%			61.00%			56.00%		60.00%	59%		63%
	0.5 microns	75.00%			65.00%			60%		62.00%	62%		65%
	0.7 microns	88.00%			79.00%			69.00%		63.00%	73%		70%
	1.0 microns	92.00%			83.00%			69.00%		64.00%	74%		69%
	2.5 microns	95.00%			84.00%			71.00%		66.00%	75%		63%
	5 microns	96.00%			88.00%			54.00%		71.00%	64%		61%
	10 microns	96.00%			90.00%			34.00%		61.00%	41%		29%

Devabhaktuni Srikrishna, Patient Knowhow Inc.

Box fan plus quad MERV 13/14 filters. The quad filter design, popularly known as the Corsi-Rosenthal box, showed significant improvement over single filters with using comparably rated filters and fan speeds. With the quad 1" MERV 14 filters at fan speed 1, the output airflow was 617 cfm versus 386 cfm with a single filter at that fan speed for an improvement of 60%. Similarly with 2" MERV 13 filter the improvement was only 35%. These results are in contrast to approximately 200%-250% improvement between single filter and quad filter designs (also with shroud and 20" Lasko box fan) reported in a study by UC-Davis [19]. Notably, there was almost no difference in output airflow when the 1" air filters were attached with duct tape (sealed airtight) or velcro (loose fitting) suggesting any leaks created by a loose fit are likely insignificant.

		quad 1" MERV 14	quad 2" MERV 13	quad 2" MERV 13	quad 2" MERV 13					
	Price (est.)	\$64	\$64	\$64	\$64	\$64	\$64	\$80	\$80	\$80
	Seal	Velcro	Velcro	Velcro	Tape	Tape	Tape	Velcro	Velcro	Velcro
	Fan speed	3	2	1	3	2	1	3	2	1
	Noise (dBA) avg of three measurements 9" away									
	Estimated Airflow (input) cfm									
	Estimated Airflow (output) cfm	850	757	617	850	744	593	870	802	626
Filtration Efficiency (%) avg of five measurements	0.3 microns				77%	81%	81%	72%	78%	68%
	0.5 microns				80%	84%	84%	75%	80%	70%
	0.7 microns				87%	88%	88%	76%	82%	73%
	1.0 microns				88%	89%	88%	76%	84%	75%
	2.5 microns				89%	91%	90%	76%	84%	73%
	5 microns				90%	93%	93%	65%	81%	74%
	10 microns				87%	85%	95%	41%	73%	79%

Devabhaktuni Srikrishna, Patient Knowhow Inc.

Discussion

Accounting for reduced filtration efficiency of MERV 13/14 filters compared to HEPA, the estimated clean air delivery rate (CADR) of a do-it-yourself (DIY) setup using 2" and 4" filters with a box fan running at fan speed 1 for tolerable noise was 278 cfm to 371 cfm, comparable or better than a commercial HEPA air purifier running at maximum speed with low noise generation (Coway Airmega 300) at 282 cfm. Yet the upfront cost of the components of the DIY setup were 5 to 10 times less (\$35-\$58) than the commercial HEPA air purifier (\$375). The DIY setup also did not require tape but could be assembled with loose-fitting velcro or simply attached by the vacuum of the fan.

However the quad filter design, popularly known as the Corsi-Rosenthal box, did not achieve gains in CADR of more than 60% over a single filter design which is in sharp contrast to the 200-250% gains reported by UC-Davis [19]. The reason why there is a discrepancy between the results reported here and by UC-Davis remains to be reconciled. Anecdotally, we observed that the airflow was non-uniform across all four filters which may be responsible for this.

Given the simplicity and low-cost of the box-fan design using single 2" or 4" MERV 13/14 filters, form-factor improvements may include a more stable frame so it is not so easy to knock over with visual designs such as wallpaper to make it aesthetically pleasing. Also a mosquito screen on the front of the fan may help prevent curious fingers from contacting the fan blade which may be especially important for classroom and home applications when young children are present.

Acknowledgements

We would like to thank Hugh Churchill, Dan Jaffe, Amalavoyal Narsimha Chari, and Robert Freedman for their helpful discussions and advice.

References

[1] Coleman KK, Tay DJW, Sen Tan K, Ong SWX, Son TT, Koh MH, Chin YQ, Nasir H, Mak TM, Chu JJH, Milton DK, Chow VTK, Tambyah PA, Chen M, Wai TK. Viral Load of SARS-CoV-2 in Respiratory Aerosols Emitted by COVID-19 Patients while Breathing, Talking, and Singing. *Clin Infect Dis*. 2021 Aug 6:ciab691. doi: 10.1093/cid/ciab691. Epub ahead of print. PMID: 34358292; PMCID: PMC8436389.

[2] Adenaiye OO, Lai J, de Mesquita PJB, Hong F, Youssefi S, German J, Tai SS, Albert B, Schanz M, Weston S, Hang J, Fung C, Chung HK, Coleman KK, Sapoval N, Treangen T, Berry IM, Mullins K, Frieman M, Ma T, Milton DK; University of Maryland StopCOVID Research Group. Infectious SARS-CoV-2 in Exhaled Aerosols and Efficacy of Masks During Early Mild Infection. *Clin Infect Dis*. 2021 Sep 14:ciab797. doi: 10.1093/cid/ciab797. Epub ahead of print. PMID: 34519774; PMCID: PMC8522431.

Devabhaktuni Srikrishna, Patient Knowhow Inc.

[3] Santarpia JL, Herrera VL, Rivera DN, Ratnesar-Shumate S, Reid SP, Ackerman DN, Denton PW, Martens JWS, Fang Y, Conoan N, Callahan MV, Lawler JV, Brett-Major DM, Lowe JJ. The size and culturability of patient-generated SARS-CoV-2 aerosol. *J Expo Sci Environ Epidemiol*. 2021 Aug 18:1–6. doi: 10.1038/s41370-021-00376-8. Epub ahead of print. PMID: 34408261; PMCID: PMC8372686.

[4] Scientific Brief: SARS-CoV-2 Transmission. Centers for Disease Control and Prevention. May 7, 2021. <https://www.cdc.gov/coronavirus/2019-ncov/science/science-briefs/sars-cov-2-transmission.html>

[5] Ventilation in Buildings. Centers for Disease Control and Prevention. June 2, 2021. <https://www.cdc.gov/coronavirus/2019-ncov/community/ventilation.html>

[6] Allen JG, Ibrahim AM. Indoor Air Changes and Potential Implications for SARS-CoV-2 Transmission. *JAMA*. 2021;325(20):2112–2113. doi:10.1001/jama.2021.5053

[7] <https://www.patientknowhow.com/hepascalculator.html>

[8] <https://www.hsph.harvard.edu/news/hsph-in-the-news/experts-offer-advice-on-air-purifiers-for-classrooms/>

[9] Bhuvan KC, Shrestha R, Leggat PA, Ravi Shankar P, Shrestha S. Safety of air travel during the ongoing COVID-19 pandemic. *Travel Med Infect Dis*. 2021 Sep-Oct;43:102103. doi: 10.1016/j.tmaid.2021.102103. Epub 2021 Jun 7. PMID: 34111566; PMCID: PMC8180446.

[10] Duill FF, Schulz F, Jain A, Krieger L, van Wachem B, Beyrau F. The Impact of Large Mobile Air Purifiers on Aerosol Concentration in Classrooms and the Reduction of Airborne Transmission of SARS-CoV-2. *Int J Environ Res Public Health*. 2021 Nov 2;18(21):11523. doi: 10.3390/ijerph182111523. PMID: 34770037

[11] Bluysen PM, Ortiz M, Zhang D. The effect of a mobile HEPA filter system on 'infectious' aerosols, sound and air velocity in the SenseLab. *Build Environ*. 2021 Jan 15;188:107475. doi: 10.1016/j.buildenv.2020.107475. Epub 2020 Dec 3. PMID: 33293755; PMCID: PMC7711180.

[12] May, N.W., Dixon, C., Jaffe, D.A. (2021). Impact of Wildfire Smoke Events on Indoor Air Quality and Evaluation of a Low-cost Filtration Method. *Aerosol Air Qual. Res.* 21, 210046. <https://doi.org/10.4209/aaqr.210046>

[13] <https://ww2.arb.ca.gov/protecting-yourself-wildfire-smoke>

[14] <https://chemicalinsights.org/wp-content/uploads/DIY-Box-Fan-Report-2021.pdf>

[15] <https://www.cdc.gov/niosh/topics/noise/app.html>

Devabhaktuni Srikrishna, Patient Knowhow Inc.

[16] <https://cowaymega.com/products/coway-airmega-300>

[17] <https://cowaymega.com/products/coway-mighty-ap-1512hh>

[18]

<https://airthereal.com/products/open-box-airthereal-glory-days-agh550-hepa-air-purifier-up-to-750-sq-ft>

[19]

https://energy.ucdavis.edu/wp-content/uploads/Case-Study_DIY-Portable-Air-Cleaners-083121.pdf