

Supplementary Materials for

Exhaled CO₂ as COVID-19 infection risk proxy for different indoor environments
and activities

Z. Peng, J. L. Jimenez.

Correspondence to: jose.jimenez@colorado.edu

This PDF file includes:

Materials and Methods

Figs. S1 to S3

Tables S1 to S3

Materials and Methods

Derivation of Eqs. 3 and 5

The evolutions of both expected value of SARS-CoV-2 concentration ($\langle c \rangle$, in quanta m^{-3}) corresponding to a certain prevalence of infectors in local population (P_I) and excess CO_2 volume mixing ratio (Δc_{CO_2}) over time (t) can be expressed in terms of emission and loss rates:

$$\frac{d\langle c \rangle}{dt} = \frac{\langle E \rangle}{V} - \lambda \langle c \rangle \quad (\text{S1})$$

$$\frac{d\Delta c_{\text{CO}_2}}{dt} = \frac{E_{\text{CO}_2}}{V} - \lambda_0 \Delta c_{\text{CO}_2} \quad (\text{S2})$$

where $\langle E \rangle$ and E_{CO_2} are the expected value of SARS-CoV-2 emission rate (in quanta h^{-1}) and excess CO_2 volume emission rate ($\text{m}^3 \text{h}^{-1}$), respectively. $\lambda \langle c \rangle$ and $\lambda_0 \Delta c_{\text{CO}_2}$ are the loss rates of SARS-CoV-2 and excess CO_2 , respectively. λ_0 is the first-order of loss rate coefficient of excess CO_2 as CO_2 is only lost through ventilation. $\langle E \rangle$ and E_{CO_2} can be further expanded as

$$\langle E \rangle = P_I(N - 1)E_p(1 - m_{ex}) \quad (\text{S3})$$

$$E_{\text{CO}_2} = NE_{p,\text{CO}_2} \quad (\text{S4})$$

Equation S4 is easy to understand. $P_I(N - 1)$ represents the expected value of the number of infectors. Since to calculate the probability of infection of a susceptible person, that person should be excluded from the occupants possibly being infectors, resulting in the $(N - 1)$ term.

Inserting Eqs. S3 and S4 into Eqs. S1 and S2, respectively, and solving the resulted differential equations (under the assumption of no SARS-CoV-2 and of the same CO_2 concentration as outdoors initially) gives

$$\langle c \rangle = \frac{P_I(N-1)E_p(1-m_{ex})}{\lambda V} (1 - e^{-\lambda t}) \quad (\text{S5})$$

$$\Delta c_{\text{CO}_2} = \frac{NE_{p,\text{CO}_2}}{\lambda_0 V} (1 - e^{-\lambda_0 t}) \quad (\text{S6})$$

The averages of $\langle c \rangle$ and Δc_{CO_2} during $[0, D]$ are thus obtained below

$$\langle c_{avg} \rangle = \int_0^D \langle c \rangle dt = \frac{P_I(N-1)E_p(1-m_{ex})}{V} \cdot \left(\frac{1}{\lambda} - \frac{1-e^{-\lambda D}}{\lambda^2 D} \right) \quad (\text{S7})$$

$$\Delta c_{avg,\text{CO}_2} = \int_0^D \Delta c_{\text{CO}_2} dt = \frac{NE_{p,\text{CO}_2}}{V} \cdot \left(\frac{1}{\lambda_0} - \frac{1-e^{-\lambda_0 D}}{\lambda_0^2 D} \right) \quad (\text{S8})$$

Volume mixing ratio of the excess CO_2 that an uninfected individual inhales for 1 h in that environment for certain infection risk

Rudnick and Milton (8) derived the excess CO_2 concentration corresponding to R_0 of 1 ($\frac{E_{p,\text{CO}_2}}{E_{pBD}}$) for an aerosol-transmitted respiratory infectious disease during an indoor event under the assumptions of large N and $\lambda \approx \lambda_0$. Unity R_0 is related to conditional probability of infection (for cases where one infector is present). P_I is thus not considered in this type of problems. When Eq. 7 is applied under the assumptions of large N and $\lambda \approx \lambda_0$, $\Delta c_{\text{CO}_2}^*$ is proportional to $\frac{E_{p,\text{CO}_2}}{E_{pBD}}$ (with $D = 1$ h).

E_p , E_{p,CO_2} , and B for different activities and associated uncertainties

E_p , E_{p,CO_2} , and B are all functions of activity according to the literature (14–17). However, they have different domains in the literature studies. For E_{p,CO_2} , level of physical activity is quantified by a continuous variable, M in MET (metabolic equivalent of task) (16). E_{p,CO_2} is also a function of basic metabolic rate, which primarily depends on age, sex, body size, and body

composition of a person (16). For the data of B (17), the levels of physical activity are discrete (“Sleep or Nap”, “Sedentary/Passive”, “Light Intensity”, “Moderate Intensity”, and “High Intensity”), and the data are also classified by age but not by sex.

To make the data of E_{p,CO_2} and B directly comparable, we take the averages of BMR for the males and females in the age ranges corresponding to the data of B in (17), except for the range of 1–3 y as a single category (two categories, i.e., 1–2 and 2–3, in (17)), and roughly assign “Sleep or Nap”, “Sedentary/Passive”, “Light Intensity”, “Moderate Intensity”, and “High Intensity” to $M = 1, 1.5, 2, 3.5,$ and 5 MET, respectively (13). Then a quantity that involves E_{p,CO_2} and B and is critical for $\Delta c_{CO_2}^*$, $\frac{E_{p,CO_2}}{B}$, i.e., fraction of CO_2 in exhaled air, is calculated for the abovementioned discrete levels of physical activity for people in different age ranges (Fig. S3). At a specific physical activity level, $\frac{E_{p,CO_2}}{B}$ does not vary strongly with age for groups with age > 11 y (BMR > 6 MJ/d). Averages are thus taken for the groups with similar $\frac{E_{p,CO_2}}{B}$ at certain M (Table S3). These averages are used in the infection risk analysis for different activities in the Main Text.

Buonanno et al. (14, 15) estimated E_p at different levels of physical activity as well as vocalization. In their estimates, there are only four levels of physical activities, i.e., “Resting”, “Standing”, “Light exercise”, and “Heavy exercise”. These four levels roughly correspond to “Sleep or Nap”, “Sedentary/Passive”, “Light Intensity”, and “High Intensity”. An interpolation is made by taking the geometric mean of E_p at the “Light exercise”, and “Heavy exercise” levels to generate data for E_p at a “Moderate exercise” level, corresponding to “Moderate Intensity” for the B data (Table S3). The dimension of vocalization for the E_p data from Buonanno et al. is preserved in this study, as degree of vocalization is critical in determining E_p (14, 15). For all activities listed in Fig. 2B and Table S3, the data of E_p and $\frac{E_{p,CO_2}}{B}$ are now available and the relevant infection risk analysis can be done.

Large uncertainties are associated with the data of E_p and $\frac{E_{p,CO_2}}{B}$ in Table S3. The E_p estimates themselves are highly uncertain, with possible ranges often spanning over an order of magnitude (14, 15). The discretization of physical activity level can also be a major uncertainty source, as there are only five discrete levels to cover the domain of a continuous variable M .




Fig. S1.

Ratio of inhaled excess CO₂ volume to inhaled SARS-CoV-2 quanta (m³ quantum⁻¹) for **(A)** variants of the university class case (see Table S1 for the case details) and **(B)** several indoor environments (see Table S3 for the case details).




Fig. S2.

Value of the fraction term involving λ , λ_0 , and D in Eqs. 6 and 7 as a function of λD .




Fig. S3.

Fraction of CO₂ in exhaled air at several physical activity levels (represented by the variable M ; see Materials and Methods for detail) for different age groups (colored by corresponding basic metabolic rates).

Table S1.

Parameter settings (number of occupants, N ; volume of the indoor environment, V ; SARS-CoV-2 exhalation rate, E_p ; breathing rate, B ; probability of an occupant being infector, P_I ; duration, D ; mask filtration efficiency for exhalation, m_{ex} ; mask filtration efficiency for inhalation, m_{in} ; ventilation rate, λ_0 ; first-order SARS-CoV-2 loss rate coefficient, λ) of the case for a typical university class and of its variants. Expected value of the amount of SARS-CoV-2 inhaled by an uninfected individual ($\langle n \rangle$), average excess CO₂ volume mixing ratio ($\Delta c_{avg,CO_2}$), and the volume mixing ratio of the excess CO₂ that an uninfected individual inhales for 1 h in that environment for a probability of infection of 0.01% ($\Delta c_{CO_2}^*$) of these cases are also shown.

| Case | N | V (m ³) | E_p (quanta h ⁻¹) | E_{p,CO_2} (m ³ h ⁻¹) | B (m ³ h ⁻¹) | P_{im} | P_I | D (h) | m_{ex} | m_{in} | λ_0 (h ⁻¹) | λ (h ⁻¹) | $\langle n \rangle$ (quanta) | $\Delta c_{avg,CO_2}$ (ppm) | $\Delta c_{CO_2}^*$ (ppm) |
|---------------------------------|-----|-----------------------|---------------------------------|--|---------------------------------------|----------|------------|-----------|----------|----------|--------------------------------|------------------------------|------------------------------|-----------------------------|---------------------------|
| Infectious instructor (default) | 10 | 142 | 100 | 0.020 3 | 0.516 | 0 | 0.001 | 0.83 3 | 0.5 | 0.3 | 3 | 3.92 | 1.70E-04 | 302 | 148 |
| Infectious student | 10 | 142 | 4 | 0.020 3 | 0.516 | 0 | 0.001 | 0.83 3 | 0.5 | 0.3 | 3 | 3.92 | 6.87E-06 | 302 | 3670 |
| Physical education class | 10 | 142 | 13.5 | 0.073 2 | 3 | 0 | 0.001 | 0.83 3 | 0.5 | 0.3 | 3 | 3.92 | 1.34E-04 | 1089 | 678 |
| N95 respirators | 10 | 142 | 100 | 0.020 3 | 0.516 | 0 | 0.001 | 0.83 3 | 0.9 | 0.9 | 3 | 3.92 | 4.91E-06 | 302 | 5130 |
| No mask | 10 | 142 | 100 | 0.020 3 | 0.516 | 0 | 0.001 | 0.83 3 | 0 | 0 | 3 | 3.92 | 4.78E-04 | 302 | 52.7 |
| New York City | 10 | 142 | 100 | 0.020 3 | 0.516 | 0 | 0.023 | 0.83 3 | 0.5 | 0.3 | 3 | 3.92 | 3.91E-03 | 302 | 6.45 |
| Boulder, CO | 10 | 142 | 100 | 0.020 3 | 0.516 | 0 | 0.000 3 | 0.83 3 | 0.5 | 0.3 | 3 | 3.92 | 5.11E-05 | 302 | 493 |
| Double duration | 10 | 142 | 100 | 0.020 3 | 0.516 | 0 | 0.001 | 1.66 7 | 0.5 | 0.3 | 3 | 3.92 | 4.03E-04 | 383 | 158 |
| Extra virus removal | 10 | 142 | 100 | 0.020 3 | 0.516 | 0 | 0.001 | 0.83 3 | 0.5 | 0.3 | 3 | 8.92 | 9.22E-05 | 302 | 273 |
| Double ventilation | 10 | 142 | 100 | 0.020 3 | 0.516 | 0 | 0.001 | 0.83 3 | 0.5 | 0.3 | 6 | 6.92 | 1.13E-04 | 191 | 141 |

Table S2.

SARS-CoV-2 exhalation rate (E_p), fraction of CO₂ in exhaled air ($\frac{E_{p,CO_2}}{B}$), and volume mixing ratio of the excess CO₂ that an uninfected individual inhales for 1 h in that environment for a probability of infection of 0.01% ($\Delta c_{CO_2}^*$) for activities with different physical and vocal levels. $\Delta c_{CO_2}^*$ is estimated with probability of an occupant being infector of 0.1% and ventilation accounting for all SARS-CoV-2 loss.

| Activity | E_p (quanta h ⁻¹) | $\frac{E_{p,CO_2}}{B}$ | $\Delta c_{CO_2}^*$ (ppm) |
|-------------------------------------|---------------------------------|------------------------|---------------------------|
| Resting – breathing | 2 | 0.0428 | 2140 |
| Resting – speaking | 9.4 | 0.0428 | 455 |
| Resting – loudly speaking | 60.5 | 0.0428 | 70.7 |
| Standing – breathing | 2.3 | 0.0656 | 2850 |
| Standing – speaking | 11.4 | 0.0656 | 575 |
| Standing – loudly speaking | 65.1 | 0.0656 | 101 |
| Light exercise – breathing | 5.6 | 0.0342 | 611 |
| Light exercise – speaking | 26.3 | 0.0342 | 130 |
| Light exercise – loudly speaking | 170 | 0.0342 | 20.1 |
| Moderate exercise – breathing | 8.7 | 0.0280 | 322 |
| Moderate exercise – speaking | 40.7 | 0.0280 | 68.8 |
| Moderate exercise – loudly speaking | 263 | 0.0280 | 10.7 |
| Heavy exercise – breathing | 13.5 | 0.0214 | 158 |
| Heavy exercise – speaking | 63.1 | 0.0214 | 33.8 |
| Heavy exercise – loudly speaking | 408 | 0.0214 | 5.23 |

Table S3.

Same format as Table S1, but for different environments, i.e., a university class, the Skagit County choir superspreading event (19), a subway car, a supermarket (focused on a worker), and an event in a stadium. Values of parameters are typical of real environments that we have analyzed.

| Case | N | V (m ³) | E_p (quant a h ⁻¹) | E_{p,CO_2} (m ³ h ⁻¹) | B (m ³ h ⁻¹) | P_{im} | P_I | D (h) | m_e _{x} | m_{in} | λ_0 (h ⁻¹) | λ (h ⁻¹) | $\langle n \rangle$ (quanta) | $\Delta c_{avg,CO_2}$ (ppm) | $\Delta c_{CO_2}^*$ (ppm) |
|------------------|-------|-----------------------|--|---|---|----------|-------------|-----------|------------------------------------|----------|-----------------------------------|---------------------------------|---------------------------------|--------------------------------|------------------------------|
| Class | 10 | 142 | 100 | 0.020 3 | 0.51 6 | 0 | 0.001 | 0.83 3 | 0. 5 | 0. 3 | 3 | 3.92 | 1.70E-04 | 302 | 148 |
| Choir | 61 | 810 | 970 | 0.037 0 | 1.56 | 0 | 0.0001 1 | 2.5 | 0 | 0 | 0.7 | 1.62 | 1.42E-02 | 2102 | 91.3 |
| Subway | 35 | 150 | 25 | 0.028 5 | 0.42 | 0.15 | 0.001 | 0.33 3 | 0. 5 | 0. 3 | 5.7 | 10.2 2 | 1.66E-05 | 645 | 1270 |
| Super- market | 75 | 2040 | 10 | 0.027 5 | 0.72 | 0 | 0.001 | 8 | 0. 5 | 0. 3 | 3 | 3.92 | 1.69E-04 | 322 | 1450 |
| Stadium | 31000 | 25500 0 | 50 | 0.024 8 | 0.72 | 0 | 0.001 | 1.5 | 0 | 0 | 40 | 40.9 2 | 1.58E-04 | 74 | 56.2 |